



-FLYLEREV-

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S- 102	CL	11+20	0.00- 1.80	A-2-4(0)	18	5	39.4	29.3	7.1	24.2	100	79	35	-	-
S- 103	CL	11+20	4.00- 7.41	A-4(1)	33	8	33.7	29.9	16.2	20.2	100	80	42	-	-
S- 275	CL	31+90	0.50- 1.20	A-7-6(6)	42	20	31.0	21.5	13.3	34.2	94	76	48	-	-
S- 297	CL	31+90	1.78- 2.38	A-2-4(0)	26	5	39.2	26.8	15.9	18.1	91	65	35	-	-
SS- 319	CL	32+50	1.18- 1.63	A-5(1)	42	9	33.7	28.8	19.4	18.1	100	80	43	-	-
SS- 320	CL	32+50	4.22- 4.67	A-2-4(0)	40	NP	38.1	35.7	18.1	8.1	94	71	33	-	-
SS- 321	CL	32+50	8.78- 9.23	A-4(0)	32	NP	15.9	53.8	22.2	8.1	100	96	40	-	-
SS- 322	CL	32+50	11.82- 12.27	A-4(0)	33	NP	20.4	47.4	26.2	6.0	100	83	45	-	-

-FLYLWREV-

SOIL TEST RESULTS															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS- 342	CL	11+40	0.15- 0.60	A-7-6(18)	55	30	21.0	19.8	12.8	46.4	100	89	64	-	-
SS- 343	CL	11+40	1.12- 1.57	A-7-5(5)	50	13	23.0	31.9	16.9	28.3	100	87	52	-	-
SS- 344	CL	11+40	2.64- 3.09	A-2-4(0)	29	NP	40.0	39.8	16.2	4.0	100	76	28	-	-
SS- 345	CL	11+40	4.16- 4.61	A-2-5(0)	41	NP	31.3	43.8	16.9	8.1	100	81	33	-	-
S- 346	CL	10+80	0.50- 1.08	A-7-6(13)	52	26	27.0	16.5	18.1	38.3	98	81	59	-	-
SS- 360	CL	13+12.5	0.15- 0.60	A-7-6(10)	46	25	29.9	19.4	10.4	40.4	100	84	53	-	-
SS- 361	CL	13+12.5	1.18- 1.63	A-2-4(0)	27	9	44.7	32.3	7.8	15.2	100	76	27	-	-
SS- 362	CL	13+12.5	2.70- 3.15	A-4(0)	39	NP	24.4	38.2	29.3	8.1	100	91	42	-	-
SS- 363	CL	13+12.5	4.22- 4.67	A-5(0)	41	NP	31.1	34.7	28.1	6.1	100	86	42	-	-
SS- 364	CL	13+12.5	5.64- 6.09	A-4(1)	38	NP	16.5	17.4	61.9	4.1	93	84	64	-	-
SS- 365	CL	13+12.5	7.16- 7.61	A-2-4(0)	28	NP	39.0	38.0	19.0	4.0	98	80	30	-	-