



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.L.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-196	30 RT	10+25	1.22-1.67	A-7-6(7)	43	18	25.9	26.7	17.2	30.3	100	86	52	-	-
SS-197	30 RT	10+25	2.74-3.19	A-2-4(0)	35	NP	39.0	34.3	18.6	8.1	96	73	32	-	-
SS-198	30 RT	10+25	4.27-4.72	A-2-4(0)	32	NP	39.8	34.3	17.8	8.1	99	74	31	-	-
SS-199	30 RT	10+25	7.32-7.77	A-2-4(0)	31	NP	38.8	39.0	16.2	6.1	99	76	29	-	-
S-338	CL	10+80	0.50-1.00	A-7-6(13)	48	27	24.4	22.2	19.1	34.3	100	88	58	-	-
S-339	CL	10+80	2.00-2.80	A-7-6(9)	47	18	21.2	23.8	12.6	42.4	100	91	59	-	-
S-340	CL	10+80	3.50-3.94	A-6(4)	36	12	28.1	25.2	30.6	16.1	100	84	52	-	-
S-341	CL	10+80	8.00-10.02	A-4(0)	25	5	24.4	33.3	20.1	22.2	100	88	48	-	-
S-347	CL	11+40	0.50-1.06	A-7-6(22)	62	37	23.2	15.5	14.8	46.4	100	85	64	-	-
SS-349	CL	12+00	0.15-0.60	A-7-6(4)	41	13	26.8	28.9	22.1	22.2	97	82	48	-	-
SS-350	CL	12+00	1.18-1.63	A-2-4(0)	35	NP	40.4	37.3	14.2	8.1	98	77	28	-	-
SS-351	CL	12+00	4.22-4.67	A-2-4(0)	30	NP	43.2	34.5	16.2	6.1	97	72	28	-	-
SS-352	CL	12+00	7.26-7.71	A-2-4(0)	35	NP	40.8	31.5	19.7	8.1	99	72	34	-	-
S-356	40RT	12+40	0.50-1.00	A-6(7)	39	18	28.3	23.0	12.4	36.3	100	83	53	-	-
S-357	CL	12+60	0.50-1.00	A-7-5(19)	62	28	17.6	17.8	14.2	50.5	100	91	67	-	-
S-358	CL	12+73.6	0.50-1.00	A-7-6(14)	50	21	13.7	23.6	16.2	46.4	100	95	67	-	-
S-366	CL	13+30	0.60-1.00	A-7-6(10)	47	28	31.3	21.6	12.7	34.3	100	83	50	-	-
S-367	CL	13+30	2.70-3.00	A-7-6(6)	41	18	29.9	22.6	19.2	28.3	100	84	51	-	-
S-368	CL	13+30	3.60-4.00	A-7-6(5)	42	13	28.3	22.6	26.9	22.2	100	83	53	-	-
S-369	CL	13+30	6.80-7.20	A-4(0)	40	6	40.2	24.4	23.2	12.1	100	73	41	-	-
SS-372	CL	13+80	0.15-0.60	A-7-5(44)	84	48	11.7	8.7	14.9	64.6	100	93	81	-	-
SS-373	CL	13+80	1.29-1.74	A-7-5(11)	62	18	23.0	26.7	28.1	22.2	100	86	58	-	-
SS-374	CL	13+80	4.33-4.78	A-5(0)	50	NP	27.3	37.2	27.5	8.1	100	83	45	-	-
SS-375	CL	13+80	8.89-9.34	A-4(0)	35	NP	33.5	39.0	23.4	4.0	100	83	36	-	-
SS-376	CL	14+40	0.15-1.10	A-7-5(33)	73	42	16.0	12.5	45.3	26.3	100	91	74	-	-
SS-377	CL	14+40	2.66-4.18	A-7-6(9)	47	18	23.8	25.3	40.8	10.1	100	88	57	-	-
SS-378	CL	14+40	5.00-5.70	A-4(1)	38	NP	28.1	36.8	25.1	10.1	100	84	44	-	-
S-387	CL	15+00	0.15-1.00	A-7-6(7)	44	25	34.9	23.2	13.5	28.3	100	81	45	-	-
SS-385	CL	15+60	1.27-1.72	A-5(5)	52	10	24.0	30.7	25.1	20.2	100	85	53	-	-
SS-386	CL	15+60	2.79-3.24	A-7-5(4)	49	13	25.5	38.0	8.3	28.3	100	85	47	-	-
SS-383	CL	16+80	1.12-1.57	A-7-6(15)	55	28	20.8	25.5	21.4	32.3	100	90	59	-	-
SS-384	CL	16+80	2.64-3.09	A-4(0)	33	NP	34.3	32.9	26.7	6.1	100	80	39	31.5	-