


50 40 30 20 10 0 10 20 30 40 50

SOIL TEST RESULTS

| SAMPLE NO. | OFFSET | STATION | DEPTH INTERVAL | AASHTO CLASS. | L.L. | P.I. | % BY WEIGHT | | | | % PASSING (SIEVES) | | | % MOISTURE | % ORGANIC |
|------------|--------|---------|----------------|---------------|------|------|-------------|---------|------|------|--------------------|----|-----|------------|-----------|
| | | | | | | | C. SAND | F. SAND | SILT | CLAY | 10 | 40 | 200 | | |
| S-111 | CL | 13+40 | 0.00-2.50 | A-7-5(35) | 78 | 31 | 3.6 | 15.1 | 15.0 | 66.3 | 100 | 99 | 86 | - | - |
| S-112 | CL | 13+40 | 2.50-4.00 | A-7-5(28) | 83 | 35 | 10.7 | 25.5 | 21.6 | 42.2 | 100 | 96 | 69 | - | - |



50 40 30 20 10 0 10 20 30 40 50