


2/13/08



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-100	35M RT	57+05	1.91 - 2.36	A-5(0)	60	NP	26.1	44.3	15.5	14.2	100	90	36		
SS-101	35M RT	57+05	4.04 - 4.49	A-5(0)	52	NP	25.5	39.8	20.5	14.2	100	87	43		
SS-102	35M RT	57+05	5.56 - 6.01	A-7-5(4)	55	15	23.1	41.7	21.1	14.2	100	89	65		
SS-96	CL	57+17	0.45 - 0.90	A-2-4(0)	26	9	23.0	47.8	15.1	14.4	95	86	33		
SS-97	CL	57+17	1.17 - 1.62	A-4(0)	34	NP	24.4	44.4	19.2	12.1	100	89	38		
SS-98	CL	57+17	2.69 - 3.14	A-4(0)	40	6	29.0	40.5	20.4	10.1	100	84	39		
SS-99	CL	57+17	4.21 - 4.66	A-2-4(0)	36	NP	24.0	51.0	19.0	6.0	100	92	34		
SS-92	25M LT	57+22	1.05 - 1.50	A-7-5(26)	70	35	2.4	37.7	33.7	26.2	100	100	70		
SS-93	25M LT	57+22	2.57 - 3.02	A-7-5(20)	75	21	1.8	38.1	41.9	18.1	100	100	71		
SS-94	25M LT	57+22	4.09 - 4.54	A-7-5(0)	57	14	9.3	50.4	30.2	10.1	100	99	49		
SS-95	25M LT	57+22	5.61 - 6.06	A-7-5(4)	59	12	10.1	52.8	27.0	10.1	100	98	47		
