



| SOIL TEST RESULTS | | | | | | | | | | | | | | | |
|-------------------|--------|---------|----------------|---------------|----|------|-------------|---------|------|------|--------------------|----|-----|------------|-----------|
| SAMPLE NO. | OFFSET | STATION | DEPTH INTERVAL | AASHTO CLASS. | LL | P.I. | % BY WEIGHT | | | | % PASSING (SIEVES) | | | % MOISTURE | % ORGANIC |
| | | | | | | | C. SAND | F. SAND | SILT | CLAY | 10 | 40 | 200 | | |
| S-110 | CL | 11+20 | 4.00-6.50 | A-5(0) | 46 | 2 | 25.3 | 45.0 | 15.6 | 14.1 | 100 | 87 | 36 | - | - |

