



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-41	CL	52+45	0.96-1.41	A-2-7(1)	43	26	71.2	9.6	1.0	18.2	96	38	19	8.8	-
SS-42	CL	52+45	2.48-2.93	A-7-5(44)	84	41	4.2	11.1	24.0	60.6	100	98	87	42.7	-
S-83	CL	52+45	3.50-4.00	A-7-6(15)	58	29	18.4	25.9	15.4	40.4	99	90	59	-	-
ST-1	CL	52+45	3.57-4.18	A-7-5(15)	61	24	11.7	31.5	20.4	36.4	100	93	63	-	-
RT-4	CL	52+45	3.57-5.50	A-7-6(16)	59	30	17.7	26.8	19.2	36.3	99	91	60	-	-
S-84	CL	52+45	5.50-6.00	A-7-5(9)	50	18	18.0	31.1	18.6	32.3	100	93	57	-	-
SS-43	CL	52+45	7.04-7.49	A-4(0)	34	NP	12.7	60.0	19.2	8.1	100	98	36	44.0	-
SS-44	CL	52+45	10.08-10.53	A-7-5(2)	44	11	9.5	57.2	23.2	10.1	100	98	43	-	-
SS-45	CL	52+45	14.64-15.09	A-7-5(7)	66	16	11.3	47.1	25.5	16.2	100	97	50	57.3	-