



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
RT-2	30M LT	48+00	0.98 - 4.02	A-7-5(21)	64	28	7.7	25.2	18.8	48.4	99	97	69		
SS-56	30M LT	48+00	1.15 - 1.60	A-7-5(33)	78	33	6.7	15.2	13.5	64.6	99	97	80		
ST-2	30M LT	48+00	2.50 - 3.11	A-7-5(14)	61	20	7.5	33.7	30.6	28.2	100	98	65		
SS-57	30M LT	48+00	2.67 - 3.12	A-7-5(16)	69	18	5.5	30.9	19.2	44.4	100	99	69		
RT-3	30M LT	48+00	5.54 - 7.06	A-7-5(27)	73	33	9.8	19.7	20.2	50.3	100	95	73		
SS-58	30M LT	48+00	5.71 - 6.16	A-7-5(13)	63	20	8.3	37.0	18.4	36.4	100	98	61		
SS-59	30M LT	48+00	7.23 - 7.68	A-5(4)	50	8	8.9	43.8	21.0	26.3	100	99	55		
CBR-2	30M LT	48+00	8.10 - 11.10												
SS-60	30M LT	48+00	10.27 - 10.72	A-5(0)	44	NP	17.2	47.7	23.0	12.1	100	94	44		
SS-61	30M LT	48+00	11.79 - 12.24	A-5(0)	42	NP	8.3	47.7	29.9	14.1	100	98	54		
S-55	26M RT	48+20	3.00 - 4.00	A-4(2)	36	10	29.7	29.9	20.2	20.2	100	84	46		

11/10/01 10:00 AM 10/10/01 10:00 AM 10/10/01 10:00 AM 10/10/01 10:00 AM 10/10/01 10:00 AM