



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
S-7	20M RT	45+00	0.86 - 1.80	A-7-6(20)	56	29	13.3	20.5	17.9	48.3	100	96	69		
S-8	20M RT	45+00	2.30 - 3.30	A-4(4)	32	10	15.7	32.4	27.8	24.1	100	95	57		
S-9	20M RT	45+00	4.50 - 5.20	A-4(2)	29	9	20.5	34.8	22.5	22.1	100	90	51		

2/17/06