



SOIL TEST RESULTS

SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	LL	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C. SAND	F. SAND	SILT	CLAY	10	40	200		
SS-12	CL	44+20	1.15-1.60	A-7-5(3)	42	11	28.2	30.6	19.1	22.1	100	83	47	19.1	-
SS-13	CL	44+20	2.67-3.12	A-2-4(0)	33	NP	34.0	45.5	16.5	4.0	98	80	26	-	-
RT-1	CL	44+20	2.67-5.71	A-2-4(0)	27	5	39.3	32.8	15.8	12.1	96	73	31	-	-
SS-14	CL	44+20	7.23-7.68	A-2-4(0)	28	NP	36.0	40.2	15.7	8.0	98	79	29	14.3	-
CBR-1	CL	44+20	8.75-13.31	A-2-4(0)	25	3	40.3	31.0	14.6	14.1	97	72	33	-	-
SS-15	CL	44+20	13.31-13.76	A-2-4(0)	29	NP	36.4	38.8	18.7	6.0	99	79	31	20.0	-
SS-10	CL	44+40	8.59-10.11	A-2-4(0)	24	NP	39.0	23.0	16.9	12.1	98	73	34	-	-

Ⓑ SOFT TO HARD WEATHERED ROCK (GRANITE)

