


LOGICAL I/O PROCESSOR PROGRAMMING DETAIL

(program controller as shown below)



- FROM MAIN MENU PRESS '2' (PHASE CONTROL), THEN '1' (PHASE CONTROL FUNCTIONS). SCROLL TO THE BOTTOM OF THE MENU AND ENABLE ACT LOGIC COMMANDS 1-6.
- FROM MAIN MENU PRESS '6' (OUTPUTS), THEN '3' (LOGICAL I/O PROCESSOR).
- THE PROGRAMMING SHOWN BELOW IS NECESSARY FOR SIGNALS TO OPERATE AS SHOWN ON THE SIGNAL DESIGN PLANS.



INPUT ASSIGNMENT PROGRAMMING DETAIL FOR SPECIAL SEQUENCE OPERATION

(program controller as shown below)

- FROM MAIN MENU PRESS '5' (INPUTS).
- WITH CURSOR IN "INPUT ASSIGNMENT #" FIELD, USE + OR - KEY TO FIND THE INPUT ASSIGNMENT NUMBER 63, AS SHOWN BELOW.
- PROGRAM CONTROLLER AS SHOWN:



THIS ELECTRICAL DETAIL IS FOR THE SIGNAL DESIGN: 01-0738T1, 01-0738T2 AND 01-0738T3. DESIGNED: JANUARY 2004 SEALED: 02/19/04 REVISED:

NEW INSTALLATION - TEMPORARY 1, 2 & 3 - SHEET 2 OF 2

	<p>US 264</p> <p>AT</p> <p>SR 1315 (SWAMP ROAD) AND BRIDGES 52 AND 54</p>			
	<p>DIVISION 01</p> <p>PLAN DATE: FEBRUARY 2004</p> <p>PREPARED BY: JAMES PETERSON</p>	<p>HYDE COUNTY</p> <p>REVIEWED BY: R. Wiseman</p> <p>REVIEWED BY:</p>		<p>NEAR ENGELHARD</p> <p>INIT. DATE</p>
	<p>REVISIONS</p>	<p>INIT. DATE</p>		<p>DATE</p>
	<p>SIGNATURE: James Peterson</p>	<p>SIGNATURE: George C. Brown</p>		<p>DATE</p>

SIG. INVENTORY NO. 01-0738

25-FEB-2004 11:48
U:\4010738...xx.ele
J Peterson