



PROJECT SPECIAL PROVISIONS
Utility Construction

All proposed utility construction shall meet the applicable requirements of the NC Department of Transportation's "Standard Specifications for Roads and Structures" dated July 2006. Division 15 of the Standard Specifications is revised as follows:

Page 15-1 Section 1500-2

Provide access for Department personnel and the owner's representatives to all phases of construction. Notify Department personnel and the utility owner two weeks prior to commencement of any work and one week prior to service interruption. Keep utility owner's representatives informed of work progress and provide opportunity for inspection of construction and testing. *The water lines on this project belong to Davidson Water, Incorporated. The contact person for Davidson Water is Mr. Robert Walters, and he can be reached by phone at 336-731-5526. Any work on these lines must be coordinated through the Engineer and the utility owner before beginning.*

NOTE: The 6" pipe to be used for the trenchless installation called for on utility construction plan sheet UC-2 shall be flexible restrained joint ductile iron. HDPE will not be allowed for use in this trenchless installation. Additionally, all water pipe on this project shall be ductile iron.

12/5/08

County: Davidson
Project: B-4097PROJECT SPECIAL PROVISIONS

Utility

UTILITIES BY OTHERS

General:

The following utility companies have facilities that will be in conflict with the construction of this project.

- A) Energy United – Power (Distribution)
- B) Energy United – Power (Transmission)
- C) Lexcom Communications - Telephone
- D) MCI / Verizon – Telephone
- E) Time Warner Cable – CATV
- F) City of Lexington – Sewer
- G) City of Lexington - Gas

The conflicting facilities of these concerns will be adjusted prior to the date of availability, unless otherwise noted and are therefore listed in these special provisions for the benefit of the Contractor. All utility work listed herein will be done by the utility owner. All utilities are shown on the plans from the best available information.

The Contractor's attention is directed to Article 105-8 of the Standard Specifications.

Utilities Requiring Adjustment:

- A) Energy United - Power (Distribution)
 - 1) See Utilities by Others Plans.
- B) Energy United – Power (Transmission)
 - 1) See Utilities by Others Plans.
- C) Lexcom Communications - Telephone
 - 1) See Utilities by Others Plans.
- D) MCI / Verizon - Telephone
 - 1) See Utilities by Others Plans.

Note: The contractor show give MCI 3 weeks notice prior to completion of clearing and grubbing and then allow MCI 3 weeks to complete the relocation of their buried telephone facilities.

E) Time Warner Cable – CATV

1) See Utilities by Others Plans.

F) City of Lexington – Sewer

1) See Utilities by Others Plans.

G) City of Lexington – Gas

1) See Utilities by Others Plans.

NOTE: All other utilities will remain in place and will be adjusted as necessary.