



PROJECT SPECIAL PROVISIONS

Utility Construction

All proposed utility construction shall meet the applicable requirements of the NC Department of Transportation's Standard Specifications for Roads and Structures dated July 2006.

Revise the *2006 Standard Specifications* as follows:

**Utility Owners' contact Information:**

**Page 15-1, Subarticle 1500-2 Cooperation with the Utility Owner**, paragraph 2, add the following sentences:

All water lines on this project belong to Wilson County Water.

The Contractor shall provide access for the owner's representatives during construction. A preconstruction meeting shall be held with Wilson County Water, the Utility Contractor and the D.O.T prior to any work beginning. The Contractor shall notify the owner two weeks before commencement of any work and three weeks before service interruption.

The contact person for Wilson County Water is Mr. Dale Causey, he can be contacted at 252-399-2749.

**Page 15-3, Subarticle 1500-9 Placing Pipelines into Service**

Limit interruption of service to water customers to a maximum of 4 hours. Tie-in should be done between 10:00 am and 2:00 pm.

**Page 15-9, Subarticle 1515-2 Materials**, add the following sentence:

In addition to the water line materials specified under Section 1036, the water line can be High Density Polyethylene (HDPE) pipe conforming to AWWA C906 with an SDR of 9 and pressure rating of 200 # WP.