


PROJECT SPECIAL PROVISIONS
Utility Construction



Revise the *2006 Standard Specifications* as follows:

Utility Owner's Contact Information:

Page 15-1, Subarticle 1500-2 Cooperation with the Utility Owner, paragraph 2, add the following sentences:

The Beaufort County Water owns the 12" water line. The contact person for the County is Mr. Curits Jett and he can be reached by phone at 252-975-0720.

The Contractor shall provide access for the owner's representatives to all phases of construction and keep all valves and meters accessible during construction. A preconstruction meeting shall be held with Beaufort County, the Utility contractor and D.O.T prior to any work beginning. The Contractor shall notify the owner two weeks before commencement of any work and three weeks before service interruption.

Page 15-9, Subarticle 1515-2 Materials, add the following sentences:

In addition to the water line materials specified under Section 1036, the water line can be High Density Polyethylene (HDPE) pipe conforming to AWWA C906 with an SDR of 9 and pressure rating of 200 # WP.

PROJECT: B-4415
COUNTY: Beaufort

PROJECT SPECIAL PROVISIONS
Utility

UTILITIES BY OTHERS:

General:

The following utility companies have facilities that will be in conflict with the construction of this project:

- A. City of Washington
- B. Tri-County Communications

The conflicting facilities will be adjusted prior to the date of availability except where noted and are therefore listed in these special provisions for the benefit of the Contractor. All utility work listed herein will be done by the utility owners. All utilities are shown on the plans from the best available information.

The Contractor's attention is directed to Article 105.8 of the Standard Specifications.

Utilities Requiring Adjustment:

- A. City of Washington
 - 1. See "Utilities by Others Plans" for utility conflicts.

- B. Tri-County Communications
 - 1. See "Utilities by Others Plans" for utility conflicts.