



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

PAT MCCRORY
GOVERNOR

ANTHONY J. TATA
SECRETARY

April 5, 2013

Addendum No. 1

RE: Contract ID C203091

WBS # 39978.3.1

F. A. # BRSTP-0070(103)

Wake County (B-4946)

Bridge # 251 over US-401 on US-70 and NC-50

April 16, 2013 Letting

To Whom It May Concern:

Reference is made to the proposal form furnished to you on this project.

The following revisions have been made to the proposal:

Page No. 117 has been revised to add the special provision "Submittal of Working Drawings for MSE Walls and Overhead Signs" to the Table of Contents. Please void Page No. 117 in your proposal and staple the revised Page No. 117 thereto.

Page No. 142 has been revised to add the above mentioned special provision. Please void Page No. 142 in your proposal and staple the revised Page No. 142 thereto.

Sincerely,

A handwritten signature in black ink, appearing to read "R. A. Garris".

R. A. Garris, PE
Contract Officer

RAG/jjr
Attachment

cc: Mr. Ron Hancock, PE
Mr. Wally Bowman, PE
Ms. D. M. Barbour, PE
Mr. J. V. Barbour, PE
Mr. R.E. Davenport, PE
Project File (2)

Mr. Ray Arnold, PE
Ms. Natalie Roskam, PE
Mr. Ronnie Higgins
Mr. Larry Strickland
Ms. Marsha Sample
Ms. Lori Strickland

Project B-4946

Wake County

Project Special Provisions
Structures

Table of Contents

	Page #
Maintenance & Protection of Traffic Beneath Proposed Structure at Station 25+71.28 -L EBL- (8-13-04)	----- 1
Placing Load on Structure Members (11-27-12)	----- 2
Steel Reinforced Elastomeric Bearings (11-27-12)	----- 2
Thermal Sprayed Coatings (Metallization) (9-30-11)	----- 2
Expansion Joint Seals (9-30-11)	----- 6
Falsework and Formwork (4-5-12)	----- 10
Submittal of Working Drawings (2-10-12)	----- 17
Crane Safety (8-15-05)	----- 23
Grout for Structures (9-30-11)	----- 23
Submittal of Working Drawings for MSE Walls and Overhead Signs (Special)	----- 25

For MSE Retaining Walls, see Geotech special provisions.



Joseph McArthur Bailey
4/5/13

B-4946

Do not place grout if the grout temperature is less than 50°F or more than 90°F or if the air temperature measured at the location of the grouting operation in the shade away from artificial heat is below 45°F.

Provide grout at a rate that permits proper handling, placing and finishing in accordance with the manufacturer's recommendations unless directed otherwise by the Engineer. Use grout free of any lumps and undispersed cement. Agitate grout continuously before placement.

Control grout delivery so the interval between placing batches in the same component does not exceed 20 minutes.

The Engineer will determine the locations to sample grout and the number and type of samples collected for field and laboratory testing. The compressive strength of the grout will be considered the average compressive strength test results of 3 cube or 2 cylinder specimens at 28 days.

4.0 BASIS OF PAYMENT

No separate payment will be made for "Grout for Structures". The cost of the material, equipment, labor, placement, and any incidentals necessary to complete the work shall be considered incidental to the structure item requiring grout.

Submittal Of Working Drawings For MSE Walls And Overhead Signs: (SPECIAL)

The contractor shall allow 10 working days for review and approval, or acceptance, of working drawings from the date they are received until they are returned by the Engineer.