FOR UTILITY INFORMATION, SEE UTILITY PLANS AND SPECIAL PROVISIONS.

## TOTAL STRUCTURE QUANTITIES CLASS A CONCRETE 84.7 C.Y. BARREL @ 1.093 CY/FT 23.3 C.Y. WINGS, ETC. SILLS TOTAL 109.3 C.Y. REINFORCING STEEL BARREL, SILLS 9,287 LBS. <u>1,658</u> LBS. WINGS, ETC. TOTAL 10,945 LBS. FOUNDATION CONDITIONING MATERIAL 53 TONS CULVERT EXCAVATION LUMP SUM PLACEMENT OF NATURAL STREAM BED MATERIAL LUMP SUM

HYDRAULIC DATA					
DESIGN DISCHARGE FREQUENCY OF DESIGN FLOOD DESIGN HIGH WATER ELEVATION DRAINAGE AREA BASE DISCHARGE (Q 100) BASE HIGH WATER ELEVATION	= 500 CFS = 50 YR. = 734.7 = 0.3 SQ MI = 600 CFS = 744.43				
OVERTOPPING FLOOD DATA					
OVERTOPPING DISCHARGE FREQUENCY OF OVERTOPPING FLOOD OVERTOPPING FLOOD ELEVATION	= 1,400 CFS = 500 YR + = 752.6				

## NOTES

ASSUMED LIVE LOAD = HL-93 OR ALTERNATE LOADING.

DESIGN FILL = 10'

TRANSVERSE CONSTRUCTION JOINTS SHALL BE USED IN THE BARREL, SPACED TO LIMIT THE POURS TO A MAXIMUM OF 70 FT. LOCATION OF JOINTS SHALL BE SUBJECT TO APPROVAL OF THE ENGINEER.

FOR CULVERT DIVERSION CHANNEL DETAILS AND PAY ITEM, SEE EROSION CONTROL PLANS.

A 3 FOOT STRIP OF GEOTEXTILE SHALL BE ATTACHED TO THE FILL FACE OF THE WING COVERING THE ENTIRE LENGTH OF THE EXPANSION JOINT.

NO PRECAST REINFORCED BOX CULVERT OPTION WILL BE ALLOWED.

CONCRETE IN CULVERTS TO BE POURED IN THE FOLLOWING ORDER:

1. WING FOOTINGS AND FLOOR SLAB INCLUDING 4"OF ALL VERTICAL WALLS.

2. THE REMAINING PORTIONS OF THE WALLS, SILLS AND WINGS FULL HEIGHT FOLLOWED BY ROOF SLAB AND HEADWALLS.

THE RESIDENT ENGINEER SHALL CHECK THE LENGTH OF CULVERT BEFORE STAKING IT OUT TO MAKE CERTAIN THAT IT WILL PROPERLY TAKE CARE OF THE FILL.

DIMENSIONS FOR WING LAYOUT AS WELL AS ADDITIONAL REINFORCING STEEL EMBEDDED IN BARREL ARE SHOWN ON WING SHEET.

AT THE CONTRACTOR'S OPTION, HE MAY SPLICE THE VERTICAL REINFORCING STEEL IN THE INTERIOR FACE OF EXTERIOR WALLS ABOVE LOWER WALL CONSTRUCTION JOINT. THE SPLICE LENGTH SHALL BE AS PROVIDED IN THE SPLICE LENGTH CHART SHOWN ON THE PLANS. EXTRA WEIGHT OF STEEL DUE TO THE SPLICES SHALL BE PAID FOR BY THE CONTRACTOR.

FOR SUBMITTAL OF WORKING DRAWINGS, SEE SPECIAL PROVISIONS.

FOR FALSEWORK AND FORMWORK, SEE SPECIAL PROVISIONS.

FOR GROUT FOR STRUCTURES, SEE SPECIAL PROVISIONS.

FOR CRANE SAFETY, SEE SPECIAL PROVISIONS.

3"Ø WEEP HOLES INDICATED TO BE IN ACCORDANCE WITH THE SPECIFICATIONS.

NATURAL STREAM BED MATERIAL SHALL BE USED TO BACKFILL THE CULVERT BETWEEN SILLS. SEE SPECIAL PROVISIONS FOR "PLACEMENT OF NATURAL STREAM BED MATERIAL."

THE CONTRACTOR SHALL PROVIDE INDEPENDENT ASSURANCE SAMPLES OF REINFORCING STEEL AS FOLLOWS: FOR PROJECTS REQUIRING UP TO 400 TONS OF REINFORCING STEEL, ONE 30 INCH SAMPLE OF EACH SIZE BAR USED, AND FOR PROJECTS REQUIRING OVER 400 TONS OF REINFORCING STEEL, TWO 30 INCH SAMPLES OF EACH SIZE BAR USED. THE BARS FROM WHICH THE SAMPLES ARE TAKEN MUST THEN BE SPLICED WITH REPLACEMENT BARS OF THE SIZE AND LENGTH OF THE SAMPLE, PLUS A MINIMUM LAP SPLICE OF THIRTY BAR DIAMETERS. PAYMENT FOR THE SAMPLES OF REINFORCING STEEL SHALL BE CONSIDERED INCIDENTAL TO VARIOUS PAY ITEMS.

PROJECT NO. W-5516

ROWAN COUNTY

STATION: 108+21.00 -L-

SHEET 1 OF 8

DEPARTMENT OF TRANSPORTATION
RALEIGH

SINGLE BARREL 8 FT. X 7 FT. CONCRETE BOX CULVERT 81° SKEW

				_	
REVISIONS				SHEET NO.	
BY:	DATE:	NO.	BY:	DATE:	C-6
		3			TOTAL SHEETS
		4			13

3'-11" \ 16'-10" 6'-5"5'-9"  $38'-2\frac{1}{2}''$ 27'-9" ∠EL. 736.6± ∠EL. 738.3± -EL. 737.5± ∠EL.735.7± ∠EL. 736.8± ►EL. 739.3± -EL.737.9± ∠EL. 739.4± -EL. 736.9± ∠EL. 738.5± ∠EL. 736.8± PROFILE ALONG & CULVERT

Engineering
5121 Kingdom Way, Suite 100 Raleigh, NC 27607
NC License No: F-0258

SEAL
14408

SEAL
14408

NGINEE

Docusigned by

Thomas E. Tallman 7/7/2015