

**STATE OF NORTH CAROLINA**  
**DEPARTMENT OF TRANSPORTATION**  
**DIVISION OF HIGHWAYS**  
**GEOTECHNICAL ENGINEERING UNIT**

**STRUCTURE**  
**SUBSURFACE INVESTIGATION**

**CONTENTS**

<u>SHEET</u>	<u>DESCRIPTION</u>
1	TITLE SHEET
2	LEGEND
3	SITE PLAN
4-5	PROFILE(S)
6-13	CROSS SECTION(S)
14-23	BORE LOG & CORE REPORT(S)
24	SOIL TEST RESULTS
25-26	CORE PHOTOGRAPH(S)
27	SITE PHOTOGRAPH(S)

PROJ. REFERENCE NO. 34182.1.4 (I-3318BB) F.A. PROJ. IMS-095-2(119)105  
 COUNTY JOHNSTON  
 PROJECT DESCRIPTION \_\_\_\_\_

SITE DESCRIPTION REPLACE BRIDGES 114 & 116 ON -L- (I-95)  
OVER LITTLE RIVER AT STA. 24+68

**CAUTION NOTICE**

THE SUBSURFACE INFORMATION AND THE SUBSURFACE INVESTIGATION ON WHICH IT IS BASED WERE MADE FOR THE PURPOSE OF STUDY, PLANNING, AND DESIGN, AND NOT FOR CONSTRUCTION OR PAY PURPOSES. THE VARIOUS FIELD BORING LOGS, ROCK CORES, AND SOIL TEST DATA AVAILABLE MAY BE REVIEWED OR INSPECTED IN RALEIGH BY CONTACTING THE N.C. DEPARTMENT OF TRANSPORTATION, GEOTECHNICAL ENGINEERING UNIT AT (919) 707-6850. NEITHER THE SUBSURFACE PLANS AND REPORTS, NOR THE FIELD BORING LOGS, ROCK CORES, OR SOIL TEST DATA ARE PART OF THE CONTRACT.

GENERAL SOIL AND ROCK STRATA DESCRIPTIONS AND INDICATED BOUNDARIES ARE BASED ON A GEOTECHNICAL INTERPRETATION OF ALL AVAILABLE SUBSURFACE DATA AND MAY NOT NECESSARILY REFLECT THE ACTUAL SUBSURFACE CONDITIONS BETWEEN BORINGS OR BETWEEN SAMPLED STRATA WITHIN THE BOREHOLE, THE LABORATORY SAMPLE DATA AND THE IN SITU (IN-PLACE) TEST DATA CAN BE RELIED ON ONLY TO THE DEGREE OF RELIABILITY INHERENT IN THE STANDARD TEST METHOD. THE OBSERVED WATER LEVELS OR SOIL MOISTURE CONDITIONS INDICATED IN THE SUBSURFACE INVESTIGATIONS ARE AS RECORDED AT THE TIME OF THE INVESTIGATION. THESE WATER LEVELS OR SOIL MOISTURE CONDITIONS MAY VARY CONSIDERABLY WITH TIME ACCORDING TO CLIMATIC CONDITIONS INCLUDING TEMPERATURES, PRECIPITATION, AND WIND, AS WELL AS OTHER NON-CLIMATIC FACTORS.

THE BIDDER OR CONTRACTOR IS CAUTIONED THAT DETAILS SHOWN ON THE SUBSURFACE PLANS ARE PRELIMINARY ONLY AND IN MANY CASES THE FINAL DESIGN DETAILS ARE DIFFERENT. FOR BIDDING AND CONSTRUCTION PURPOSES, REFER TO THE CONSTRUCTION PLANS AND DOCUMENTS FOR FINAL DESIGN INFORMATION ON THIS PROJECT. THE DEPARTMENT DOES NOT WARRANT OR GUARANTEE THE SUFFICIENCY OR ACCURACY OF THE INVESTIGATION MADE, NOR THE INTERPRETATIONS MADE, OR OPINION OF THE DEPARTMENT AS TO THE TYPE OF MATERIALS AND CONDITIONS TO BE ENCOUNTERED. THE BIDDER OR CONTRACTOR IS CAUTIONED TO MAKE SUCH INDEPENDENT SUBSURFACE INVESTIGATIONS AS HE DEEMS NECESSARY TO SATISFY HIMSELF AS TO CONDITIONS TO BE ENCOUNTERED ON THIS PROJECT. THE CONTRACTOR SHALL HAVE NO CLAIM FOR ADDITIONAL COMPENSATION OR FOR AN EXTENSION OF TIME FOR ANY REASON RESULTING FROM THE ACTUAL CONDITIONS ENCOUNTERED AT THE SITE DIFFERING FROM THOSE INDICATED IN THE SUBSURFACE INFORMATION.

PERSONNEL

CONSULTANT:

SUMMIT

INVESTIGATED BY J. L. PEDRO

CHECKED BY N. T. ROBERSON

SUBMITTED BY N. T. ROBERSON


DATE JANUARY 2013

**PROJECT: 34182.1.4 ID: I-3318BB**

DRAWN BY: T.T. WALKER, J. L. PEDRO

NOTE - THE INFORMATION CONTAINED HEREIN IS NOT IMPLIED OR GUARANTEED BY THE N.C. DEPARTMENT OF TRANSPORTATION AS BEING ACCURATE NOR IT IS CONSIDERED TO BE PART OF THE PLANS, SPECIFICATIONS, OR CONTRACT FOR THE PROJECT.

NOTE - BY HAVING REQUESTED THIS INFORMATION THE CONTRACTOR SPECIFICALLY WAIVES ANY CLAIMS FOR INCREASED COMPENSATION OR EXTENSION OF TIME BASED ON DIFFERENCES BETWEEN THE CONDITIONS INDICATED HEREIN AND THE ACTUAL CONDITIONS AT THE PROJECT SITE.




**NORTH CAROLINA DEPARTMENT OF TRANSPORTATION**  
**DIVISION OF HIGHWAYS**  
**GEOTECHNICAL ENGINEERING UNIT**

PROJECT REFERENCE NO. 34182.1,4 (I-3318BB)	SHEET NO. 2
---	----------------

**SUBSURFACE INVESTIGATION**


**SOIL AND ROCK LEGEND, TERMS, SYMBOLS, AND ABBREVIATIONS**

SOIL DESCRIPTION	GRADATION	ROCK DESCRIPTION	TERMS AND DEFINITIONS
SOIL IS CONSIDERED TO BE THE UNCONSOLIDATED, SEMI-CONSOLIDATED, OR WEATHERED EARTH MATERIALS THAT CAN BE PENETRATED WITH A CONTINUOUS FLIGHT POWER AUGER, AND YIELD LESS THAN 100 BLOWS PER FOOT ACCORDING TO STANDARD PENETRATION TEST (ASTM D-1586). SOIL CLASSIFICATION IS BASED ON THE AASHTO SYSTEM. BASIC DESCRIPTIONS GENERALLY SHALL INCLUDE: CONSISTENCY, COLOR, TEXTURE, MOISTURE, MOISTURE, AASHTO CLASSIFICATION, AND OTHER PERTINENT FACTORS SUCH AS MINERALOGICAL COMPOSITION, ANGULARITY, STRUCTURE, PLASTICITY, ETC. EXAMPLE: <i>VERY STIFF, GRAY-SILTY CLAY, MOST WITH INTERBEDDED FINE SAND LAYERS, HIGH PLASTIC, A-7-6</i>	<b>WELL GRADED</b> - INDICATES A GOOD REPRESENTATION OF PARTICLE SIZES FROM FINE TO COARSE. <b>UNIFORM</b> - INDICATES THAT SOIL PARTICLES ARE ALL APPROXIMATELY THE SAME SIZE. (ALSO POORLY GRADED) <b>GAP-GRADED</b> - INDICATES A MIXTURE OF UNIFORM PARTICLES OF TWO OR MORE SIZES. <b>ANGULARITY OF GRAINS</b> THE ANGULARITY OR ROUNDNESS OF SOIL GRAINS IS DESIGNATED BY THE TERMS: <b>ANGULAR</b> , <b>SUBANGULAR</b> , <b>SUBROUNDED</b> , OR <b>ROUNDED</b> .	<b>HARD ROCK</b> IS NON-COASTAL PLAIN MATERIAL THAT IF TESTED, WOULD YIELD SPT REFUSAL. AN INFERRED ROCK LINE INDICATES THE LEVEL AT WHICH NON-COASTAL PLAIN MATERIAL WOULD YIELD SPT REFUSAL. SPT REFUSAL IS PENETRATION BY A SPLIT SPOON SAMPLER EQUAL TO OR LESS THAN 0.1 FOOT PER 60 BLOWS. IN NON-COASTAL PLAIN MATERIAL, THE TRANSITION BETWEEN SOIL AND ROCK IS OFTEN REPRESENTED BY A ZONE OF WEATHERED ROCK. ROCK MATERIALS ARE TYPICALLY DIVIDED AS FOLLOWS: <b>WEATHERED ROCK (WR)</b> <b>CRYSTALLINE ROCK (CR)</b> <b>NON-CRYSTALLINE ROCK (NCR)</b> <b>COASTAL PLAIN SEDIMENTARY ROCK (CP)</b>	<b>ALLUVIUM (ALLUV.)</b> - SOILS THAT HAVE BEEN TRANSPORTED BY WATER. <b>AQUIFER</b> - A WATER BEARING FORMATION OR STRATA. <b>ARENACEOUS</b> - APPLIED TO ROCKS THAT HAVE BEEN DERIVED FROM SAND OR THAT CONTAIN SAND. <b>ARGILLACEOUS</b> - APPLIED TO ALL ROCKS OR SUBSTANCES COMPOSED OF CLAY MINERALS, OR HAVING A NOTABLE PROPORTION OF CLAY IN THEIR COMPOSITION, AS SHALE, SLATE, ETC. <b>ARTESIAN</b> - GROUND WATER THAT IS UNDER SUFFICIENT PRESSURE TO RISE ABOVE THE LEVEL AT WHICH IT IS ENCOUNTERED, BUT WHICH DOES NOT NECESSARILY RISE TO OR ABOVE THE GROUND SURFACE. <b>CALCAREOUS (CALC.)</b> - SOILS THAT CONTAIN APPRECIABLE AMOUNTS OF CALCIUM CARBONATE. <b>COLLUVIUM</b> - ROCK FRAGMENTS MIXED WITH SOIL DEPOSITED BY GRAVITY ON SLOPE OR AT BOTTOM OF SLOPE. <b>CORE RECOVERY (REC.)</b> - TOTAL LENGTH OF ALL MATERIAL RECOVERED IN THE CORE BARREL DIVIDED BY TOTAL LENGTH OF CORE RUN AND EXPRESSED AS A PERCENTAGE. <b>DIKE</b> - A TABULAR BODY OF IGNEOUS ROCK THAT CUTS ACROSS THE STRUCTURE OF ADJACENT ROCKS OR CUTS MASSIVE ROCK. <b>DIP</b> - THE ANGLE AT WHICH A STRATUM OR ANY PLANAR FEATURE IS INCLINED FROM THE HORIZONTAL. <b>DIP DIRECTION (DIP AZIMUTH)</b> - THE DIRECTION OR BEARING OF THE HORIZONTAL TRACE OF THE LINE OF DIP, MEASURED CLOCKWISE FROM NORTH. <b>FAULT</b> - A FRACTURE OR FRACTURE ZONE ALONG WHICH THERE HAS BEEN DISPLACEMENT OF THE SIDES RELATIVE TO ONE ANOTHER PARALLEL TO THE FRACTURE. <b>FISSILE</b> - A PROPERTY OF SPLITTING ALONG CLOSELY SPACED PARALLEL PLANES. <b>FLOAT</b> - ROCK FRAGMENTS ON SURFACE NEAR THEIR ORIGINAL POSITION AND DISLOGGED FROM PARENT MATERIAL. <b>FLOOD PLAIN (FP)</b> - LAND BORDERING A STREAM, BUILT OF SEDIMENTS DEPOSITED BY THE STREAM. <b>FORMATION (FM)</b> - A MAPPABLE GEOLOGIC UNIT THAT CAN BE RECOGNIZED AND TRACED IN THE FIELD. <b>JOINT</b> - FRACTURE IN ROCK ALONG WHICH NO APPRECIABLE MOVEMENT HAS OCCURRED. <b>LEDGE</b> - A SHELF-LIKE RIDGE OR PROJECTION OF ROCK WHOSE THICKNESS IS SMALL COMPARED TO ITS LATERAL EXTENT. <b>LENS</b> - A BODY OF SOIL OR ROCK THAT THINS OUT IN ONE OR MORE DIRECTIONS. <b>MOTTLED (MOT.)</b> - IRREGULARLY MARKED WITH SPOTS OF DIFFERENT COLORS. MOTTLING IN SOILS USUALLY INDICATES POOR AERATION AND LACK OF GOOD DRAINAGE. <b>PERCHED WATER</b> - WATER MAINTAINED ABOVE THE NORMAL GROUND WATER LEVEL BY THE PRESENCE OF AN INTERVENING IMPERVIOUS STRATUM. <b>RESIDUAL (RES.) SOIL</b> - SOIL FORMED IN PLACE BY THE WEATHERING OF ROCK. <b>ROCK QUALITY DESIGNATION (RQD)</b> - A MEASURE OF ROCK QUALITY DESCRIBED BY TOTAL LENGTH OF ROCK SEGMENTS EQUAL TO OR GREATER THAN 4 INCHES DIVIDED BY THE TOTAL LENGTH OF CORE RUN AND EXPRESSED AS A PERCENTAGE. <b>SAPROLITE (SAP.)</b> - RESIDUAL SOIL THAT RETAINS THE RELIC STRUCTURE OR FABRIC OF THE PARENT ROCK. <b>SILL</b> - AN INTRUSIVE BODY OF IGNEOUS ROCK OF APPROXIMATELY UNIFORM THICKNESS AND RELATIVELY THIN COMPARED WITH ITS LATERAL EXTENT, THAT HAS BEEN EMPLACED PARALLEL TO THE BEDDING OR SCHISTOSITY OF THE INTRUDED ROCKS. <b>SLICKENSIDE</b> - POLISHED AND STRIATED SURFACE THAT RESULTS FROM FRICTION ALONG A FAULT OR SLIP PLANE. <b>STANDARD PENETRATION TEST (PENETRATION RESISTANCE) (SPT)</b> - NUMBER OF BLOWS (IN OR BPF) OF A 140 LB. HAMMER FALLING 30 INCHES REQUIRED TO PRODUCE A PENETRATION OF 1 FOOT INTO SOIL WITH A 2 INCH OUTSIDE DIAMETER SPLIT SPOON SAMPLER. SPT REFUSAL IS PENETRATION EQUAL TO OR LESS THAN 0.1 FOOT PER 60 BLOWS. <b>STRATA CORE RECOVERY (SREC.)</b> - TOTAL LENGTH OF STRATA MATERIAL RECOVERED DIVIDED BY TOTAL LENGTH OF STRATUM AND EXPRESSED AS A PERCENTAGE. <b>STRATA ROCK QUALITY DESIGNATION (SRQD)</b> - A MEASURE OF ROCK QUALITY DESCRIBED BY TOTAL LENGTH OF ROCK SEGMENTS WITHIN A STRATUM EQUAL TO OR GREATER THAN 4 INCHES DIVIDED BY THE TOTAL LENGTH OF STRATA AND EXPRESSED AS A PERCENTAGE. <b>TOPSOIL (TS)</b> - SURFACE SOILS USUALLY CONTAINING ORGANIC MATTER.
<b>SOIL LEGEND AND AASHTO CLASSIFICATION</b>	<b>MINERALOGICAL COMPOSITION</b>	<b>WEATHERING</b>	
GENERAL CLASS. GRANULAR MATERIALS (≤ 35% PASSING #200) SILT-CLAY MATERIALS (> 35% PASSING #200) ORGANIC MATERIALS	MINERAL NAMES SUCH AS QUARTZ, FELDSPAR, MICA, TALC, KAOLIN, ETC. ARE USED IN DESCRIPTIONS WHENEVER THEY ARE CONSIDERED OF SIGNIFICANCE.	<b>FRESH</b> - ROCK FRESH, CRYSTALLINE BRIGHT, FEW JOINTS MAY SHOW SLIGHT STAINING. ROCK RINGS UNDER HAMMER IF CRYSTALLINE. <b>VERY SLIGHT (V SLI.)</b> - ROCK GENERALLY FRESH, JOINTS STAINED, SOME JOINTS MAY SHOW THIN CLAY COATINGS IF OPEN. CRYSTALS ON A BROKEN SPECIMEN FACE SHINE BRIGHTLY. ROCK RINGS UNDER HAMMER BLOWS IF OF A CRYSTALLINE NATURE. <b>SLIGHT (SLI.)</b> - ROCK GENERALLY FRESH, JOINTS STAINED AND DISCOLORATION EXTENDS INTO ROCK UP TO 1 INCH. OPEN JOINTS MAY CONTAIN CLAY. IN GRANITOID ROCKS SOME OCCASIONAL FELDSPAR CRYSTALS ARE DULL AND DISCOLORED. CRYSTALLINE ROCKS RING UNDER HAMMER BLOWS. <b>MODERATE (MOD.)</b> - SIGNIFICANT PORTIONS OF ROCK SHOW DISCOLORATION AND WEATHERING EFFECTS. IN GRANITOID ROCKS, MOST FELDSPARS ARE DULL AND DISCOLORED, SOME SHOW CLAY. ROCK HAS DULL SOUND UNDER HAMMER BLOWS AND SHOWS SIGNIFICANT LOSS OF STRENGTH AS COMPARED WITH FRESH ROCK. <b>MODERATELY SEVERE (MOD. SEV.)</b> - ALL ROCK EXCEPT QUARTZ DISCOLORED OR STAINED. IN GRANITOID ROCKS, ALL FELDSPARS DULL AND DISCOLORED AND A MAJORITY SHOW KAOLINIZATION. ROCK SHOWS SEVERE LOSS OF STRENGTH AND CAN BE EXCAVATED WITH A GEOLOGIST'S PICK. ROCK GIVES 'CLUNK' SOUND WHEN STRUCK. <i>IF TESTED, WOULD YIELD SPT REFUSAL</i> <b>SEVERE (SEV.)</b> - ALL ROCK EXCEPT QUARTZ DISCOLORED OR STAINED. ROCK FABRIC CLEAR AND EVIDENT BUT REDUCED IN STRENGTH TO STRONG SOIL. IN GRANITOID ROCKS ALL FELDSPARS ARE KAOLINIZED TO SOME EXTENT. SOME FRAGMENTS OF STRONG ROCK USUALLY REMAIN. <i>IF TESTED, YIELDS SPT N VALUES &gt; 100 BPF</i> <b>VERY SEVERE (V SEV.)</b> - ALL ROCK EXCEPT QUARTZ DISCOLORED OR STAINED. ROCK FABRIC ELEMENTS ARE DISCERNIBLE BUT THE MASS IS EFFECTIVELY REDUCED TO SOIL STATUS, WITH ONLY FRAGMENTS OF STRONG ROCK REMAINING. SAPROLITE IS AN EXAMPLE OF ROCK WEATHERED TO A DEGREE SUCH THAT ONLY MINOR VESTIGES OF THE ORIGINAL ROCK FABRIC REMAIN. <i>IF TESTED, YIELDS SPT N VALUES &lt; 100 BPF</i> <b>COMPLETE</b> - ROCK REDUCED TO SOIL. ROCK FABRIC NOT DISCERNIBLE, OR DISCERNIBLE ONLY IN SMALL AND SCATTERED CONCENTRATIONS. QUARTZ MAY BE PRESENT AS DIKES OR STRINGERS. SAPROLITE IS ALSO AN EXAMPLE.	
<b>COMPRESSIBILITY</b> SLIGHTLY COMPRESSIBLE MODERATELY COMPRESSIBLE HIGHLY COMPRESSIBLE	<b>PERCENTAGE OF MATERIAL</b> ORGANIC MATERIAL TRACE OF ORGANIC MATTER LITTLE ORGANIC MATTER MODERATELY ORGANIC HIGHLY ORGANIC	<b>LIQUID LIMIT LESS THAN 31</b> <b>LIQUID LIMIT EQUAL TO 31-50</b> <b>LIQUID LIMIT GREATER THAN 50</b>	
<b>GROUND WATER</b> WATER LEVEL IN BORE HOLE IMMEDIATELY AFTER DRILLING STATIC WATER LEVEL AFTER 24 HOURS PERCHED WATER, SATURATED ZONE, OR WATER BEARING STRATA SPRING OR SEEP	<b>MISCELLANEOUS SYMBOLS</b> ROADWAY EMBANKMENT (RE) WITH SOIL DESCRIPTION SOIL SYMBOL ARTIFICIAL FILL (AF) OTHER THAN ROADWAY EMBANKMENT INFERRED SOIL BOUNDARY INFERRED ROCK LINE ALLUVIAL SOIL BOUNDARY DIP & DIP DIRECTION OF ROCK STRUCTURES	<b>TEST BORING</b> AUGER BORING CORE BORING MONITORING WELL PIEZOMETER INSTALLATION SLOPE INDICATOR INSTALLATION CONE PENETROMETER TEST SOUNDING ROD	
<b>CONSISTENCY OR DENSENESS</b>	<b>ABBREVIATIONS</b> AR - AUGER REFUSAL BT - BORING TERMINATED CL - CLAY CPT - CONE PENETRATION TEST CSE - COARSE DMT - DILATOMETER TEST DPT - DYNAMIC PENETRATION TEST e - VOID RATIO F - FINE FOSS. - FOSSILIFEROUS FRAC. - FRACTURED, FRACTURES FRAGS. - FRAGMENTS HL - HIGHLY MED. - MEDIUM MICA - MICA MOD. - MODERATELY NP - NON PLASTIC ORG. - ORGANIC PMT - PRESSUREMETER TEST SAP. - SAPROLITIC SD. - SAND, SANDY SL. - SILT, SILTY SLI. - SLIGHTLY TCR - TRICONE REFUSAL w - MOISTURE CONTENT V - VERY VST - VANE SHEAR TEST WEA. - WEATHERED % - UNIT WEIGHT %g - DRY UNIT WEIGHT SAMPLE ABBREVIATIONS S - BULK SS - SPLIT SPOON ST - SHELBY TUBE RS - ROCK RT - RECOMPACTED TRIAXIAL CBR - CALIFORNIA BEARING RATIO	<b>ROCK HARDNESS</b> <b>VERY HARD</b> - CANNOT BE SCRATCHED BY KNIFE OR SHARP PICK. BREAKING OF HAND SPECIMENS REQUIRES SEVERAL HARD BLOWS OF THE GEOLOGIST'S PICK. <b>HARD</b> - CAN BE SCRATCHED BY KNIFE OR PICK ONLY WITH DIFFICULTY. HARD HAMMER BLOWS REQUIRED TO DETACH HAND SPECIMEN. <b>MODERATELY HARD</b> - CAN BE SCRATCHED BY KNIFE OR PICK. GOUGES OR GROOVES TO 0.25 INCHES DEEP CAN BE EXCAVATED BY HARD BLOW OF A GEOLOGIST'S PICK. HAND SPECIMENS CAN BE DETACHED BY MODERATE BLOWS. <b>MEDIUM HARD</b> - CAN BE GROOVED OR GOUGED 0.05 INCHES DEEP BY FIRM PRESSURE OF KNIFE OR PICK POINT. CAN BE EXCAVATED IN SMALL CHIPS TO PEICES 1 INCH MAXIMUM SIZE BY HARD BLOWS OF THE POINT OF A GEOLOGIST'S PICK. <b>SOFT</b> - CAN BE GROVED OR GOUGED READILY BY KNIFE OR PICK. CAN BE EXCAVATED IN FRAGMENTS FROM CHIPS TO SEVERAL INCHES IN SIZE BY MODERATE BLOWS OF A PICK POINT. SMALL, THIN PIECES CAN BE BROKEN BY FINGER PRESSURE. <b>VERY SOFT</b> - CAN BE CARVED WITH KNIFE. CAN BE EXCAVATED READILY WITH POINT OF PICK. PIECES 1 INCH OR MORE IN THICKNESS CAN BE BROKEN BY FINGER PRESSURE. CAN BE SCRATCHED READILY BY FINGER NAIL.	
<b>TEXTURE OR GRAIN SIZE</b> U.S. STD. SIEVE SIZE OPENING (MM) BOULDER (BLDR.) COBBLE (COB.) GRAVEL (GR.) COARSE SAND (CSE, SD.) FINE SAND (F, SD.) SILT (SL.) CLAY (CL.)			
<b>SOIL MOISTURE - CORRELATION OF TERMS</b>	<b>EQUIPMENT USED ON SUBJECT PROJECT</b>	<b>FRACTURE SPACING</b>	<b>BEDDING</b>
SOIL MOISTURE SCALE (ATTERBERG LIMITS) FIELD MOISTURE DESCRIPTION GUIDE FOR FIELD MOISTURE DESCRIPTION LL - LIQUID LIMIT PL - PLASTIC LIMIT OM - OPTIMUM MOISTURE SL - SHRINKAGE LIMIT SATURATED - (SAT.) USUALLY LIQUID; VERY WET, USUALLY FROM BELOW THE GROUND WATER TABLE WET - (W) SEMISOLID; REQUIRES DRYING TO ATTAIN OPTIMUM MOISTURE MOIST - (M) SOLID; AT OR NEAR OPTIMUM MOISTURE DRY - (D) REQUIRES ADDITIONAL WATER TO ATTAIN OPTIMUM MOISTURE	DRILL UNITS: MOBILE B- BK-51 CME-45C CME-550 PORTABLE HOIST D-50 TRACK ADVANCING TOOLS: CLAY BITS 6" CONTINUOUS FLIGHT AUGER 8" HOLLOW AUGERS HARD FACED FINGER BITS TUNG.-CARBIDE INSERTS CASING W/ ADVANCER TRICONE * STEEL TEETH TRICONE * TUNG.-CARB. CORE BIT 1/4 HOLLOW AUGERS HAMMER TYPE: AUTOMATIC MANUAL CORE SIZE: B N Q2 H HAND TOOLS: POST HOLE DIGGER HAND AUGER SOUNDING ROD VANE SHEAR TEST	<b>VERY WIDE</b> - MORE THAN 10 FEET <b>WIDE</b> - 3 TO 10 FEET <b>MODERATELY CLOSE</b> - 1 TO 3 FEET <b>CLOSE</b> - 0.16 TO 1 FEET <b>VERY CLOSE</b> - LESS THAN 0.16 FEET	<b>VERY THICKLY BEDDED</b> - > 4 FEET <b>THICKLY BEDDED</b> - 1.5 - 4 FEET <b>THINLY BEDDED</b> - 0.16 - 1.5 FEET <b>VERY THINLY BEDDED</b> - 0.03 - 0.16 FEET <b>THICKLY LAMINATED</b> - 0.008 - 0.03 FEET <b>THINLY LAMINATED</b> - < 0.008 FEET
<b>PLASTICITY</b> PLASTICITY INDEX (PI) NONPLASTIC LOW PLASTICITY MED. PLASTICITY HIGH PLASTICITY		<b>INDURATION</b> FOR SEDIMENTARY ROCKS, INDURATION IS THE HARDENING OF THE MATERIAL BY CEMENTING, HEAT, PRESSURE, ETC. <b>FRIABLE</b> <b>MODERATELY INDURATED</b> <b>INDURATED</b> <b>EXTREMELY INDURATED</b>	<b>BENCH MARK:</b> ELEVATION: _____ FT. <b>NOTES:</b> GPK FILE DATED 10/8/2013 AND TIN FILE DATED 6/21/2011 WERE USED TO GET BORING ELEVATIONS AND CROSS SECTION GROUND LINES.
<b>COLOR</b> DESCRIPTIONS MAY INCLUDE COLOR OR COLOR COMBINATIONS (TAN, RED, YELLOW-BROWN, BLUE-GRAY). MODIFIERS SUCH AS LIGHT, DARK, STREAKED, ETC. ARE USED TO DESCRIBE APPEARANCE.			




**SKREW ANGLE = 110°**


# SOUTHBOUND




<b>PROJECT REFERENCE NO.</b>	<b>SHEET</b>
34182.14 (I-3318BB)	4
<b>FENCE DIAGRAM OF BORINGS PROJECTED ALONG -L- PROFILE</b>	




# NORTHBOUND





<b>PROJECT REFERENCE NO.</b>	<b>SHEET</b>
34182.14 (I-3318BB)	5
<b>FENCE DIAGRAM OF BORINGS PROJECTED ALONG -L- PROFILE</b>	






PROJECT REFERENCE NO.	SHEET
34182.14 (I-3318BB)	6
CROSS SECTION THROUGH END BENT 1 -SBL-	







PROJECT REFERENCE NO.	SHEET
34182.14 (I-3318BB)	7
CROSS SECTION THROUGH BENT 1 -SBL-	



SKEW ANGLE = 110°




PROJECT REFERENCE NO.	SHEET
34182.1.4 (3318BB)	8
CROSS SECTION THROUGH BENT 2 -SBL-	




SKEW ANGLE = 110°







PROJECT REFERENCE NO.	SHEET
34182.14 (I-3318BB)	9
CROSS SECTION THROUGH END BENT 2 -SBL-	




SKREW ANGLE = 110°




PROJECT REFERENCE NO.	SHEET
34182.1.4 (I-3318BB)	10
CROSS SECTION THROUGH END BENT 1 -NBL-	




SKEW ANGLE = 110°




PROJECT REFERENCE NO.	SHEET
34182.1.4 (I-3318BB)	11
CROSS SECTION THROUGH BENT 1 -NBL-	




SKEW ANGLE = 110°




<b>PROJECT REFERENCE NO.</b>	<b>SHEET</b>
34182.14 (I-3318BB)	12
<b>CROSS SECTION THROUGH BENT 2 -NBL-</b>	



**SKEW ANGLE = 110°**



PROJECT REFERENCE NO.	SHEET
34182.14 (I-3318BB)	13
CROSS SECTION THROUGH END BENT 2 -NBL-	



Ⓢ RESIDUAL, GRAY, DENSE, DRY, SAPROLITIC, SILTY SAND

SKEW ANGLE = 110°





**NCDOT GEOTECHNICAL ENGINEERING UNIT**  
**BORELOG REPORT**

WBS 34182.1.4	TIP I-3318BB	COUNTY JOHNSTON	GEOLOGIST Contract Geologist	
SITE DESCRIPTION BRIDGE NO. 116 ON -L- (I-95 SOUTHBOUND) OVER LITTLE RIVER				GROUND WTR (ft)
BORING NO. SB_B1-A	STATION 24+49	OFFSET 71 ft LT	ALIGNMENT -L-	0 HR. N/A
COLLAR ELEV. 126.2 ft	TOTAL DEPTH 56.0 ft	NORTHING 663,452	EASTING 2,248,973	24 HR. 4.1
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013		DRILL METHOD NW Casing W/SPT & Core	HAMMER TYPE Automatic	
DRILLER Contract Driller	START DATE 01/03/14	COMP. DATE 01/03/14	SURFACE WATER DEPTH N/A	

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)	
			0.5ft	0.5ft	0.5ft	0	25	50	75	100					
130															
125														126.2	GROUND SURFACE
120	121.0	5.2	3	5	7							M			ALLUVIAL GRAY, SILTY CLAY
115	116.0	10.2	29	27	30							M		118.2	RESIDUAL GRAY TO TAN-GREEN, SAPROLITIC, CLAYEY SILT
110	111.0	15.2	100/0.4											112.7	WEATHERED ROCK (SCHIST)
105	106.0	20.2	6	8	12							M		107.2	RESIDUAL TAN TO GREEN-GRAY AND BROWN, SAPROLITIC, CLAYEY SILT
100	101.0	25.2	100/0.4											102.7	WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)
95	96.0	30.2	37	63/0.4											
90	91.0	35.2	100/0.3												
85	86.0	40.2	60/0.1											87.2	CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)
80														85.9	GREEN-GRAY, SLIGHTLY WEATHERED TO FRESH, MODERATELY HARD TO HARD, VERY CLOSE TO CLOSE FRACTURE SPACING, METAVOLCANIC CHLORITE SCHIST
75															REC=98% RQD=61% RMR=46
														70.2	Boring Terminated at Elevation 70.2 ft IN CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)

NCDOT BORE DOUBLE I3318BB\_GEO\_BH.GPJ NC\_DOT.GDT 1/31/14



**NCDOT GEOTECHNICAL ENGINEERING UNIT**  
**CORE BORING REPORT**

WBS 34182.1.4	TIP I-3318BB	COUNTY JOHNSTON	GEOLOGIST Contract Geologist	
SITE DESCRIPTION BRIDGE NO. 116 ON -L- (I-95 SOUTHBOUND) OVER LITTLE RIVER				GROUND WTR (ft)
BORING NO. SB_B1-A	STATION 24+49	OFFSET 71 ft LT	ALIGNMENT -L-	0 HR. N/A
COLLAR ELEV. 126.2 ft	TOTAL DEPTH 56.0 ft	NORTHING 663,452	EASTING 2,248,973	24 HR. 4.1
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013		DRILL METHOD NW Casing W/SPT & Core	HAMMER TYPE Automatic	
DRILLER Contract Driller	START DATE 01/03/14	COMP. DATE 01/03/14	SURFACE WATER DEPTH N/A	

ELEV (ft)	RUN ELEV (ft)	DEPTH (ft)	RUN (ft)	DRILL RATE (Min/ft)	RUN		SAMP. NO.	STRATA		LOG	DESCRIPTION AND REMARKS	DEPTH (ft)
					REC. (ft) %	RQD (ft) %		REC. (ft) %	RQD (ft) %			
85.9												
85	85.9	40.3	0.7	2:50/0.7	(0.7)	(0.0)		(15.4)	(9.6)		Begin Coring @ 40.3 ft	40.3
	85.2	41.0	5.0	3:10/1.0 2:35/1.0 2:10/1.0 2:05/1.0 1:50/1.0 1:56/1.0	100%	0%	RS-3	98%	61%		GREEN-GRAY, SLIGHTLY WEATHERED TO FRESH, MODERATELY HARD TO HARD, VERY CLOSE TO CLOSE FRACTURE SPACING, METAVOLCANIC CHLORITE SCHIST	
80	80.2	46.0	5.0	1:52/1.0 2:10/1.0 2:05/1.0 1:50/1.0 1:56/1.0	(5.0)	(3.3)					RMR=46	
75	75.2	51.0	5.0	1:50/1.0 1:52/1.0 1:54/1.0 1:58/1.0 1:55/1.0	94%	66%						
		70.2									Boring Terminated at Elevation 70.2 ft IN CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)	56.0

NCDOT CORE DOUBLE I3318BB\_GEO\_BH.GPJ NC\_DOT.GDT 2/3/14

**NCDOT GEOTECHNICAL ENGINEERING UNIT**  
**BORELOG REPORT**

WBS 34182.1.4	TIP I-3318BB	COUNTY JOHNSTON	GEOLOGIST Contract Geologist
SITE DESCRIPTION BRIDGE NO. 116 ON -L- (I-95 SOUTHBOUND) OVER LITTLE RIVER			GROUND WTR (ft)
BORING NO. SB_B1-B	STATION 24+35	OFFSET 12 ft LT	ALIGNMENT -L-
COLLAR ELEV. 123.5 ft	TOTAL DEPTH 43.9 ft	NORTHING 663,392	EASTING 2,248,984
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013		DRILL METHOD H.S. Augers	HAMMER TYPE Automatic
DRILLER Contract Driller	START DATE 12/20/13	COMP. DATE 12/20/13	SURFACE WATER DEPTH N/A

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)		
			0.5ft	0.5ft	0.5ft	0	25	50	75	100						
125														123.5	GROUND SURFACE	0.0
120	119.6	3.9	1	1	3								W	117.3	ALLUVIAL BROWN, GRAY, AND GREEN-GRAY, SANDY CLAY WITH TRACE GRAVEL AND ORGANICS	6.2
115	114.6	8.9	62	38/0.2											WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)	
110	109.6	13.9	40	60/0.1												
105	104.6	18.9	45	55/0.1												
100	99.6	23.9	100/0.5													
95	94.6	28.9	41	59/0.1												
90	89.6	33.9	100/0.3													
85	84.6	38.9	100/0.2													
80	79.6	43.9	60/0.0											79.6	Boring Terminated with Standard Penetration Test Refusal at Elevation 79.6 ft ON CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)	43.9

WBS 34182.1.4	TIP I-3318BB	COUNTY JOHNSTON	GEOLOGIST Contract Geologist
SITE DESCRIPTION BRIDGE NO. 116 ON -L- (I-95 SOUTHBOUND) OVER LITTLE RIVER			GROUND WTR (ft)
BORING NO. SB_B2-A	STATION 25+61	OFFSET 83 ft LT	ALIGNMENT -L-
COLLAR ELEV. 124.4 ft	TOTAL DEPTH 24.1 ft	NORTHING 663,509	EASTING 2,249,070
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013		DRILL METHOD H.S. Augers	HAMMER TYPE Automatic
DRILLER Contract Driller	START DATE 01/10/14	COMP. DATE 01/10/14	SURFACE WATER DEPTH N/A

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)		
			0.5ft	0.5ft	0.5ft	0	25	50	75	100						
125														124.4	GROUND SURFACE	0.0
120	120.4	4.0	1	4	5								M	116.9	ROADWAY EMBANKMENT GRAY AND TAN, SILTY SAND	7.5
115	115.4	9.0	1	5	7								M	112.4	ALLUVIAL GRAY, SILTY SAND	12.0
110	110.4	14.0	100/0.2												WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)	
105	105.4	19.0	100/0.4													
100	100.4	24.0	60/0.1											101.2	CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)	23.2
														100.3	Boring Terminated with Standard Penetration Test Refusal at Elevation 100.3 ft IN CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)	24.1

NCDOT BORE DOUBLE I3318BB\_GEO\_BH.GPJ NC\_DOT.GDT 2/3/14









# NCDOT GEOTECHNICAL ENGINEERING UNIT

## BORELOG REPORT

WBS 34182.1.4	TIP I-3318BB	COUNTY JOHNSTON	GEOLOGIST Contract Geologist
SITE DESCRIPTION BRIDGE NO. 114 ON -L- (I-95 NORTHBOUND) OVER LITTLE RIVER			GROUND WTR (ft)
BORING NO. NB_EB1-A	STATION 23+27	OFFSET 19 ft RT	ALIGNMENT -L-
COLLAR ELEV. 151.0 ft	TOTAL DEPTH 54.3 ft	NORTHING 663,319	EASTING 2,248,899
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013		DRILL METHOD H.S. Augers	HAMMER TYPE Automatic
DRILLER Contract Driller	START DATE 01/08/14	COMP. DATE 01/08/14	SURFACE WATER DEPTH N/A

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION
			0.5ft	0.5ft	0.5ft	0	25	50	75	100			
155													
150													GROUND SURFACE 0.0 ROADWAY EMBANKMENT 1.0 ASPHALT AND CONCRETE GRAY, TAN, AND ORANGE-BROWN, SILTY SAND
145	147.0	4.0	1	2	3							M	
140	142.0	9.0	2	5	4							M	
135	137.0	14.0	2	3	4							M	
130	132.0	19.0	2	4	5							M	
125	127.0	24.0	2	4	4							M	
120	122.0	29.0	4	6	6							M	
115	117.0	34.0	100/0.3							100/0.3		M	WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)
110	112.0	39.0	100/0.3							100/0.3		M	
105	107.0	44.0	100/0.2							100/0.2		M	
100	102.0	49.0	100/0.4							100/0.4		M	
	97.0	54.0	100/0.3							100/0.3		M	Boring Terminated at Elevation 96.7 ft IN WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)

WBS 34182.1.4	TIP I-3318BB	COUNTY JOHNSTON	GEOLOGIST Oti, O. B.
SITE DESCRIPTION BRIDGE NO. 114 ON -L- (I-95 NORTHBOUND) OVER LITTLE RIVER			GROUND WTR (ft)
BORING NO. NB_EB1-B	STATION 23+00	OFFSET 91 ft RT	ALIGNMENT -L-
COLLAR ELEV. 135.9 ft	TOTAL DEPTH 24.0 ft	NORTHING 663,243	EASTING 2,248,904
DRILL RIG/HAMMER EFF./DATE RFO0074 CME-55 92% 07/12/2011		DRILL METHOD H.S. Augers	HAMMER TYPE Automatic
DRILLER Conley, H. R.	START DATE 05/23/13	COMP. DATE 05/23/13	SURFACE WATER DEPTH N/A

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION
			0.5ft	0.5ft	0.5ft	0	25	50	75	100			
140													
135													GROUND SURFACE 0.0 RESIDUAL 135.9 TAN-BROWN, SANDY SILT
130	131.9	4.0	2	2	3						SS-8	M	
125	126.9	9.0	2	2	4						SS-9	M	
120	121.9	14.0	29	55	45/0.4					100/0.9		M	WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)
115	116.9	19.0	19	50	50/0.1					100/0.6		M	
	111.9	24.0	60/0.0							60/0.0		M	Boring Terminated with Standard Penetration Test Refusal at Elevation 111.9 ft ON CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)

NCDOT BORE DOUBLE I3318BB\_GEO\_BH.GPJ NC\_DOT.GDT 2/3/14



**NCDOT GEOTECHNICAL ENGINEERING UNIT**  
**BORELOG REPORT**

WBS 34182.1.4		TIP I-3318BB		COUNTY JOHNSTON		GEOLOGIST Contract Geologist									
SITE DESCRIPTION BRIDGE NO. 114 ON -L- (I-95 NORTHBOUND) OVER LITTLE RIVER							GROUND WTR (ft)								
BORING NO. NB_B1-A		STATION 24+13		OFFSET 12 ft RT		ALIGNMENT -L-									
COLLAR ELEV. 126.2 ft		TOTAL DEPTH 41.2 ft		NORTHING 663,361		EASTING 2,248,974									
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013			DRILL METHOD NW Casing W/SPT & Core		HAMMER TYPE Automatic										
DRILLER Contract Driller		START DATE 01/06/14		COMP. DATE 01/06/14		SURFACE WATER DEPTH N/A									
ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)	
			0.5ft	0.5ft	0.5ft	0	25	50	75	100					
130															
125														126.2	GROUND SURFACE
120	120.9	5.3	1	2	3							M			
115	115.9	10.3	11	89/0.3										117.7	WEATHERED ROCK (METAVOLCANIC CHLORITE SCHIST)
110	110.9	15.3	100/0.3												
105	105.9	20.3	100/0.2												
100	100.9	25.3	60/0.1											102.2	CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)
95														100.8	GREEN-GRAY, VERY SLIGHTLY WEATHERED TO FRESH, MODERATELY HARD TO HARD, CLOSE FRACTURE SPACING, METAVOLCANIC CHLORITE SCHIST
90															REC=99% RQD=63% RMR=56
85														85.0	Boring Terminated at Elevation 85.0 ft IN CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)

NCDOT BORE DOUBLE I3318BB\_GEO\_BH.GPJ NC\_DOT.GDT 1/31/14



**NCDOT GEOTECHNICAL ENGINEERING UNIT**  
**CORE BORING REPORT**

WBS 34182.1.4		TIP I-3318BB		COUNTY JOHNSTON		GEOLOGIST Contract Geologist						
SITE DESCRIPTION BRIDGE NO. 114 ON -L- (I-95 NORTHBOUND) OVER LITTLE RIVER							GROUND WTR (ft)					
BORING NO. NB_B1-A		STATION 24+13		OFFSET 12 ft RT		ALIGNMENT -L-						
COLLAR ELEV. 126.2 ft		TOTAL DEPTH 41.2 ft		NORTHING 663,361		EASTING 2,248,974						
DRILL RIG/HAMMER EFF./DATE SUM0093 DIEDRICH D-50 86% 08/15/2013			DRILL METHOD NW Casing W/SPT & Core		HAMMER TYPE Automatic							
DRILLER Contract Driller		START DATE 01/06/14		COMP. DATE 01/06/14		SURFACE WATER DEPTH N/A						
CORE SIZE NQ2			TOTAL RUN 15.8 ft									
ELEV (ft)	RUN ELEV (ft)	DEPTH (ft)	RUN (ft)	DRILL RATE (Min/ft)	RUN		SAMP. NO.	STRATA		LOG	DESCRIPTION AND REMARKS	DEPTH (ft)
					REC. (ft) %	RQD (ft) %		REC. (ft) %	RQD (ft) %			
100.8	100.8	25.4	0.8	1:58/0.8	(0.7)	(0.5)		(15.6)	(9.9)		Begin Coring @ 25.4 ft	25.4
	100.0	26.2	5.0	1:45/1.0 1:50/1.0 2:05/1.0 2:15/1.0 2:18/1.0	88% (5.0)	63% (2.4)		99%	63%		GREEN-GRAY, VERY SLIGHTLY WEATHERED TO FRESH, MODERATELY HARD TO HARD, CLOSE FRACTURE SPACING, METAVOLCANIC CHLORITE SCHIST	
95	95.0	31.2	5.0	1:59/1.0 1:47/1.0 2:10/1.0 3:18/1.0 2:46/1.0	100% (5.0)	78% (3.9)	RS-1				RMR=56	
90	90.0	36.2	5.0	2:06/1.0 2:10/1.0 2:04/1.0 1:59/1.0 2:13/1.0	98% (4.9)	62% (3.1)						
85	85.0	41.2									Boring Terminated at Elevation 85.0 ft IN CRYSTALLINE ROCK (METAVOLCANIC CHLORITE SCHIST)	41.2

NCDOT BORE DOUBLE I3318BB\_GEO\_BH.GPJ NC\_DOT.GDT 2/3/14







**PROJ. NO. - 34182.1.4**  
**ID NO. - I-3318BB**  
**COUNTY - JOHNSTON**

**SB\_B1-A**

<b>ROCK TEST RESULTS</b>							
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	ROCK TYPE	UNIT WT LB/FT <sup>3</sup>	UNCONFINED COMP. STRENGTH, KSI	SECTION MOD. @ 40% MPSI
RS-3	71' LT	24+49	41.0-41.4	SCHIST	145.0	0.89	0.82

**SB\_B2-B**

<b>ROCK TEST RESULTS</b>							
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	ROCK TYPE	UNIT WT LB/FT <sup>3</sup>	UNCONFINED COMP. STRENGTH, KSI	SECTION MOD. @ 40% MPSI
RS-4	18' LT	25+21	23.5-23.9	SCHIST	163.4	2.19	0.42

**NB\_EB1-B**

<b>SOIL TEST RESULTS</b>															
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	AASHTO CLASS.	L.L.	P.I.	% BY WEIGHT				% PASSING (SIEVES)			% MOISTURE	% ORGANIC
							C.SAND	F.SAND	SILT	CLAY	10	40	200		
S-8	91' RT	23+00	4.0-5.5	A-4(3)	30	8	8.1	37.5	28.2	26.2	97	92	59	-	-
S-9	91' RT	23+00	9.0-10.5	A-4(5)	33	10	16.3	24.8	30.6	28.2	100	90	65	-	-

**NB\_B1-A**

<b>ROCK TEST RESULTS</b>							
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	ROCK TYPE	UNIT WT LB/FT <sup>3</sup>	UNCONFINED COMP. STRENGTH, KSI	SECTION MOD. @ 40% MPSI
RS-1	12' RT	24+13	31.2-31.7	SCHIST	163.7	2.46	0.42

**NB\_B2-B**


<b>ROCK TEST RESULTS</b>							
SAMPLE NO.	OFFSET	STATION	DEPTH INTERVAL	ROCK TYPE	UNIT WT LB/FT <sup>3</sup>	UNCONFINED COMP. STRENGTH, KSI	SECTION MOD. @ 40% MPSI
RS-2	75' RT	24+98	26.0-26.6	SCHIST	173.2	2.05	0.58



# CORE PHOTOGRAPHS

## SB\_B1-A

BOXES 1 & 2: 40.3 - 56.0 FEET



## SB\_B2-B


BOXES 1 - 3: 20.1 - 40.8 FEET






# CORE PHOTOGRAPHS

**NB\_B1-A**  
BOXES 1 & 2: 25.4 - 41.2 FEET



**NB\_B2-B**  
BOXES 1 - 3: 25.2 - 51.0 FEET





# SITE PHOTOGRAPH

Bridge Nos. 114 and 116 on -L- (I-95) over Little River



Looking North and upstream at Bridge No. 114