



MATCHLINE -L- STA.53+50 SEE SHEET 11

MATCHLINE -L- STA.59+00 SEE SHEET 13

MATCHLINE -Y6- STA.19+00 SEE SHEET 27

MATCHLINE -Y6- STA.22+50 SEE SHEET 28

PROP. 45' - 12"
D.I. WATER LINE
1 - 12" VALVE
W/4 - 45
DEGREE BENDS

PROP. 40' -
ABANDON 12" UTILITY
PIPE (D.I. WATER)

PROP. RELOCATE
WATER METER
PROP. RELOCATE
1 1/4" RPZ BACKFLOW
PREVENTION ASS'Y.

PROP. RELOCATE
FIRE HYDRANT
PROP. 53' - 6"
D. I. WATER LINE
1 - 6" TAPPING
VALVE

PROP. - ABANDON UTILITY PIPE
48' - 8" (VC SEWER)
72' - 8" (RCP SEWER)
157' - 10" (PVC SEWER)
42' - 15" (RCP SEWER)

PROP. 4' DIA.
UTILITY MANHOLE E4
STA. 2+39.22, LINE E
23.72' LT. OF -L- STA. 57+32.98

PROP.
RELOCATE
WATER METER

PROP. 2 - ABANDON
UTILITY MANHOLES

CUT OUT TEE
SLEEVE 12" PIPE
REMOVE 6" GATE VALVE
RELOCATE HYDRANT
SHOWN

PROP. 239.22' - 16" SANITARY
GRAVITY SEWER (LINE E)
SEE SHEET UC-43 FOR PROFILE

PROP. 2 - ABANDON
UTILITY MANHOLES

PROP. 4' DIA.
UTILITY MANHOLE E1
STA. 0+00.00, LINE E
7.58' RT. OF -L- STA. 55+81.99

PROP. RELOCATE
FIRE HYDRANT
PROP. 48' - 6"
D. I. WATER LINE
1 - 6" TAPPING
VALVE

PROP.
RELOCATE
WATER METER

PROP. 2 -
RELOCATE
WATER METERS

PROP. 4' DIA.
UTILITY MANHOLE E2
STA. 0+68.46, LINE E
46.32' RT. OF -Y6- STA. 21+28.29

PROP. 4' DIA.
UTILITY MANHOLE E3
STA. 1+49.19, LINE E
34.32' LT. OF -Y6- STA. 21+32.32

PROP. 300' - ABANDON 8"
UTILITY PIPE (TCP SEWER)

PROP. 45' - 12"
D.I. WATER LINE
1 - 12" VALVE
W/4 - 45
DEGREE BENDS

PROP. - 2
SANITARY SEWER
CLEAN-OUTS

PROP. 40' -
ABANDON 12" UTILITY
PIPE (D.I. WATER)

MARKET PLAZA CENTER, LLC.
DB 5364 PG 1777
DB 791 PG 112
DB 815 PG 411
DB 790 PG 352
DB 789 PG 131
DB 1637 PG 1944
DB 1913 PG 406

H. L. PREVATTE,
DB 764 PG 159
DB 1131 PG 165
DB 1131 PG 166

-L-
PI Sta 57+06.06
Δ = 14° 58' 43.2" (RT)
D = 4' 46' 28.7"
L = 313.71'
T = 157.76'
R = 1,200.00'
SE = 04
RUNOFF = 192'
V = 50 mph