

ECONOLITE ASC/3-2070 OVERLAP PROGRAMMING DETAIL *(program controller as shown)*

1. From Main Menu select
2. From CONTROLLER Submenu select

OVERLAP A

Select TMG VEH OVLP [A] and 'PPLT FYA'

TMG VEH OVLP... [A] TYPE:

PROTECTED PHASE (LEFT TURN)..... 1

PERMISSIVE PHASE (OPPOSING THRU)... 2

FLASHING ARROW OUTPUT.....CH9 ISOLATE

DELAY START OF: FYA..0.0 CLEARANCE..0.0

ACTION PLAN SF BIT DISABLE..... 0

Toggle 3 Times

OVERLAP D

Select TMG VEH OVLP [D] and 'NORMAL'

TMG VEH OVLP... [D] TYPE:




PHASES 1 2 3 4 5 6 7 8 9 0 1 2 3 4 5 6

INCLUDED . . . X X

LAG GRN 0.0 YEL 0.0 RED 0.0

END PROGRAMMING

THIS ELECTRICAL DETAIL IS FOR
THE SIGNAL DESIGN: 06-0705
DESIGNED: December 2015
SEALED: 3-31-16
REVISED: N/A

<small>ELECTRICAL AND PROGRAMMING DETAILS FOR:</small> 	US 401 Bypass (Skibo Road) at Cross Creek Mall and Cross Creek Plaza	<small>SEAL</small> 												
	Division 6 Cumberland County Fayetteville PLAN DATE: March 2016 REVIEWED BY: DTJ PREPARED BY: James Peterson REVIEWED BY:	DocuSigned by:  6/15/2016 2F807668E8CD845												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">REVISIONS</th> <th style="width: 20%;">INIT.</th> <th style="width: 20%;">DATE</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>	REVISIONS	INIT.	DATE										SIG. INVENTORY NO. 06-0705	
REVISIONS	INIT.	DATE												