

REFERENCE: B-5333

PROJECT: 46047

CONTENTS

SHEET NO.	DESCRIPTION
1	TITLE SHEET
2	LEGEND
3	SITE PLAN
4	PROFILE
5-10	BORE LOG(S)
11	SITE PHOTOGRAPHS)

STATE OF NORTH CAROLINA
 DEPARTMENT OF TRANSPORTATION
 DIVISION OF HIGHWAYS
 GEOTECHNICAL ENGINEERING UNIT

STRUCTURE
SUBSURFACE INVESTIGATION

COUNTY ROBESON
 PROJECT DESCRIPTION BRIDGE NOs. 173 & 174 ON
SR 1550 (LOWE RD.) OVER THE LUMBER RIVER
AND LUMBER RIVER OVERFLOW
 SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER
RIVER AT STATION 21+66.08 -L-

STATE	STATE PROJECT REFERENCE NO.	SHEET NO.	TOTAL SHEETS
N.C.	B-5333	1	11

CAUTION NOTICE

THE SUBSURFACE INFORMATION AND THE SUBSURFACE INVESTIGATION ON WHICH IT IS BASED WERE MADE FOR THE PURPOSE OF STUDY, PLANNING AND DESIGN, AND NOT FOR CONSTRUCTION OR PAY PURPOSES. THE VARIOUS FIELD BORING LOGS, ROCK CORES AND SOIL TEST DATA AVAILABLE MAY BE REVIEWED OR INSPECTED IN RALEIGH BY CONTACTING THE N. C. DEPARTMENT OF TRANSPORTATION, GEOTECHNICAL ENGINEERING UNIT AT (919) 707-6850. THE SUBSURFACE PLANS AND REPORTS, FIELD BORING LOGS, ROCK CORES AND SOIL TEST DATA ARE NOT PART OF THE CONTRACT.

GENERAL SOIL AND ROCK STRATA DESCRIPTIONS AND INDICATED BOUNDARIES ARE BASED ON A GEOTECHNICAL INTERPRETATION OF ALL AVAILABLE SUBSURFACE DATA AND MAY NOT NECESSARILY REFLECT THE ACTUAL SUBSURFACE CONDITIONS BETWEEN BORINGS OR BETWEEN SAMPLED STRATA WITHIN THE BOREHOLE. THE LABORATORY SAMPLE DATA AND THE IN SITU (IN-PLACE) TEST DATA CAN BE RELIED ON ONLY TO THE DEGREE OF RELIABILITY INHERENT IN THE STANDARD TEST METHOD. THE OBSERVED WATER LEVELS OR SOIL MOISTURE CONDITIONS INDICATED IN THE SUBSURFACE INVESTIGATIONS ARE AS RECORDED AT THE TIME OF THE INVESTIGATION. THESE WATER LEVELS OR SOIL MOISTURE CONDITIONS MAY VARY CONSIDERABLY WITH TIME ACCORDING TO CLIMATIC CONDITIONS INCLUDING TEMPERATURES, PRECIPITATION AND WIND, AS WELL AS OTHER NON-CLIMATIC FACTORS.

THE BIDDER OR CONTRACTOR IS CAUTIONED THAT DETAILS SHOWN ON THE SUBSURFACE PLANS ARE PRELIMINARY ONLY AND IN MANY CASES THE FINAL DESIGN DETAILS ARE DIFFERENT. FOR BIDDING AND CONSTRUCTION PURPOSES, REFER TO THE CONSTRUCTION PLANS AND DOCUMENTS FOR FINAL DESIGN INFORMATION ON THIS PROJECT. THE DEPARTMENT DOES NOT WARRANT OR GUARANTEE THE SUFFICIENCY OR ACCURACY OF THE INVESTIGATION MADE, NOR THE INTERPRETATIONS MADE, OR OPINION OF THE DEPARTMENT AS TO THE TYPE OF MATERIALS AND CONDITIONS TO BE ENCOUNTERED. THE BIDDER OR CONTRACTOR IS CAUTIONED TO MAKE SUCH INDEPENDENT SUBSURFACE INVESTIGATIONS AS HE DEEMS NECESSARY TO SATISFY HIMSELF AS TO CONDITIONS TO BE ENCOUNTERED ON THE PROJECT. THE CONTRACTOR SHALL HAVE NO CLAIM FOR ADDITIONAL COMPENSATION OR FOR AN EXTENSION OF TIME FOR ANY REASON RESULTING FROM THE ACTUAL CONDITIONS ENCOUNTERED AT THE SITE DIFFERING FROM THOSE INDICATED IN THE SUBSURFACE INFORMATION.

- NOTES:
- THE INFORMATION CONTAINED HEREIN IS NOT IMPLIED OR GUARANTEED BY THE N. C. DEPARTMENT OF TRANSPORTATION AS ACCURATE NOR IS IT CONSIDERED PART OF THE PLANS, SPECIFICATIONS OR CONTRACT FOR THE PROJECT.
 - BY HAVING REQUESTED THIS INFORMATION, THE CONTRACTOR SPECIFICALLY WAIVES ANY CLAIMS FOR INCREASED COMPENSATION OR EXTENSION OF TIME BASED ON DIFFERENCES BETWEEN THE CONDITIONS INDICATED HEREIN AND THE ACTUAL CONDITIONS AT THE PROJECT SITE.

PERSONNEL

C. WANG

S. DAVIS

W. SHENBERGER

INVESTIGATED BY F&R, Inc.

DRAWN BY T.T. WALKER

CHECKED BY P. ALTON

SUBMITTED BY P. ALTON

DATE NOVEMBER 2015



DocuSigned by:

W. Patrick Alton

12/2/2015



A270EF78A6DF442
SIGNATURE

DATE


DOCUMENT NOT CONSIDERED FINAL
UNLESS ALL SIGNATURES COMPLETED

**NORTH CAROLINA DEPARTMENT OF TRANSPORTATION
DIVISION OF HIGHWAYS
GEOTECHNICAL ENGINEERING UNIT
SUBSURFACE INVESTIGATION
SOIL AND ROCK LEGEND, TERMS, SYMBOLS, AND ABBREVIATIONS**


SOIL DESCRIPTION	GRADATION	ROCK DESCRIPTION	TERMS AND DEFINITIONS
SOIL IS CONSIDERED UNCONSOLIDATED, SEMI-CONSOLIDATED, OR WEATHERED EARTH MATERIALS THAT CAN BE PENETRATED WITH A CONTINUOUS FLIGHT POWER AUGER AND YIELD LESS THAN 100 BLOWS PER FOOT ACCORDING TO THE STANDARD PENETRATION TEST (AASHTO T 206, ASTM D1586). SOIL CLASSIFICATION IS BASED ON THE AASHTO SYSTEM. BASIC DESCRIPTIONS GENERALLY INCLUDE THE FOLLOWING: CONSISTENCY, COLOR, TEXTURE, MOISTURE, AASHTO CLASSIFICATION, AND OTHER PERTINENT FACTORS SUCH AS MINERALOGICAL COMPOSITION, ANGULARITY, STRUCTURE, PLASTICITY, ETC. FOR EXAMPLE, VERY STIFF, GRAY, SILTY CLAY, MOIST WITH INTERBEDDED FINE SAND LAYERS, HIGHLY PLASTIC, A-7-6	WELL GRADED - INDICATES A GOOD REPRESENTATION OF PARTICLE SIZES FROM FINE TO COARSE. UNIFORMLY GRADED - INDICATES THAT SOIL PARTICLES ARE ALL APPROXIMATELY THE SAME SIZE. GAP-GRADED - INDICATES A MIXTURE OF UNIFORM PARTICLE SIZES OF TWO OR MORE SIZES.	HARD ROCK IS NON-COASTAL PLAIN MATERIAL THAT WOULD YIELD SPT REFUSAL IF TESTED, AN INFERRED ROCK LINE INDICATES THE LEVEL AT WHICH NON-COASTAL PLAIN MATERIAL WOULD YIELD SPT REFUSAL. SPT REFUSAL IS PENETRATION BY A SPLIT SPOON SAMPLER EQUAL TO OR LESS THAN 60 BLOWS PER 60 BLOWS IN NON-COASTAL PLAIN MATERIAL. THE TRANSITION BETWEEN SOIL AND ROCK IS OFTEN REPRESENTED BY A ZONE OF WEATHERED ROCK. ROCK MATERIALS ARE TYPICALLY DIVIDED AS FOLLOWS: WEATHERED ROCK (WR) NON-COASTAL PLAIN MATERIAL THAT WOULD YIELD SPT N VALUES > 100 BLOWS PER FOOT IF TESTED. CRYSTALLINE ROCK (CR) FINE TO COARSE GRAIN IGNEOUS AND METAMORPHIC ROCK THAT WOULD YIELD SPT REFUSAL IF TESTED. ROCK TYPE INCLUDES GRANITE, GNEISS, GABBRO, SCHIST, ETC. NON-CRYSTALLINE ROCK (INCR) FINE TO COARSE GRAIN METAMORPHIC AND NON-COASTAL PLAIN SEDIMENTARY ROCK THAT WOULD YIELD SPT REFUSAL IF TESTED. ROCK TYPE INCLUDES PHYLLITE, SLATE, SANDSTONE, ETC. COASTAL PLAIN SEDIMENTARY ROCK (CP) COASTAL PLAIN SEDIMENTS CEMENTED INTO ROCK, BUT MAY NOT YIELD SPT REFUSAL. ROCK TYPE INCLUDES LIMESTONE, SANDSTONE, CEMENTED SHELL BEDS, ETC.	ALLUVIUM (ALLUV.) - SOILS THAT HAVE BEEN TRANSPORTED BY WATER. AQUIFER - A WATER BEARING FORMATION OR STRATA. ARENACEOUS - APPLIED TO ROCKS THAT HAVE BEEN DERIVED FROM SAND OR THAT CONTAIN SAND. ARGILLACEOUS - APPLIED TO ALL ROCKS OR SUBSTANCES COMPOSED OF CLAY MINERALS, OR HAVING A NOTABLE PROPORTION OF CLAY IN THEIR COMPOSITION, SUCH AS SHALE, SLATE, ETC. ARTESIAN - GROUND WATER THAT IS UNDER SUFFICIENT PRESSURE TO RISE ABOVE THE LEVEL AT WHICH IT IS ENCOUNTERED, BUT WHICH DOES NOT NECESSARILY RISE TO OR ABOVE THE GROUND SURFACE. CALCAREOUS (CALC.) - SOILS THAT CONTAIN APPRECIABLE AMOUNTS OF CALCIUM CARBONATE. COLLUVIUM - ROCK FRAGMENTS MIXED WITH SOIL DEPOSITED BY GRAVITY ON SLOPE OR AT BOTTOM OF SLOPE. CORE RECOVERY (REC.) - TOTAL LENGTH OF ALL MATERIAL RECOVERED IN THE CORE BARREL DIVIDED BY TOTAL LENGTH OF CORE RUN AND EXPRESSED AS A PERCENTAGE. DIKE - A TABULAR BODY OF IGNEOUS ROCK THAT CUTS ACROSS THE STRUCTURE OF ADJACENT ROCKS OR CUTS MASSIVE ROCK. DIP - THE ANGLE AT WHICH A STRATUM OR ANY PLANAR FEATURE IS INCLINED FROM THE HORIZONTAL. DIP DIRECTION (DIP AZIMUTH) - THE DIRECTION OR BEARING OF THE HORIZONTAL TRACE OF THE LINE OF DIP, MEASURED CLOCKWISE FROM NORTH. FAULT - A FRACTURE OR FRACTURE ZONE ALONG WHICH THERE HAS BEEN DISPLACEMENT OF THE SIDES RELATIVE TO ONE ANOTHER PARALLEL TO THE FRACTURE. FISSILE - A PROPERTY OF SPLITTING ALONG CLOSELY SPACED PARALLEL PLANES. FLOAT - ROCK FRAGMENTS ON SURFACE NEAR THEIR ORIGINAL POSITION AND DISLODGED FROM PARENT MATERIAL. FLOOD PLAIN (FP) - LAND BORDERING A STREAM, BUILT OF SEDIMENTS DEPOSITED BY THE STREAM. FORMATION (FM) - A MAPPABLE GEOLOGIC UNIT THAT CAN BE RECOGNIZED AND TRACED IN THE FIELD. JOINT - FRACTURE IN ROCK ALONG WHICH NO APPRECIABLE MOVEMENT HAS OCCURRED. LEDGE - A SHELF-LIKE RIDGE OR PROJECTION OF ROCK WHOSE THICKNESS IS SMALL COMPARED TO ITS LATERAL EXTENT. LENS - A BODY OF SOIL OR ROCK THAT THINS OUT IN ONE OR MORE DIRECTIONS. MOTTLED (MOT.) - IRREGULARLY MARKED WITH SPOTS OF DIFFERENT COLORS. MOTTLING IN SOILS USUALLY INDICATES POOR AERATION AND LACK OF GOOD DRAINAGE. PERCHED WATER - WATER MAINTAINED ABOVE THE NORMAL GROUND WATER LEVEL BY THE PRESENCE OF AN INTERVENING IMPERVIOUS STRATUM. RESIDUAL (RES.) SOIL - SOIL FORMED IN PLACE BY THE WEATHERING OF ROCK. ROCK QUALITY DESIGNATION (RQD) - A MEASURE OF ROCK QUALITY DESCRIBED BY TOTAL LENGTH OF ROCK SEGMENTS EQUAL TO OR GREATER THAN 4 INCHES DIVIDED BY THE TOTAL LENGTH OF CORE RUN AND EXPRESSED AS A PERCENTAGE. SAPROLITE (SAP.) - RESIDUAL SOIL THAT RETAINS THE RELIC STRUCTURE OR FABRIC OF THE PARENT ROCK. SILL - AN INTRUSIVE BODY OF IGNEOUS ROCK OF APPROXIMATELY UNIFORM THICKNESS AND RELATIVELY THIN COMPARED WITH ITS LATERAL EXTENT, THAT HAS BEEN EMPLACED PARALLEL TO THE BEDDING OR SCHISTOSITY OF THE INTRODUCED ROCKS. SLICKENSIDE - POLISHED AND STRIATED SURFACE THAT RESULTS FROM FRICTION ALONG A FAULT OR SLIP PLANE. STANDARD PENETRATION TEST (PENETRATION RESISTANCE) (SPT) - NUMBER OF BLOWS IN OR BPF) OF A 140 LB. HAMMER FALLING 30 INCHES REQUIRED TO PRODUCE A PENETRATION OF 1 FOOT INTO SOIL WITH A 2 INCH OUTSIDE DIAMETER SPLIT SPOON SAMPLER. SPT REFUSAL IS PENETRATION EQUAL TO OR LESS THAN 60 BLOWS. STRATA CORE RECOVERY (SREC.) - TOTAL LENGTH OF STRATA MATERIAL RECOVERED DIVIDED BY TOTAL LENGTH OF STRATUM AND EXPRESSED AS A PERCENTAGE. STRATA ROCK QUALITY DESIGNATION (SRQD) - A MEASURE OF ROCK QUALITY DESCRIBED BY TOTAL LENGTH OF ROCK SEGMENTS WITHIN A STRATUM EQUAL TO OR GREATER THAN 4 INCHES DIVIDED BY THE TOTAL LENGTH OF STRATA AND EXPRESSED AS A PERCENTAGE. TOPSOIL (TS.) - SURFACE SOILS USUALLY CONTAINING ORGANIC MATTER.
SOIL LEGEND AND AASHTO CLASSIFICATION	ANGULARITY OF GRAINS THE ANGULARITY OR ROUNDNESS OF SOIL GRAINS IS DESIGNATED BY THE TERMS: ANGULAR, SUBANGULAR, SUBROUNDED, OR ROUNDED.	WEATHERING FRESH - ROCK FRESH, CRYSTALS BRIGHT, FEW JOINTS MAY SHOW SLIGHT STAINING. ROCK RINGS UNDER HAMMER IF CRYSTALLINE. VERY SLIGHT (V SLI.) - ROCK GENERALLY FRESH, JOINTS STAINED, SOME JOINTS MAY SHOW THIN CLAY COATINGS IF OPEN. CRYSTALS ON A BROKEN SPECIMEN FACE SHINE BRIGHTLY. ROCK RINGS UNDER HAMMER BLOWS IF OF A CRYSTALLINE NATURE. SLIGHT (SLI.) - ROCK GENERALLY FRESH, JOINTS STAINED AND DISCOLORATION EXTENDS INTO ROCK UP TO 1 INCH. OPEN JOINTS MAY CONTAIN CLAY. IN GRANITOID ROCKS SOME OCCASIONAL FELDSPAR CRYSTALS ARE DULL AND DISCOLORED. CRYSTALLINE ROCKS RING UNDER HAMMER BLOWS. MODERATE (MOD.) - SIGNIFICANT PORTIONS OF ROCK SHOW DISCOLORATION AND WEATHERING EFFECTS. IN GRANITOID ROCKS, MOST FELDSPARS ARE DULL AND DISCOLORED, SOME SHOW CLAY. ROCK HAS DULL SOUND UNDER HAMMER BLOWS AND SHOWS SIGNIFICANT LOSS OF STRENGTH AS COMPARED WITH FRESH ROCK. MODERATELY SEVERE (MOD. SEV.) - ALL ROCK EXCEPT QUARTZ DISCOLORED OR STAINED. IN GRANITOID ROCKS, ALL FELDSPARS DULL AND DISCOLORED AND A MAJORITY SHOW KAOLINIZATION. ROCK SHOWS SEVERE LOSS OF STRENGTH AND CAN BE EXCAVATED WITH A GEOLOGIST'S PICK. ROCK GIVES "CLUNK" SOUND WHEN STRUCK. <i>IF TESTED, WOULD YIELD SPT REFUSAL</i> SEVERE (SEV.) - ALL ROCK EXCEPT QUARTZ DISCOLORED OR STAINED. ROCK FABRIC CLEAR AND EVIDENT BUT REDUCED IN STRENGTH TO STRONG SOIL. IN GRANITOID ROCKS ALL FELDSPARS ARE KAOLINIZED TO SOME EXTENT. SOME FRAGMENTS OF STRONG ROCK USUALLY REMAIN. <i>IF TESTED, WOULD YIELD SPT N VALUES > 100 BPF</i> VERY SEVERE (V SEV.) - ALL ROCK EXCEPT QUARTZ DISCOLORED OR STAINED. ROCK FABRIC ELEMENTS ARE DISCERNIBLE BUT MASS IS EFFECTIVELY REDUCED TO SOIL STATUS, WITH ONLY FRAGMENTS OF STRONG ROCK REMAINING. SAPROLITE IS AN EXAMPLE OF ROCK WEATHERED TO A DEGREE THAT ONLY MINOR VESTIGES OF ORIGINAL ROCK FABRIC REMAIN. <i>IF TESTED, WOULD YIELD SPT N VALUES < 100 BPF</i> COMPLETE - ROCK REDUCED TO SOIL. ROCK FABRIC NOT DISCERNIBLE, OR DISCERNIBLE ONLY IN SMALL AND SCATTERED CONCENTRATIONS. QUARTZ MAY BE PRESENT AS DIKES OR STRINGERS. SAPROLITE IS ALSO AN EXAMPLE.	TERMS AND DEFINITIONS
GENERAL CLASS. A-1, A-1-b, A-3, A-2-4, A-2-5, A-2-6, A-2-7, A-4, A-5, A-6, A-7, A-1, A-2, A-3, A-4, A-5, A-6, A-7	MINERALOGICAL COMPOSITION MINERAL NAMES SUCH AS QUARTZ, FELDSPAR, MICA, TALC, KAOLIN, ETC. ARE USED IN DESCRIPTIONS WHEN THEY ARE CONSIDERED OF SIGNIFICANCE.	CRISTALLINE ROCK (CR)	
GROUP CLASS.	COMPRESSIBILITY SLIGHTLY COMPRESSIBLE LL < 31 MODERATELY COMPRESSIBLE LL = 31 - 50 HIGHLY COMPRESSIBLE LL > 50	NON-CRYSTALLINE ROCK (INCR)	
SYMBOL	PERCENTAGE OF MATERIAL	COASTAL PLAIN SEDIMENTARY ROCK (CP)	
% PASSING *10 *40 *200	ORGANIC MATERIAL TRACE OF ORGANIC MATTER 2 - 3% LITTLE ORGANIC MATTER 3 - 5% MODERATELY ORGANIC 5 - 10% HIGHLY ORGANIC > 10%		
MATERIAL PASSING #40 LL PI	GROUND WATER WATER LEVEL IN BORE HOLE IMMEDIATELY AFTER DRILLING STATIC WATER LEVEL AFTER 24 HOURS PERCHED WATER, SATURATED ZONE, OR WATER BEARING STRATA SPRING OR SEEP		
GROUP INDEX	MISCELLANEOUS SYMBOLS ROADWAY EMBANKMENT (RE) WITH SOIL DESCRIPTION SOIL SYMBOL ARTIFICIAL FILL (AF) OTHER THAN ROADWAY EMBANKMENT INFERRED SOIL BOUNDARY INFERRED ROCK LINE ALLUVIAL SOIL BOUNDARY		
USUAL TYPES OF MAJOR MATERIALS	RECOMMENDATION SYMBOLS UNDERCUT SHALLOW UNDERCUT UNCLASSIFIED EXCAVATION - UNSUITABLE WASTE UNCLASSIFIED EXCAVATION - ACCEPTABLE DEGRADABLE ROCK		
GEN. RATING AS SUBGRADE	ABBREVIATIONS AR - AUGER REFUSAL BT - BORING TERMINATED CL - CLAY CPT - CONE PENETRATION TEST CSE - COARSE DMT - DILATOMETER TEST DPT - DYNAMIC PENETRATION TEST e - VOID RATIO F - FINE FOSS. - FOSSILIFEROUS FRAC. - FRACTURED, FRACTURES FRAGS. - FRAGMENTS HL - HIGHLY MED. - MEDIUM MICA - MICA MOD. - MODERATELY NP - NON PLASTIC ORG. - ORGANIC PMT - PRESSUREMETER TEST SAP. - SAPROLITIC SD. - SAND, SANDY SL. - SILT, SILTY SLL. - SLIGHTLY TCR - TRICONE REFUSAL w - MOISTURE CONTENT V - VERY VST - VANE SHEAR TEST WEA. - WEATHERED % - UNIT WEIGHT % - DRY UNIT WEIGHT SAMPLE ABBREVIATIONS SS - BULK SS - SPLIT SPOON ST - SHELBY TUBE RS - ROCK RT - RECOMPACTED TRIAXIAL CBR - CALIFORNIA BEARING RATIO		
CONSISTENCY OR DENSENESS	EQUIPMENT USED ON SUBJECT PROJECT DRILL UNITS: <input type="checkbox"/> CME-45C <input checked="" type="checkbox"/> CME-55 <input type="checkbox"/> CME-550 <input type="checkbox"/> VANE SHEAR TEST <input type="checkbox"/> PORTABLE HOIST ADVANCING TOOLS: <input type="checkbox"/> CLAY BITS <input type="checkbox"/> 6" CONTINUOUS FLIGHT AUGER <input checked="" type="checkbox"/> 8" HOLLOW AUGERS <input type="checkbox"/> HARD FACED FINGER BITS <input type="checkbox"/> TUNG.-CARBIDE INSERTS <input type="checkbox"/> CASING <input type="checkbox"/> w/ ADVANCER <input type="checkbox"/> TRICONE <input type="checkbox"/> *STEEL TEETH <input type="checkbox"/> TRICONE <input type="checkbox"/> *TUNG.-CARB. <input type="checkbox"/> CORE BIT <input checked="" type="checkbox"/> DRAG BIT HAMMER TYPE: <input checked="" type="checkbox"/> AUTOMATIC <input type="checkbox"/> MANUAL CORE SIZE: <input type="checkbox"/> -B <input type="checkbox"/> -H <input type="checkbox"/> -N HAND TOOLS: <input type="checkbox"/> POST HOLE DIGGER <input type="checkbox"/> HAND AUGER <input type="checkbox"/> SOUNDING ROD <input type="checkbox"/> VANE SHEAR TEST		
TEXTURE OR GRAIN SIZE	ROCK HARDNESS VERY HARD - CANNOT BE SCRATCHED BY KNIFE OR SHARP PICK. BREAKING OF HAND SPECIMENS REQUIRES SEVERAL HARD BLOWS OF THE GEOLOGIST'S PICK. HARD - CAN BE SCRATCHED BY KNIFE OR PICK ONLY WITH DIFFICULTY. HARD HAMMER BLOWS REQUIRED TO DETACH HAND SPECIMEN. MODERATELY HARD - CAN BE SCRATCHED BY KNIFE OR PICK. GOUGES OR GROOVES TO 0.25 INCHES DEEP CAN BE EXCAVATED BY HARD BLOW OF A GEOLOGIST'S PICK. HAND SPECIMENS CAN BE DETACHED BY MODERATE BLOWS. MEDIUM HARD - CAN BE GROOVED OR GOUGED 0.05 INCHES DEEP BY FIRM PRESSURE OF KNIFE OR PICK POINT. CAN BE EXCAVATED IN SMALL CHIPS TO PEICES 1 INCH MAXIMUM SIZE BY HARD BLOWS OF THE POINT OF A GEOLOGIST'S PICK. SOFT - CAN BE GROVED OR GOUGED READILY BY KNIFE OR PICK. CAN BE EXCAVATED IN FRAGMENTS FROM CHIPS TO SEVERAL INCHES IN SIZE BY MODERATE BLOWS OF A PICK POINT. SMALL, THIN PIECES CAN BE BROKEN BY FINGER PRESSURE. VERY SOFT - CAN BE CARVED WITH KNIFE. CAN BE EXCAVATED READILY WITH POINT OF PICK. PIECES 1 INCH OR MORE IN THICKNESS CAN BE BROKEN BY FINGER PRESSURE. CAN BE SCRATCHED READILY BY FINGER NAIL.		
COMPACTNESS OR CONSISTENCY	FRACTURE SPACING TERM SPACING VERY WIDE MORE THAN 10 FEET WIDE 3 TO 10 FEET MODERATELY CLOSE 1 TO 3 FEET CLOSE 0.15 TO 1 FOOT VERY CLOSE LESS THAN 0.16 FEET		
RANGE OF STANDARD PENETRATION RESISTANCE (N-VALUE)	BEDDING TERM THICKNESS VERY THICKLY BEDDED 4 FEET THICKLY BEDDED 1.5 - 4 FEET THINLY BEDDED 0.16 - 1.5 FEET VERY THINLY BEDDED 0.03 - 0.16 FEET THICKLY LAMINATED 0.008 - 0.03 FEET THINLY LAMINATED < 0.008 FEET		
RANGE OF UNCONFINED COMPRESSIVE STRENGTH (TONS/FT²)	INDURATION FOR SEDIMENTARY ROCKS, INDURATION IS THE HARDENING OF MATERIAL BY CEMENTING, HEAT, PRESSURE, ETC. FRIABLE - RUBBING WITH FINGER FREES NUMEROUS GRAINS; GENTLE BLOW BY HAMMER DISINTEGRATES SAMPLE. MODERATELY INDURATED - GRAINS CAN BE SEPARATED FROM SAMPLE WITH STEEL PROBE; BREAKS EASILY WHEN HIT WITH HAMMER. INDURATED - GRAINS ARE DIFFICULT TO SEPARATE WITH STEEL PROBE; DIFFICULT TO BREAK WITH HAMMER. EXTREMELY INDURATED - SHARP HAMMER BLOWS REQUIRED TO BREAK SAMPLE; SAMPLE BREAKS ACROSS GRAINS.		
U.S. STD. SIEVE SIZE OPENING (MM)	PLASTICITY PLASTICITY INDEX (PI) DRY STRENGTH NON PLASTIC 0-5 VERY LOW SLIGHTLY PLASTIC 6-15 SLIGHT MODERATELY PLASTIC 16-25 MEDIUM HIGHLY PLASTIC 26 OR MORE HIGH		
BOULDER (BLDR.) COBBLE (COB.) GRAVEL (GR.) COARSE SAND (CSE. SD.) FINE SAND (F. SD.) SILT (SL.) CLAY (CL.)	COLOR DESCRIPTIONS MAY INCLUDE COLOR OR COLOR COMBINATIONS (TAN, RED, YELLOW-BROWN, BLUE-BROWN). MODIFIERS SUCH AS LIGHT, DARK, STREAKED, ETC. ARE USED TO DESCRIBE APPEARANCE.		
GRAIN SIZE	NOTES:		
SOIL MOISTURE - CORRELATION OF TERMS	ELEVATION: 137.47 FEET		
SOIL MOISTURE SCALE (ATTERBERG LIMITS)	DATE: 8-15-14		



SKEW=90°



PROJECT REFERENCE NO.	SHEET NO.
B-5333	4
PROFILE BORINGS PROJECTED ALONG -L-	



GEOTECHNICAL BORING REPORT

BORE LOG


WBS 46047.1.1		TIP B-5333		COUNTY ROBESON		GEOLOGIST C. WANG										
SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER RIVER AT STATION 21+66.08 -L-							GROUND WTR (ft)									
BORING NO. B1-A		STATION 20+82		OFFSET 6 ft LT		ALIGNMENT -L-										
COLLAR ELEV. 130.3 ft		TOTAL DEPTH 95.0 ft		NORTHING 317,605		EASTING 1,958,942										
DRILL RIG/HAMMER EFF./DATE F&R2175 CME-55 76% 02/25/2015			DRILL METHOD Mud Rotary			HAMMER TYPE Automatic										
DRILLER S. DAVIS		START DATE 10/01/15		COMP. DATE 10/01/15		SURFACE WATER DEPTH N/A										
ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG MOI	LOG G	SOIL AND ROCK DESCRIPTION		
			0.5ft	0.5ft	0.5ft	0	25	50	75	100				ELEV. (ft)	DEPTH (ft)	
135																
130	130.3	0.0	1	3	2										130.3	GROUND SURFACE
125	126.8	3.5	3	3	4											ALLUVIAL BROWN, FINE TO COARSE SAND (A-3)
120	121.8	8.5	WOH	1	1										122.3	YELLOW AND GRAY-BLACK, SILTY FINE TO COARSE SAND (A-2-4) WITH CREOSOTE ODOR
115	116.8	13.5	1	WOH	WOH											Sat.
110	111.8	18.5	1	1	2										112.3	COASTAL PLAIN GRAY-BLACK, SILTY FINE SAND (A-2-4) (BLACK CREEK FORMATION)
105	106.8	23.5	4	6	5											Sat.
100	101.8	28.5	12	18	18										102.3	GRAY-BLACK, COARSE TO FINE SAND (A-3)
95	96.8	33.5	8	7	7										97.3	GRAY, CLAYEY FINE TO COARSE SAND (A-2-6)
90	91.8	38.5	4	5	7										92.3	GRAY, FINE SANDY SILTY CLAY (A-7-5) WITH TRACE ORGANICS
85	86.8	43.5	4	6	5											Sat.
80	81.8	48.5	4	6	7											Sat.
75	76.8	53.5	5	8	10											Sat.
70	71.8	58.5	5	8	10											Sat.
65	66.8	63.5	4	7	9											Sat.
60	61.8	68.5	3	6	8											Sat.
55	56.8	73.5	3	5	7											Sat.

WBS 46047.1.1		TIP B-5333		COUNTY ROBESON		GEOLOGIST C. WANG										
SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER RIVER AT STATION 21+66.08 -L-							GROUND WTR (ft)									
BORING NO. B1-A		STATION 20+82		OFFSET 6 ft LT		ALIGNMENT -L-										
COLLAR ELEV. 130.3 ft		TOTAL DEPTH 95.0 ft		NORTHING 317,605		EASTING 1,958,942										
DRILL RIG/HAMMER EFF./DATE F&R2175 CME-55 76% 02/25/2015			DRILL METHOD Mud Rotary			HAMMER TYPE Automatic										
DRILLER S. DAVIS		START DATE 10/01/15		COMP. DATE 10/01/15		SURFACE WATER DEPTH N/A										
ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG MOI	LOG G	SOIL AND ROCK DESCRIPTION		
			0.5ft	0.5ft	0.5ft	0	25	50	75	100				ELEV. (ft)	DEPTH (ft)	
55																
50	51.8	78.5	5	6	10											Match Line
45	46.8	83.5	8	14	20											Sat. 46.0 84.3
40	41.8	88.5	11	13	16											Sat. 42.3 88.0
	36.8	93.5	10	10	9											Sat. 36.3 94.0
																Sat. 35.3 95.0
																Boring Terminated at Elevation 35.3 ft in CLAY (BLACK CREEK FORMATION)


NCDOT BORE DOUBLE B5333_GEO_BH_BRDG0173.GPJ NC_DOT_GDT 11/11/15

GEOTECHNICAL BORING REPORT

BORE LOG



NCDOT BORE DOUBLE B5333_GEO_BH_BRD0173.GPJ NC_DOT.GDT 11/11/15



GEOTECHNICAL BORING REPORT

BORE LOG

WBS 46047.1.1		TIP B-5333		COUNTY ROBESON		GEOLOGIST C. WANG	
SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER RIVER AT STATION 21+66.08 -L-							GROUND WTR (ft)
BORING NO. B3-A		STATION 21+82		OFFSET 7 ft LT		ALIGNMENT -L-	
COLLAR ELEV. 119.4 ft		TOTAL DEPTH 90.0 ft		NORTHING 317,662		EASTING 1,959,025	
DRILL RIG/HAMMER EFF./DATE F&R2175 CME-55 76% 02/25/2015			DRILL METHOD Mud Rotary		HAMMER TYPE Automatic		
DRILLER S. DAVIS		START DATE 09/30/15		COMP. DATE 09/30/15		SURFACE WATER DEPTH 7.0ft	

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)
			0.5ft	0.5ft	0.5ft	0	25	50	75	100				
120	119.4	0.0	1	3	3								GROUND SURFACE	0.0
	115.9	3.5	1	WOH	1								ALLUVIAL GRAY-BROWN, COARSE SAND (A-1-b) WITH TRACE SHELLS AND ORGANICS	3.0
	110.9	8.5	3		3								GRAY-BLACK, SILTY FINE TO COARSE SAND (A-2-4)	
	105.9	13.5	6		9								COASTAL PLAIN GRAY AND WHITE, SILTY FINE TO COARSE SAND (A-2-4) (BLACK CREEK FORMATION)	13.0
	100.9	18.5	5		8									
	95.9	23.5	3		2								GRAY, CLAYEY FINE TO COARSE SAND (A-2-6)	23.0
	90.9	28.5	3		6								GRAY, FINE SANDY SILTY CLAY (A-7-5)	28.0
	85.9	33.5	3		4								GRAY, CLAYEY FINE SAND (A-2-6)	33.0
	80.9	38.5	8		9								GRAY, FINE SANDY SILTY CLAY (A-7-5)	38.0
	75.9	43.5	8		11									
	70.9	48.5	7		7								GRAY, FINE SANDY SILT (A-4)	48.0
	65.9	53.5	7		11								BLACK-BROWN, SILTY CLAY (A-7-5)	53.0
	60.9	58.5	6		9									
	55.9	63.5	4		7									
	50.9	68.5	8		13								GRAY, FINE TO COARSE SANDY SILTY CLAY (A-7-5)	68.0
	45.9	73.5	10		8								GRAY, CLAYEY FINE TO COARSE SAND (A-2-6)	73.0
	40.9	78.5	12		18									
40														40.1

NCDOT BORE DOUBLE B5333_GEO_BH_BRDG0173.GPJ NC_DOT.GDT 11/11/15

WBS 46047.1.1		TIP B-5333		COUNTY ROBESON		GEOLOGIST C. WANG	
SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER RIVER AT STATION 21+66.08 -L-							GROUND WTR (ft)
BORING NO. B3-A		STATION 21+82		OFFSET 7 ft LT		ALIGNMENT -L-	
COLLAR ELEV. 119.4 ft		TOTAL DEPTH 90.0 ft		NORTHING 317,662		EASTING 1,959,025	
DRILL RIG/HAMMER EFF./DATE F&R2175 CME-55 76% 02/25/2015			DRILL METHOD Mud Rotary		HAMMER TYPE Automatic		
DRILLER S. DAVIS		START DATE 09/30/15		COMP. DATE 09/30/15		SURFACE WATER DEPTH 7.0ft	

ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)
			0.5ft	0.5ft	0.5ft	0	25	50	75	100				
40														
	35.9	83.5	6		8								BLACK-BROWN, SILTY CLAY (A-7-5) (continued)	
	30.9	88.5	15		24								GRAY, SILTY FINE TO COARSE SAND (A-2-4)	88.0
													Boring Terminated at Elevation 29.4 ft in SAND (BLACK CREEK FORMATION)	90.0

GEOTECHNICAL BORING REPORT

BORE LOG

WBS 46047.1.1		TIP B-5333		COUNTY ROBESON		GEOLOGIST C. WANG											
SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER RIVER AT STATION 21+66.08 -L-							GROUND WTR (ft)										
BORING NO. B4-B		STATION 22+32		OFFSET 7 ft RT		ALIGNMENT -L-											
COLLAR ELEV. 127.3 ft		TOTAL DEPTH 90.0 ft		NORTHING 317,678		EASTING 1,959,074											
DRILL RIG/HAMMER EFF./DATE F&R2175 CME-55 76% 02/25/2015			DRILL METHOD Mud Rotary			HAMMER TYPE Automatic											
DRILLER S. DAVIS		START DATE 09/29/15		COMP. DATE 09/29/15		SURFACE WATER DEPTH N/A											
ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	MOI	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)		
			0.5ft	0.5ft	0.5ft	0	25	50	75	100							
130																	
	127.3	0.0	1	1	2										127.3	GROUND SURFACE	0.0
125																ALLUVIAL GRAY-BROWN, FINE TO COARSE SAND (A-3) WITH TRACE ORGANICS	
	123.8	3.5	2	3	5												
120																	
	118.8	8.5	3	3	4											GRAY-BROWN, COARSE SAND (A-1-b) WITH TRACE WOOD FRAGMENTS	8.0
115																	
	113.8	13.5	4	4	4											GRAY, SILTY FINE TO COARSE SAND (A-2-4) WITH TRACE WOOD FRAGMENTS	13.0
110																	
	108.8	18.5	9	10	12											COASTAL PLAIN TAN-BROWN AND GRAY, SILTY FINE TO COARSE SAND (A-2-4) (BLACK CREEK FORMATION)	18.0
105																	
	103.8	23.5	7	14	16												
100																	
	98.8	28.5	12	20	13												
95																	
	93.8	33.5	6	6	7												
90																	
	88.8	38.5	7	7	9												
85																	
	83.8	43.5	7	11	14												
80																	
	78.8	48.5	8	11	14												
75																	
	73.8	53.5	8	11	17												
70																	
	68.8	58.5	6	11	17												
65																	
	63.8	63.5	7	11	15												
60																	
	58.8	68.5	4	6	10												
55																	
	53.8	73.5	5	9	13												
50																	

WBS 46047.1.1		TIP B-5333		COUNTY ROBESON		GEOLOGIST C. WANG											
SITE DESCRIPTION BRIDGE NO. 173 OVER LUMBER RIVER AT STATION 21+66.08 -L-							GROUND WTR (ft)										
BORING NO. B4-B		STATION 22+32		OFFSET 7 ft RT		ALIGNMENT -L-											
COLLAR ELEV. 127.3 ft		TOTAL DEPTH 90.0 ft		NORTHING 317,678		EASTING 1,959,074											
DRILL RIG/HAMMER EFF./DATE F&R2175 CME-55 76% 02/25/2015			DRILL METHOD Mud Rotary			HAMMER TYPE Automatic											
DRILLER S. DAVIS		START DATE 09/29/15		COMP. DATE 09/29/15		SURFACE WATER DEPTH N/A											
ELEV (ft)	DRIVE ELEV (ft)	DEPTH (ft)	BLOW COUNT			BLOWS PER FOOT					SAMP. NO.	MOI	LOG	SOIL AND ROCK DESCRIPTION	DEPTH (ft)		
			0.5ft	0.5ft	0.5ft	0	25	50	75	100							
50																	
	48.8	78.5	14	22	25										49.3	GRAY, FINE TO COARSE SANDY CLAY (A-6)	78.0
45															44.3	GRAY, SILTY FINE TO COARSE SAND (A-2-4)	83.0
	43.8	83.5	10	22	24										39.3	BLACK-BROWN, SILTY CLAY (A-7-5)	88.0
40															37.3	Boring Terminated at Elevation 37.3 ft in CLAY (BLACK CREEK FORMATION)	90.0
	38.8	88.5	6	11	16												

NCDOT BORE DOUBLE B5333_GEO_BH_BRDG0173.GPJ NC_DOT_GDT 11/11/15



Bridge No. 173 over Lumber River at -L- Station 21+66.08 SITE PHOTOGRAPHS



Photograph No. 1: View from End Bent 1 looking northeast



Photograph No. 3: View under the bridge looking downstream



Photograph No. 2: View under the bridge looking northeast



Photograph No. 4: View under the bridge looking northeast