



NORTH CAROLINA D.O.T. PEDESTRIAN FERRY

Mechanical Calculations

Prepared for: NCDOT • Raleigh, NC

Ref: 16109-003-505-0

Rev. -

March 3, 2017

PREPARED BY

Elliott Bay Design Group – North Carolina, PLLC
5305 Shilshole Ave. NW, Ste. 100
Seattle, WA 98107

REVISIONS

REV	DESCRIPTION	DATE	APPROVED
-	Initial Issue	3/3/17	LGB 51201

CONFIDENTIAL AND PROPRIETARY PROPERTY OF
ELLIOTT BAY DESIGN GROUP – NORTH CAROLINA, PLLC
MAY NOT BE USED FOR CONSTRUCTION OR PROVIDED TO
ANY THIRD PARTIES WITHOUT PRIOR WRITTEN CONSENT.
© 2017 ELLIOTT BAY DESIGN GROUP - NORTH CAROLINA, PLLC.

TABLE OF CONTENTS

	PAGE
1 Purpose	1
2 Regulatory framework	1
Appendix A HVAC Block Diagram, Dwg. 16109-003-065-0	
Appendix B Fuel Oil Diagram, Dwg. 16109-003-261-1	
Appendix C Sea Chests and Seawater Cooling, Dwg. 16109-003-520-0	
Appendix D Fire Main System, Dwg. 16109-003-521-0	
Appendix E Sanitary Drains and Sewage Discharge System, Dwg. 16109-003-528-1	
Appendix F Bilge System, Dwg. 16109-003-529-1	
Appendix G Potable Water System, Dwg. 16109-003-533-0	

1 PURPOSE

This report documents the calculations used in support of piping and machinery system designs for the North Carolina D.O.T. Pedestrian Ferry. The subject vessel is a new design for a 92 ft long x 26 ft wide, catamaran type, fast passenger ferry, which will be owned and operated by the North Carolina Department of Transportation (NCDOT).

The calculations relating to each specific system are presented in separate appendices. Each appendix provides the following information:

- References used in preparing the calculations
- Description of the system
- Calculation procedures
- Given and assumed parameters
- Formulas and software used
- Calculation results

2 REGULATORY FRAMEWORK

The Pedestrian Ferry is inspected by the US Coast Guard under the provisions of 46 CFR Subchapter T. The vessel structure and bilge system are designed in accordance with Lloyd's Register Rules and Regulations for the Classification of Special Service Craft, 2016. Therefore, all piping and mechanical system design shall comply with the respective requirements of these agencies.

Appendix A

HVAC

1 DESCRIPTION

This appendix documents the calculations used in designing the machinery ventilation and passenger and crew space HVAC systems. These calculations establish minimum ventilation and cooling loads and identify appropriate duct sizes, trunk sizes, and fan and heat pump ratings.

2 PROCEDURE

Calculations are presented in the following sequence:

- Passenger Space cooling loads and exhaust fan sizing
- Pilothouse cooling load
- Engine Room ventilation and supply fan sizing
- Jet Room ventilation and exhaust fan sizing

3 GIVEN AND ASSUMED PARAMETERS

- The following environmental conditions were used to determine the HVAC loads:

Environmental Condition	
Cooling Outside Air Dry Bulb Temperature (F)	88
Cooling Outside Air Relative Humidity (%)	75
Cooling Sea Water Temperature (F)	85
Air Conditioned Spaces Temperature (F)	72
Air Conditioned Spaces Humidity (%)	55
Machinery Space Temperature (F)	115
Heating Outside Air Temperature	40
Heating Accommodations Indoor Air Temperature	68
Heating Machinery Space Indoor Air Temperature	50

- Passenger Space and Pilothouse will be served by mini-split heat pump units. Mini-split units will provide cooling and heating to each space.
- Machinery Spaces will not be supplied with any auxiliary heating.
- Compartment areas and volumes have been estimated based upon arrangements, [1].
- The outside air requirement for the Passenger Space was determined using ASHRAE 62.1 Ventilation for Acceptable Indoor Air Quality, [2].
- Passenger Space window glass solar factor (GSF) was modified for geographic location, and an assumed window film per ASHRAE fundamentals in accordance with the RLF method of Chapter 17.

- The Engine Rooms will be provided with mechanical supply and natural exhaust.
- The Jet Rooms will be provided with natural supply and mechanical exhaust.
- All other below deck spaces are provided with natural supply and exhaust.
- Engine Room ventilation is calculated assuming two propulsion engines, Caterpillar C18's rated for 800 HP at 2100 RPM and one generator, Northern Lights M40C3 rated for 40 kW. Heat rejection and air requirements at 100% MCR are tabulated below, [3] [4].

Engine Room Equipment Loads	
Propulsion Engine Heat Rejection (btu/min)	1815
Propulsion Engine Consumption Air (cfm)	1856
Generator Engine Cooling Air Required (cfm)	805
Generator Engine Consumption Air (cfm)	114

- Engine Room exhaust air is based upon supply air minus the consumption air of two engines running at 100% MCR.
- Engine Room supply fans have variable frequency drive motors that determine speed based upon a positively pressurized engine room.

4 FORMULAS

(not used)

5 CALCULATIONS

5.1 Passenger Space Cooling Loads and Exhaust Fan Sizing

Based upon the attached cooling load calculations, the estimated total cooling load for the Passenger Space is approximately 120,000 btu/hr or 10 tons of cooling. The passenger space will be served by four equally sized mini split heat units, each sized for 3.0 tons of cooling. This selection will provide margin and redundancy.

The Passenger Space will be served by an exhaust fan located in the overhead at the aft end of the accommodations. At minimum this fan shall exhaust approximately 600 cfm of air at an estimated static pressure of 1.3 inches H2O.

5.2 Pilothouse Cooling Load

Based upon the attached cooling load calculations, the estimated total cooling load for the Pilothouse is approximately 36,000 btu/hr or 3.0 tons of cooling. The Pilothouse will be served by two equally sized mini split heat units, each sized for 2 tons of cooling. This selection will provide margin and redundancy.

5.3 Engine Room Ventilation and Supply Fan Sizing

Based upon the attached calculations a ventilation rate of 10,400 cfm is required to provide cooling and combustion air to the Engine Rooms.

One fan, providing 10,400 cfm, will supply air the each Engine Room. The calculated static pressure is 0.7 inches H₂O.

5.4 Jet Room Ventilation and Exhaust Fan Sizing

Based upon the attached calculations a minimum ventilation rate of 157 cfm is required to provide 10 air changes per hour in the Jet Rooms.

One fan, providing 200 cfm, will supply air the each Jet Room. The calculated static pressure is 1.5 inches H₂O.

REFERENCES

[1] Elliott Bay Design Group, "Profiles and Arrangements," 16109-003-101 , Seattle, WA.

[2] ASHRAE, "Standard 62.1-2010 Ventilaton for Acceptable Indoor Air Quality," 2010.

[3] Caterpillar, "Performance Data [EM0270]," 11/10/2016.

[4] Mitsubishi, "ISM Toyota Mistubishi Marine Genset Specs," 2/2016.

Passenger Space		Deck Area: 940 ft ²		Volume: 7050 ft ³									
Space No:		Height: 7.5 ft											
Lighting Load Calculation													
Description	Area (ft ²)	LC, (Btu/hr/ft ²)	qs (btuh)		qt (btuh)								
Type of Lighting	940	7	6,580		6,580								
			Lighting Totals:	6,580	6,580								
Equipment Load Calculation													
Description	qs (btuh)	ql (btuh)	Qty	Use Factor	qs (btuh)	qi (btuh)	qt (btuh)						
Coffee Maker (commercial)	6,500	2,000	0	1									
Electric motor, (5 HP x 2545 / .87)	14,626		0	0.5									
					Equipment Totals:	0	0	0					
Personnel Load Calculation													
Description	Gender	Type	qs (btuh)	qi (btuh)	Count	qs (btuh)	qi (btuh)	qt (btuh)					
SEATED AT REST	male	1-P1	240	160	0								
SEATED AT REST	mixed	1-P2	210	140	100	21,000	14,000	35,000					
						Personnel Totals:	21000	14000	35000				
Ventilation Requirements													
Type	Description	Rate	Unit	Qty	OA (cfm)		EX (cfm)						
People Outdoor Air Rate	Public Assembly	5	cfm/person	100 people	500								
Area Outdoor Air Rate	Public Assembly	0.06	cfm/sq ft	940 ft ³	56								
					556								
				Heating Outside Air Temp	40 °F	Cooling Outside Air Temp		88 °F					
				Heating Inside Air Temp	68 °F	Cooling Design Temp:		72 °F					
Heating and Cooling Load Calculation													
Description	Load Key	Insul Type	Area (ft ²)	Heating				Cooling Season					
				T (°F)	ΔT	U or GSF	q _w (btuh)	T (°F)	ΔT	U or GSF	q _s (btuh)	q _i (btuh)	q _t (btuh)
Exterior - Weather (Solar)	Over	090-D1	812.0	40	28	0.238	5,411	123	51	0.274	11,347		11,347
Pilot House	Over	090-D4	175.0	68	0	0.219		72	0	0.243			
Void Space	Belw	090-U4	620.0	40	28	0.260	4,514	88	16	0.282	2,797		2,797
Exterior - Weather	Belw	090-U2	320.0	40	28	0.293	2,625	88	16	0.278	1,423		1,423
Exterior - Weather (Solar)	Fwd	090-H1	148.0	40	28	0.259	1,073	108	36	0.287	1,529		1,529
Exterior - Weather	Fwd	090-H2	148.0	40	28	0.259	1,073	88	16	0.260	616		616
Exterior - Windows (Shaded)	Fwd	001-H2	37.0	40	28	1.130	1,171	88	16	1.130	669		669
Exterior - Windows (Solar)	Fwd	001-H1	37.0	40	28	1.130	1,171	108	36	75	2,775		2,775
Exterior - Weather	Aft	090-H2	234.0	40	28	0.259	1,697	88	16	0.260	973		973
Exterior - Weather (Solar)	Port	090-H1	217.0	40	28	0.259	1,574	108	36	0.287	2,242		2,242
Exterior - Windows (Solar)	Port	001-H1	90.0	40	28	1.130	2,848	108	36	75	6,750		6,750
Exterior - Windows (Shaded)	Stbd	001-H2	90.0	40	28	1.130	2,848	88	16	1.130	1,627		1,627
Exterior - Weather	Stbd	090-H2	217.0	40	28	0.259	1,574	88	16	0.260	903		903
LIGHTS	Lght										6,580		6,580
EQUIPMENT	Eqpt												
PERSONNEL	Pers										21,000	14,000	35,000
Ventilation	OA							88	16		9,258	35,208	44,466
Space Totals:							27,578	Totals:		70,490	49,208	119,698	

Passenger Space Exhaust Fan Total Pressure Calculation

Input Variables

Supply Air Temperature (T_{IN}) = 88 °F
 Humidity Ratio = 0.0217 lb/lb dry air
 Air In Specific Volume (v_{IN}) = 14.29 ft³ / lb dry air
 Supply air specific weight = 0.070 lb/cu ft
 Supply air viscosity = 3.89E-07 lb-s/sq ft²
 Supply air density = 0.0022 slugs/cu ft

Max Temperature (T_{OUT}) = 90.0 °F
 Air out Specific Volume (v_{OUT}) = 14.34 ft³ / lb dry air
 Exhaust air specific weight = 0.070 lb/cu ft
 Exhaust air viscosity = 4.02E-07 lb-s/sq ft²
 Exhaust air density = 0.0022 slugs/cu ft

Description	height (in)	width (in)	h/w	equiv dia (in)	hyd diam (in)	area (sq ft)	length (ft)	qty	q (cfm)	v (ft/min)	Re	f	K	h _L (ft)
Supply Ducting														
Inlet Grill, 45 deg taper	6	6	-	-	6.00	0.20		1	200	1019	4.74E+04	0.024	0.100	0.45
Elbow, R/D = 1.5			-	-	6.00	0.20		1	200	1019	4.74E+04	0.024	0.330	1.48
Round Ducting			-	-	6.00	0.20	12	1	200	1019	4.74E+04	0.024	0.586	2.62
Tee, branch			-	-	4.00	0.09		1	100	1146	3.55E+04	0.027	0.500	2.83
Duct			-	-	4.00	0.09	8	1	100	1146	3.55E+04	0.027	0.638	3.61
Diffuser, L/D = 3	10	10			10.00	0.55		1	100	183	1.42E+04	0.030	0.200	0.03
Tee, branch					4.00	0.09		1	100	1146	3.55E+04	0.000	0.500	2.83
Round Ducting					4.00	0.09	4	1	100	1146	3.55E+04	0.027	0.319	1.81
Elbow					4.00	0.09		1	100	1146	3.55E+04	0.027	0.330	1.87
Diffuser, L/D = 3					10.00	0.55		1	100	183	1.42E+04	0.030	0.200	0.03
Segment total pressure														17.56

Description	height (in)	width (in)	h/w		hyd diam (in)	area (sq ft)	length (ft)	qty	q (cfm)	v (ft/min)	Re	f	K	h _L (ft)
Exhaust Vent														
Exhaust Grill, 45 deg Taper, 50% open	12.00	12.00	1.00	-	12.00	0.50		1	400	800	7.19E+04	0.021	0.100	0.28
Damper, D/Do = .9, 50 Deg					8.00	0.35		1	400	1146	6.87E+04	0.022	9.600	54.37
Ducting					8.00	0.35	12	1	400	1146	6.87E+04	0.022	0.404	2.29
Wye, Converging, 45 deg, main					6.00	0.20		1	500	2546	1.14E+05	0.022	0.130	3.64
Duct					6.00	0.20	8	1	500	2546	1.14E+05	0.022	0.352	9.84
Wye, Converging, 45 deg, main					6.00	0.20		1	600	3056	1.37E+05	0.022	0.130	5.24
Duct					6.00	0.20	4	1	600	3056	1.37E+05	0.022	0.173	6.97
Fan					6.00	0.20		1	600	3056	1.37E+05	0.022	0.000	0.00
Louver	10.00	10.00			10.00	0.52		1	600	1152	8.63E+04	0.021	3.600	20.61
Segment total pressure														103.23

	FT	in H2O
supply air total pressure	17.56	0.236
exhaust air total pressure	103.23	1.389
Total	120.79	1.626
15% design margin	138.90	1.869

Exhaust Fan Static Pressure	
Fan Dia (in)	6.00
Fan area (ft ²)	0.20
flowrate (cfm)	600
velocity (fpm)	3056
fan velocity pressure	0.5411
Static Pressure for fan selection (in H2O)	1.328

Pilothouse		Deck Area:	175 ft ²		Volume:	1225 ft ³									
Space No:		Height:	7 ft												
Lighting Load Calculation															
Description		Area (ft ²)	LC, (Btu/hr/ft ²)		qs (btuh)	qt (btuh)									
LED lighting		175	7		1,225	1,225									
					Lighting Totals:	1,225	1,225								
Equipment Load Calculation															
Description		qs (btuh)	ql (btuh)	Qty	Use Factor	qs (btuh)	qt (btuh)								
Misc Electronics, (5 HP x 2545 / .87)		14,626		1	0.5	7,313	7,313								
					Equipment Totals:	7313	7313								
Personnel Load Calculation															
Description		Gender	Type	qs (btuh)	qi (btuh)	Count	qt (btuh)								
SEATED AT REST		male	1-P1	240	160	3	720								
SEATED AT REST		mixed	1-P2	210	140	0	480								
					Personnel Totals:	720	1200								
Ventilation Requirements															
Type	Description		Rate	Unit	Qty	OA (cfm)	EX (cfm)								
By Occupancy	Low Occupancy		15	cfm/person	3 people	45									
Rate of Change	AC, Pilot House		1	ach	1225 ft ³	20									
Sanitary Fixtures			50	cfm/fixture	0 fixture										
						45									
				Heating Outside Air Temp	40 °F	Cooling Outside Air Temp	88 °F								
				Heating Inside Air Temp	68 °F	Cooling Design Temp:	72 °F								
Heating and Cooling Load Calculation															
Description		Load Key	Insul Type	Area (ft ²)	T (°F)	ΔT	U or GSF	q _w (btuh)	T (°F)	ΔT	U or GSF	q _s (btuh)	q _l (btuh)	q _t (btuh)	
Pilot House Top		Over	090-D1	150.0	40	28	0.238	1,000	123	51	0.274	2,096		2,096	
Passenger Space		Belw	090-U4	155.0	68	0	0.260		72	0	0.282				
Exterior - Weather (Solar)		Fwd	090-H1	104.0	40	28	0.259	754	108	36	0.287	1,075		1,075	
Exterior - Weather		Fwd	090-H2	0.0	40	28	0.259		88	16	0.260				
Exterior - Windows (Solar)		Fwd	001-H1	92.0	40	28	1.130	2,911	108	36	160	14,720		14,720	
Exterior - Windows (Shaded)		Aft	001-H2	24.0	40	28	1.130	759	88	16	1.130	434		434	
Exterior - Weather		Aft	090-H2	72.0	40	28	0.259	522	88	16	0.260	300		300	
Exterior - Weather (Solar)		Port	090-H1	28.0	40	28	0.259	203	108	36	0.287	289		289	
Exterior - Weather		Port	090-H2	28.0	40	28	0.259	203	88	16	0.260	116		116	
Exterior - Windows (Solar)		Port	001-H1	16.5	40	28	1.130	522	108	36	160	2,640		2,640	
Exterior - Windows (Shaded)		Port	001-H2	16.5	40	28	1.130	522	88	16	1.130	298		298	
Exterior - Windows (Shaded)		Stbd	001-H2	33.0	40	28	1.130	1,044	88	16	1.130	597		597	
Exterior - Weather		Stbd	090-H2	56.0	40	28	0.259	406	88	16	0.260	233		233	
LIGHTS		Lght										1,225		1,225	
EQUIPMENT		Eqpt										7,313		7,313	
PERSONNEL		Pers										720	480	1,200	
Ventilation		OA							88	16		749	2,848	3,596	
								Space Totals:			8,847	Totals:	32,805	3,328	36,132

Engine Room Ventilation

Approach

The minimum required airflow to the Engine Room is calculated based on i) airflow necessary to dissipate heat given off by running equipment, and ii) minimum airflow of 6 air change per hour into the space.

Equipment Loads

Main engines Heat Rejection, $q_e = 1,815.00 \text{ btu/min}$
 Main engines Consumption Air, $Q_e = 1,856.20 \text{ cfm}$
 Number of Engines Operating, $N_e = 2.00$

Generator Cooling Air, $V_g = 805.00 \text{ cfm}$
 Generator Consumption Air, $Q_g = 114.00 \text{ cfm}$
 Number of Engines Operating, $N_g = 1.00$

Inlet Air Conditions

Summer Air In Temperature (TIN) = $88.00 \text{ }^\circ\text{F}$
 Humidity Ratio = $0.022 \text{ lb/lb dry air}$
 Air In Enthalpy (hIN) = 45.03 Btu / lb
 Air In Specific Volume (rIN) = $14.29 \text{ ft}^3 / \text{lb dry air}$

Exhaust Air Conditions

Max Temperature (TOUT) = $115.00 \text{ }^\circ\text{F}$
 Air Out Enthalpy (hOUT) = 51.77 Btu / lb
 Air out Specific Volume (rOUT) = $14.99 \text{ ft}^3 / \text{lb dry air}$

Other Givens

Volume of Space (V) = $1,900 \text{ ft}^3$
 Minutes per air change (MA) = 10.00 min

Calculated Airflow based on Total Heat Loads

Total Heat Rejection (Qe) = 3630 Btu / min
 D Enthalpy (Dh) = 6.74 Btu / lb $Dh = h_{OUT} - h_{IN}$
 Required CFM (Heat Load) = 8500 cfm $CFM = (Q_e / Dh \times r_{IN}) + V_g$

Calculated Exhaust Airflow

cooling air (V) = $8,500 \text{ cfm}$ *(maximum of required airflows)*
 inlet air specific volume = $14.29 \text{ ft}^3/\text{lb}$
 exhaust air specific volume = $14.99 \text{ ft}^3/\text{lb}$
 expansion = 4.93%
 exhaust air = $8,919 \text{ cfm}$ $CFM = V / r_{IN} * r_{OUT}$

Results

cooling air = $8,500 \text{ cfm}$ *(maximum of required airflows)*
 consumption air = $3,826 \text{ cfm}$
 total intake air = $10,413 \text{ cfm}$ *(50% combustion air from cooling air)*
 total exhaust air = $6,701 \text{ cfm}$

Engine Room Total Pressure Calculation

Input Variables

Supply Air Temperature (T_{IN}) = 88 °F
 Humidity Ratio = 0.0217 lb/lb dry air
 Air In Specific Volume (v_{IN}) = 14.29 ft³ / lb dry air
 Supply air specific weight = 0.070 lb/cu ft
 Supply air viscosity = 3.89E-07 lb-s/sq ft²
 Supply air density = 0.0022 slugs/cu ft

Max Temperature (T_{OUT}) = 115.0 °F
 Air out Specific Volume (v_{OUT}) = 14.99 ft³ / lb dry air
 Exhaust air specific weight = 0.067 lb/cu ft
 Exhaust air viscosity = 4.02E-07 lb-s/sq ft²
 Exhaust air density = 0.0021 slugs/cu ft

Supply air flow rate = 10400 cfm
 Exhaust air flow rate = 6600 ft/min

Description	height (in)	width (in)	h/w	equiv dia (in)	hyd diam (in)	area (sq ft)	length (ft)	qty	q (cfm)	v (ft/min)	Re	f	K	h _L (ft)
Supply Ducting														
Inlet Demister	40	30	1.33	36.75	34.29	8.33		1	10400	1248	3.32E+05	0.016	5.500	36.95
Round Fabricated Fire Damper			-	-	30.00	4.91		1	10400	2119	4.93E+05	0.015	0.100	1.94
Fan			-	-	24.00	3.14		1	10400	3310	6.16E+05	0.016	0.000	0.00
Flexible Duct / Round Duct			-	-	32.00	5.59	0.50	1	10400	1862	4.62E+05	0.015	0.003	0.04
Discharge Aft to Gen, R/D = 1.5, 45 deg			-	-	32.00	5.59		1	10400	1862	4.62E+05	0.015	1.200	17.95
Screen (wire mesh)			-	-	32.00	5.59		1	10400	1862	4.62E+05	0.015	0.500	7.48
Segment total pressure														64.35

Description	height (in)	width (in)	h/w		hyd diam (in)	area (sq ft)	length (ft)	qty	q (cfm)	v (ft/min)	Re	f	K	h _L (ft)
Exhaust Vent														
Damper	27.00	20.00	1.35		22.98	3.75		1	6600	1760	2.90E+05	0.017	0.370	4.94
Inlet	27.00	20.00	1.35		22.98	3.75		1	6600	1760	2.90E+05	0.017	0.500	6.68
Rectangular ducting	40.00	28.00	1.43	-	32.94	7.78	10	1	6600	849	2.00E+05	0.017	0.062	0.19
Exhaust Louver with insect screen	42	42	1.00	-	42.00	9.19		1	6600	718	2.16E+05	0.016	3.800	8.01
Segment total pressure														19.83

	FT	in H2O
supply air total pressure	64.35	0.866
exhaust air total pressure	19.83	0.267
Total	84.18	1.133
15% design margin	96.81	1.303

Supply Fan Static Pressure		
Fan Dia (in)		24.00
Fan area (ft ²)		3.14
flowrate (cfm)		10400
velocity (fpm)		3310
fan velocity pressure		0.6074
Static Pressure for fan selection (in H2O)		0.696

Jet Room Ventilation

Approach

The minimum required airflow to the Jet Room is calculated based on minimum airflow of 10 air change per hour.

Inlet Air Conditions

Summer Air In Temperature (TIN) =	88.00	°F
Humidity Ratio	0.022	lb/lb dry air
Air In Enthalpy (hIN) =	45.03	Btu / lb
Air In Specific Volume (rIN) =	14.29	ft ³ / lb dry air

Exhaust Air Conditions

Max Temperature (TOUT) =	90.00	°F
Air Out Enthalpy (hOUT) =	45.53	Btu / lb
Air out Specific Volume (rOUT) =	14.34	ft ³ / lb dry air

Other Givens

Volume of Space (V) =	940	ft ³
Minutes per air change (MA) =	6.00	min 10 ACH

Calculated Airflow based on minimum air exchanges :

Volume of Space (V) =	940	ft ³
Air exchanges / min (AC)=	6	min/AC
Required CFM(Air Exchange) =	157	cfm CFM = V/MA

Jet Room Total Pressure Calculation

Input Variables

Supply Air Temperature (T_{IN}) = 88 °F
 Humidity Ratio = 0.0217 lb/lb dry air
 Air In Specific Volume (v_{IN}) = 14.29 ft³ / lb dry air
 Supply air specific weight = 0.070 lb/cu ft
 Supply air viscosity = 3.89E-07 lb-s/sq ft²
 Supply air density = 0.0022 slugs/cu ft

Max Temperature (T_{OUT}) = 90.0 °F
 Air out Specific Volume (v_{OUT}) = 14.34 ft³ / lb dry air
 Exhaust air specific weight = 0.070 lb/cu ft
 Exhaust air viscosity = 4.02E-07 lb-s/sq ft²
 Exhaust air density = 0.0022 slugs/cu ft

Supply air flow rate = 200 cfm
 Exhaust air flow rate = 200 ft/min

Description	height (in)	width (in)	h/w	equiv dia (in)	hyd diam (in)	area (sq ft)	length (ft)	qty	q (cfm)	v (ft/min)	Re	f	K	h _L (ft)
Exhaust Ducting														
Gooseneck inlet with screen			-	-	4.03	0.09		1	200	2258	7.05E+04	0.024	1.400	30.78
4" Sch 40 pipe			-	-	4.03	0.09	5	1	200	2258	7.05E+04	0.024	0.364	8.01
Fan			-	-	4.00	0.09		1	200	2292	7.11E+04	0.024	0.000	0.00
Sudden Expansion, fan outlet			-	-	4.03	0.09		1	200	2258	7.05E+04	0.024	0.510	11.21
Screen			-	-	4.03	0.09		1	200	2258	7.05E+04	0.024	0.240	5.28
Segment total pressure														55.29

Description	height (in)	width (in)	h/w	equiv dia (in)	hyd diam (in)	area (sq ft)	length (ft)	qty	q (cfm)	v (ft/min)	Re	f	K	h _L (ft)
Supply Vent														
Inlet - Projecting			-	-	4.03	0.09		1	200	2258	6.82E+04	0.025	0.550	12.09
4" Sch 40 pipe			-	-	4.03	0.09	5	1	200	2258	6.82E+04	0.025	0.366	8.04
Gooseneck outlet with screen			-	-	4.03	0.09		1	200	2258	6.82E+04	0.025	2.000	43.98
Segment total pressure														64.11

	FT	in H2O
exhaust air total pressure	55.29	0.744
supply air total pressure	64.11	0.863
Total	119.40	1.607
15% design margin	137.31	1.848

Supply Fan Static Pressure	
Fan Dia (in)	4.00
Fan area (ft ²)	0.09
flowrate (cfm)	200
velocity (fpm)	2292
fan velocity pressure	0.3043
Static Pressure for fan selection (in H2O)	1.544

Appendix B

Fuel Oil System

1 DESCRIPTION

This appendix documents the first principles calculations used in designing the fuel oil system. These calculations are used to identify steady state frictional losses throughout the piping system and to validate system design.

2 PROCEDURE

Calculations are presented in the following sequence:

- Pipe size calculations
- Engine fuel pump suction pressure calculations

Frictional losses through the piping system are calculated by constructing a model using PIPE-FLO Professional software with the Darcy Weisbach method applied.

3 GIVEN AND ASSUMED PARAMETERS

- Maximum fuel flow rate to each main engine is 3.53 gpm, from [1].
- Maximum fuel flow rate to each generator is 0.16 gpm, from [2].
- Piping system lengths, routing, fittings, etc. are estimated based on the Profiles and Arrangements, and Fuel Oil Diagram [3] [4].
- Listed main engine fuel system design constraints [1]:

Table 1: Main Engine Fuel System Design Constraints

Engine	Maximum
Allowable supply line restriction to main engine	4.37 psi
Allowable return line restriction to main engine	3.93 psi

- Pressure drop across the Racor 791000MAVM triplex fuel filter for a flowrate of 3.53 gpm is 1 psi, from [5].
- Pressure drop across the Racor 1000MAM fuel filter is for a flowrate of .016 gpm is 0.03 psi, from [6].
- Tank and engine elevations were estimated from [3], all elevations are in reference to the vessel's baseline:

Table2: Elevations

Elevation Point	Elevation
Fuel tank low fuel level	3.5 feet
Fuel tank high fuel level	7.5 feet
Main Engine fuel inlet	4 feet
Main Engine fuel outlet	5.8 feet
Generator fuel inlet	4.25 feet
Generator fuel outlet	4.8 feet

4 FORMULAS

(not used)

5 CALCULATIONS

5.1 Pipe Size Calculations

Pipe sizes are based on the nominal velocity limits found in Marine Engineering, Chapter 20, Table 3, [7]. The following table shows the flow rates of fuel occurring in the system, and the resulting pipe/tube sizes.

Table 3: Fuel Oil System Pipe Sizes and Velocities

Pipe Segment	Flow Rate gpm	Pipe/Tube Size (NPS/0.065 Wall)	ID in	Design Velocity (ft/s)		V ft/s
				Nominal	Limit	
Fill Rate	50	2" Sch 80	1.940	6.96	12.00	5.29
Supply Main (2 me, 1 gen)	7.22	1.5" Tube	1.370	2.34	7.00	1.53
Return main (2 me, 1 gen)	7.22	1.5" Tube	1.370	5.85	12.00	1.53
Main Engine - Supply	3.53	1" Tube	0.870	1.87	7.00	1.86
Generator - Supply	0.16	0.5" Tube	0.370	1.22	7.00	0.46
Main Engine - Return	3.53	1" Tube	0.870	4.66	12.00	1.86
Generator - Return	0.16	0.5" Tube	0.370	3.04	12.00	0.46

5.2 Engine Fuel Suction Pressure Calculations

The main engines are supplied with fuel pumps used to draw fuel from fuel tanks. The attached system model confirms that the piping systems are compatible with the engines' fuel supply allowable line restriction requirements. As listed above, the maximum fuel line restriction is 4.37 psi. The attached model shows the calculated pressure loss to be 1.95 psi.

Due to the very low fuel flow rate of the generators compared to the fuel filter and tubing size, the calculated pressure loss for the generator fuel suction is 0.85 psi.


5.3 Engine Fuel Return Pressure Calculations

The attached model of the fuel system's return piping confirms that the backpressure at the main engines does not exceed the listed maximum value of 3.93psi. The return line restriction at the main engines was found to be 1.35 psi.

The generators fuel return line restriction was found to be 1.5 psi as shown in the attached model.

6 REFERENCES

- [1] Caterpillar, "C18 Systems Data," EM0270, 12/19/2016.
- [2] Northern Lights, "ISM Toyota Mitsubishi Marine Genset Specs; Model M944T3," Feb 2016.
- [3] Elliott Bay Design Group, "NCDOT Pedestrian Ferry: Profiles and Arrangements," 16109-003-101-1, Seattle, WA.
- [4] Elliott Bay Design Group, "NCDOT Pedestrian Ferry: Fuel Oil Diagram," 16109-003-261-1, Seattle, WA.
- [5] Parker Racor, "Racor Products Catalog: Marine Fuel Filtration Products: 79/1000MAV".
- [6] Parker Racor, "Racor Products Catalog: Marine Fuel Filtration Products: 1000MA".
- [7] R. L. Harrington, Marine Engineering, Jersey City, NJ: SNAME, 1992.



PIPE-FLO Professional	Units Used	Project Information
Program Version: 15.2.37316 Calculation Method: Darcy-Weisbach Maximum Iterations: 100 Iteration Tolerance: 0.01 Laminar Cutoff Re: 2100	Flow rate: gpm Velocity: f/s Pressure: psi g Elevation: ft Length: ft Size: in Power: °F Temperature: °F Density: lb/ft ³ Viscosity: cP Atmospheric Pressure: 14.7 psi a	Company: EBDG Project: 16109 Drawn by: JHP File Name: Fuel Supply.ppt Lineup: <Design Case> Print Date: Wednesday, February 08, 2017 09:14 AM

List Report

File Name: Fuel Supply.pipe
 Lineup: -Design Case-
 Program Name: PIPE-FLO Professional
 Version: 15.2.37316

Calculation Method: Darcy-Weisbach
 Lammar Cutoff Re.: 2100
 Max Iterations: 100
 Iteration Tolerance: 0.01
 Atmospheric Pressure: 14.7 psi a

Company: EBDG
 Project: 16109
 by: JHP
 Date: Wednesday, February 08, 2017 09:14 AM

Pipe Specifications									
Specification Name	Material Schedule	Absolute Roughness Hazen Williams C Factor	Sizing Criteria	Velocity	Design Limits Pressure	Reynolds Number			
ASTM-A-269 .120 Wall standard	SS/steel ASTM-A-269 Schedule:12	6E-05 in	0.0	to f/s	to psi g	to			
ASTM-A-269 .049 Wall standard	SS/steel ASTM-A-269 Schedule:049	6E-05 in	0.0	to f/s	to psi g	to			
ASTM-A-269 .083 Wall standard	SS/steel ASTM-A-269 Schedule:083	6E-05 in	0.0	to f/s	to psi g	to			
ASTM-A-269 0.065 Wall standard	SS/steel ASTM-A-269 Schedule:065	6E-05 in	0.0	to f/s	to psi g	to			
Fluid Zones									
Fluid Zone Name	Temperature	Pressure	Fluid State	Density Viscosity	Vapor Pressure Critical Pressure	Specific Heat Ratio (k)			
Fuel 3	50 °F	0 psi g	Liquid	56.38 lb/ft ³ 10.19 cP	0.2171 psi a 3199 psi a	--			
Fuel 3 Max						1			
Pipelines									
Pipeline Name	Size Inside Diameter Length	Inlet Elevation	Flow Rate Fluid Velocity Reynolds Number	Total Head Loss V&F Head Loss	Inlet Pressure Outlet Pressure	Total dp V&F dp	Pipe Friction Factor V&F Friction Factor		
Pipe 1	1.5 in	2.5 ft	7.22 gpm 1.571 f/s 1477	0.4875 ft 0.1233 ft	0.3915 psi g -0.1909 psi g	0.5624 psi 0.04829 psi	0.04333 0.02101	3.21	
ASTM-A-269 0.065 Wall Fuel 3	1.37 in 25 ft	3.5 ft							
	Inlet Device: FO Tank		Outlet Device: Node 1						
Pipe 3	1.5 in	3.5 ft	7.06 gpm 1.537 f/s 1444	0.2426 ft 0.1002 ft	-0.1909 psi g -0.2859 psi g	0.095 psi 0.09923 psi	0.04432 0.02101	2.73	
ASTM-A-269 0.065 Wall Fuel 3	1.37 in 10 ft	3.5 ft							
	Inlet Device: Node 1		Outlet Device: Node 2						
Pipe 5	1 in	3.5 ft	3.53 gpm 1.905 f/s 1137	0.9443 ft 0.2874 ft	-0.2859 psi g -0.6556 psi g	0.3697 psi 0.1125 psi	0.05629 0.02363	5.10	
ASTM-A-269 0.065 Wall Fuel 3	0.87 in 15 ft	3.5 ft							
	Inlet Device: Node 2		Outlet Device: Racor 79/1000						
Pipe 6	1 in	3.5 ft	3.53 gpm 1.905 f/s 1137	0.3256 ft 0.1066 ft	-1.636 psi g -1.959 psi g	0.3232 psi 0.04175 psi	0.05629 0.02363	1.89	
ASTM-A-269 0.065 Wall Fuel 3	0.87 in 5 ft	4 ft							
	Inlet Device: Racor 79/1000		Outlet Device: ME At						
Pipe 4	1 in	3.5 ft	3.53 gpm 1.905 f/s 1137	0.6587 ft 0.2208 ft	-0.2859 psi g -0.5437 psi g	0.2579 psi 0.08644 psi	0.05629 0.02363	3.91	
ASTM-A-269 0.065 Wall Fuel 3	0.87 in 10 ft	3.5 ft							
	Inlet Device: Node 2		Outlet Device: Racor 79/1000 1						

Pipelines											
Pipeline Name Specification Fluid Zone	Size Inside Diameter Length	Inlet Elevation Outlet Elevation	Flow Rate Fluid Velocity Reynolds Number	Total Head Loss V&F Head Loss	Inlet Pressure Outlet Pressure	Total dP V&F dP	Pipe Friction Factor V&F Friction Factor V&F Resistance K				
Pipe 7 ASTM-A-269 0.065 Wall Fuel 3	1 in 0.87 in 5 ft	3.5 ft 4 ft	3.53 gpm 1.905 ft/s 1137	0.3256 ft 0.1066 ft	-1.524 psi g -1.848 psi g	0.3232 psi 0.04175 psi	0.05629 0.02363 1.89				
Inlet Device: Racor 79/1000 1 Outlet Device: ME FWD											
Pipe 2 ASTM-A-269 0.065 Wall Fuel 3	0.5 in 0.37 in 10 ft	3.5 ft 3.5 ft	0.16 gpm 0.4774 ft/s 121.2	0.6215 ft 0.011476 ft	-0.1909 psi g -0.4342 psi g	0.2433 psi 5.780E-03 psi	0.5281 0.03012 4.17				
Inlet Device: Note 1 Outlet Device: Racor 1000											
Pipe 8 ASTM-A-269 0.065 Wall Fuel 3	0.5 in 0.37 in 3 ft	3.5 ft 4.25 ft	0.16 gpm 0.4774 ft/s 121.2	0.1906 ft 8.535E-03 ft	-0.4608 psi g -0.8291 psi g	0.3682 psi 3.341E-03 psi	0.5281 0.03012 2.41				
Inlet Device: Racor 1000 Outlet Device: Genset											
Tanks											
Tank Name Fluid Zone	Bottom Elevation Liquid Level	Surface Pressure Bottom Pressure	Hydraulic Grade	Pipeline Name	Penetration Height	Pipeline Flow Rate	Pressure at Penetration				
FO Tank Fuel 3	2.5 ft 1 ft	0 psi g 0.3915 psi g	3.5 ft	Pipe 1	0 ft	7.22 gpm	0.3915 psi g				
Curve dP Devices											
Curve dP Device Name Description	Inlet Elevation Inlet Pressure	Outlet Elevation Outlet Pressure	dP Head Loss	Flow Rate							
Racor 79/1000 Racor 79/1000	3.5 ft -0.6556 psi g	3.5 ft -1.636 psi g	0.9806 psi 2.504 ft	3.53 gpm							
Racor 1000 Racor 1000	3.5 ft -0.4342 psi g	3.5 ft -0.4608 psi g	0.02667 psi 0.06811 ft	0.16 gpm							
Racor 79/1000 1 Racor 79/1000	3.5 ft -0.5437 psi g	3.5 ft -1.524 psi g	0.9806 psi 2.504 ft	3.53 gpm							
Nodes											
Node Name	Elevation	Pressure	Hydraulic Grade								
Node 1	3.5 ft	-0.1909 psi g	2.986 ft								
Node 2	3.5 ft	-0.2859 psi g	2.72 ft								
Flow Demands											
Flow Demand Name	Elevation	Pressure	Hydraulic Grade	Flow Rate	Flow Direction						
ME ART	4 ft	-1.959 psi g	-1.061 ft		Flow out						
ME FWD	4 ft	-1.848 psi g	-0.7753 ft		Flow out						
Genset	4.25 ft	-0.8291 psi g	2.129 ft		Flow out						


Bill of Materials Report

File Name: Fuel Supply.pipe
Lineup: <Design Case>
Program Name: PIPE-FLO Professional
Version: 15.2.37316

Company: EBDG
Project: 16109
by: JHP
Date: Wednesday, February 08, 2017 09:15 AM

Pipelines				
Pipeline	Specification	Size	Length	Valves and Fittings
Pipe 1	ASTM-A-269 0.065 Wall	1.5 in	25 ft	3 x Elbow - Standard 90° 3 x Pipe Bend - r/d 1 (90°) 1 x Ball
Pipe 3	ASTM-A-269 0.065 Wall	1.5 in	10 ft	2 x Pipe Bend - r/d 1 (90°) 3 x Elbow - Standard 90°
Pipe 5	ASTM-A-269 0.065 Wall	1 in	15 ft	1 x Ball 4 x Pipe Bend - r/d 1 (90°) 4 x Elbow - Standard 90° 1 x Reducer - Contraction (1 in x 1.5 in -
Pipe 6	ASTM-A-269 0.065 Wall	1 in	5 ft	4 x Pipe Bend - r/d 1 (90°)
Pipe 4	ASTM-A-269 0.065 Wall	1 in	10 ft	3 x Pipe Bend - r/d 1 (90°) 3 x Elbow - Standard 90° 1 x Ball 1 x Reducer - Contraction (1 in x 1.5 in -
Pipe 7	ASTM-A-269 0.065 Wall	1 in	5 ft	4 x Pipe Bend - r/d 1 (90°)
Pipe 2	ASTM-A-269 0.065 Wall	0.5 in	10 ft	3 x Pipe Bend - r/d 1 (90°) 2 x Elbow - Standard 90° 1 x Reducer - Contraction (0.5 in x 1.5 in 1 x Ball
Pipe 8	ASTM-A-269 0.065 Wall	0.5 in	3 ft	4 x Pipe Bend - r/d 1 (90°)

Pipeline Material Summary				
Specification	Material	Size	Total Length	Valves & Fittings
ASTM-A-269 0.065 Wall	SSteel ASTM-A-269 Schedule: .065	0.5 in	13.00 ft	1 x Ball 2 x Elbow - Standard 90° 7 x Pipe Bend - r/d 1 (90°) 1 x Reducer - Contraction (0.5 in x 1.5 in - 0 in)
ASTM-A-269 0.065 Wall	SSteel ASTM-A-269 Schedule: .065	1 in	35.00 ft	2 x Ball 7 x Elbow - Standard 90° 15 x Pipe Bend - r/d 1 (90°) 2 x Reducer - Contraction (1 in x 1.5 in - 0 in)
ASTM-A-269 0.065 Wall	SSteel ASTM-A-269 Schedule: .065	1.5 in	35.00 ft	1 x Ball 6 x Elbow - Standard 90° 5 x Pipe Bend - r/d 1 (90°)



Project Information

Company: EBDG
 Project: 16109
 Drawn by: JHP
 File Name: Fuel Return.pipe
 Lineup: <Design Case>
 Print Date: Wednesday, February 08, 2017 09:15 AM

Units Used

Flow rate: gpm
 Velocity: ft/s
 Pressure: psi g
 Elevation: ft
 Length: ft
 Size: in
 Power: Power
 Temperature: °F
 Density: lb/ft³
 Viscosity: cP
 Atmospheric Pressure: 14.7 psi a

PIPE-FLO Professional

Program Version: 15.2.37316
 Calculation Method: Darcy-Weisbach
 Maximum Iterations: 100
 Iteration Tolerance: 0.01
 Laminar Cutoff Re: 2100

List Report

File Name: Fuel Return.pipe
 Lineup: <Design Case>
 Program Name: PIPE-FLO Professional
 Version: 15.2.37316

Calculation Method: Darcy-Weisbach
 Laminar Cutoff Re: 2100
 Max Iterations: 100
 Iteration Tolerance: 0.01
 Atmospheric Pressure: 14.7 psi a

Company: EBDG
 Project: 16109
 by: JHP
 Date: Wednesday, February 08, 2017 09:16 AM

Specification Name Valve Table	Material Schedule	Pipe Specifications		Sizing Criteria		Design Limits		Reynolds Number
		Absolute Roughness Hazen Williams C Factor	Velocity	Pressure	Velocity	Pressure	Reynolds Number	
ASTM-A-269 .120 Wall standard	SSSteel ASTM-A-269 Schedule:12	6E-05 in 100	0.0	to	to	psi g	to	to
ASTM-A-269 .049 Wall standard	SSSteel ASTM-A-269 Schedule:049	6E-05 in 100	0.0	to	to	psi g	to	to
ASTM-A-269 .083 Wall standard	SSSteel ASTM-A-269 Schedule:083	6E-05 in 100	0.0	to	to	psi g	to	to
ASTM-A-269 0.065 Wall standard	SSSteel ASTM-A-269 Schedule:065	6E-05 in 100	0.0	to	to	psi g	to	to

Fluid Zones

Fluid Zone Name Table Name	Temperature	Fluid State	Density Viscosity	Vapor Pressure Critical Pressure	Specific Heat Ratio (k)
Fuel 3 Fuel 3 Max	50 °F	Liquid	56.38 lb/ft ³ 10.19 cP	0.2171 psi a 3199 psi a	-- 1

Pipelines

Pipeline Name Specification Fluid Zone	Size Inside Diameter Length	Inlet Elevation Outlet Elevation	Flow Rate Fluid Velocity Reynolds Number	Total Head Loss V&F Head Loss	Inlet Pressure Outlet Pressure	Total dP V&F dP	Pipe Friction Factor V&F Friction Factor V&F Resistance K
Pipe 1 ASTM-A-269 0.065 Wall Fuel 3	1.5 in 1.37 in 25 ft	3.5 ft 2.5 ft	7.22 gpm 1.571 ft/s 1477	0.4875 ft 0.1233 ft	1.757 psi g 1.958 psi g	-0.2007 psi 0.04829 psi	0.04333 0.02101 3.21
Inlet Device: Node 1							
Pipe 2 ASTM-A-269 0.065 Wall Fuel 3	0.5 in 0.37 in 10 ft	4.8 ft 3.5 ft	0.16 gpm 0.4774 ft/s 121.2	0.6318 ft 0.02511 ft	1.495 psi g 1.757 psi g	-0.2616 psi 9.832E-03 psi	0.5281 0.03012 7.09
Inlet Device: Genset							
Pipe 4 ASTM-A-269 0.065 Wall Fuel 3	1 in 0.87 in 10 ft	5.8 ft 3.5 ft	3.53 gpm 1.905 ft/s 1137	0.788 ft 0.3501 ft	1.26 psi g 1.852 psi g	-0.592 psi 0.1371 psi	0.05629 0.02363 6.21
Inlet Device: ME FWD							
Pipe 5 ASTM-A-269 0.065 Wall Fuel 3	1 in 0.87 in 15 ft	5.8 ft 3.5 ft	3.53 gpm 1.905 ft/s 1137	1.074 ft 0.4167 ft	1.372 psi g 1.852 psi g	-0.4802 psi 0.1632 psi	0.05629 0.02363 7.39
Inlet Device: ME Aft							
Pipe 3 ASTM-A-269 0.065 Wall Fuel 3	1.5 in 1.37 in 10 ft	3.5 ft 3.5 ft	7.06 gpm 1.537 ft/s 1444	0.2426 ft 0.1002 ft	1.852 psi g 1.757 psi g	0.095 psi 0.03923 psi	0.04432 0.02101 2.73
Inlet Device: Node 2							

Tanks										
Tank Name	Bottom Elevation	Surface Pressure	Hydraulic Grade	Pipeline Name	Penetration Height	Connecting Pipelines	Pipeline Flow Rate	Pressure at Penetration		
Fluid Zone	Liquid Level	Bottom Pressure								
FO Tank	2.5 ft	0 psi g	7.5 ft	Pipe 1	0 ft		7.22 gpm	1,958 psi g		
Fuel3	5 ft	1,958 psi g								
Nodes										
Node Name	Elevation	Pressure	Hydraulic Grade							
Node 1	3.5 ft	1,757 psi g	7,961 ft							
Node 2	3.5 ft	1,852 psi g	8.18 ft							
Flow Demands										
Flow Demand Name	Elevation	Pressure	Hydraulic Grade	Flow Rate	Flow Direction					
ME Alt	5.8 ft	1,372 psi g	9,247 ft		Flow in					
ME FWD	5.8 ft	1,206 psi g	8,962 ft		Flow in					
Genset	4.8 ft	1,495 psi g	8,616 ft		Flow in					

Bill of Materials Report

File Name: Fuel Return.pipe
Lineup: <Design Case>
Program Name: PIPE-FLO Professional
Version: 15.2.37316

Company: EBDG
Project: 16109
by: JHP
Date: Wednesday, February 08, 2017 09:16 AM

Pipelines				
Pipeline	Specification	Size	Length	Valves and Fittings
Pipe 1	ASTM-A-269 0.065 Wall	1.5 in	25 ft	3 x Elbow - Standard 90° 3 x Pipe Bend - r/d 1 (90°) 1 x Ball
Pipe 2	ASTM-A-269 0.065 Wall	0.5 in	10 ft	3 x Pipe Bend - r/d 1 (90°) 2 x Elbow - Standard 90° 1 x Reducer - Contraction (0.5 in x 1.5 in) 1 x Swing Check - Angled
Pipe 4	ASTM-A-269 0.065 Wall	1 in	10 ft	3 x Pipe Bend - r/d 1 (90°) 3 x Elbow - Standard 90° 1 x Reducer - Contraction (1 in x 1.5 in - 1 x Swing Check - Angled
Pipe 5	ASTM-A-269 0.065 Wall	1 in	15 ft	4 x Pipe Bend - r/d 1 (90°) 4 x Elbow - Standard 90° 1 x Reducer - Contraction (1 in x 1.5 in - 1 x Swing Check - Angled
Pipe 3	ASTM-A-269 0.065 Wall	1.5 in	10 ft	2 x Pipe Bend - r/d 1 (90°) 3 x Elbow - Standard 90°

Pipeline Material Summary				
Specification	Material	Size	Total Length	Valves & Fittings
ASTM-A-269 0.065 Wall	SSteel ASTM-A-269 Schedule: .065	0.5 in	10.00 ft	2 x Elbow - Standard 90° 3 x Pipe Bend - r/d 1 (90°) 1 x Reducer - Contraction (0.5 in x 1.5 in - 0 in) 1 x Swing Check - Angled
ASTM-A-269 0.065 Wall	SSteel ASTM-A-269 Schedule: .065	1 in	25.00 ft	7 x Elbow - Standard 90° 7 x Pipe Bend - r/d 1 (90°) 2 x Reducer - Contraction (1 in x 1.5 in - 0 in) 2 x Swing Check - Angled
ASTM-A-269 0.065 Wall	SSteel ASTM-A-269 Schedule: .065	1.5 in	35.00 ft	1 x Ball 6 x Elbow - Standard 90° 5 x Pipe Bend - r/d 1 (90°)

Appendix C

Sea Chests and Seawater Cooling

1 DESCRIPTION

This appendix documents the calculations used in designing the seawater cooling system. These calculations establish minimum sea chest area and seawater suction pipe sizes. Estimated losses through the system piping are not calculated as the system heat exchangers are supplied by the engine manufacturers and all cooling lines discharge into wet exhaust systems designed and provided by others.

2 PROCEDURE

Calculations are presented in the following sequence:

- Seawater pipe nominal velocity calculation
- Sea chest cross sectional area

Initial pipe sizes are based on the nominal velocity limits found in [1], Chapter 20, Table 3.

3 GIVEN AND ASSUMED PARAMETERS

- Seawater system is to be constructed of sch 40 aluminum pipe.
- System pipe lengths, routing and fittings are estimated based on the Profiles and Arrangements, [2].
- Total area of pipes connected to an individual sea chest is 7.393 square inches based upon one 3 inch sch 40 suction pipe.

4 FORMULAS

(not used)

5 CALCULATIONS

5.1 Pipe Nominal Velocity Calculation

Pipe sizes are based on the nominal velocity limits found in [1]. Table 1 shows the flows occurring in all branches of the system, and the resulting pipe sizes:

Table 1: Nominal Pipe Velocities

Pipe Segment	Flow Rate gpm	Pipe Size (NPS)	ID in	Design Velocity (ft/s)		V ft/s
				Nominal	Limit	
Main Engine	100	3" Sch 40	3.068	5.25	15.00	4.23
Generator	11.3	1" Sch 40	1.049	3.07	15.00	4.09
Fire Pump	50	2" Sch 40	2.067	4.31	15.00	4.66
Main Engine & Generator	111.3	3" Sch 40	3.068	5.25	15.00	4.70
Jet Oil Cooler	4	1" Hose	1.000	5.00	15.00	1.59

5.2 Sea Chest Cross Sectional Area

From the calculations below, the minimum cross sectional area for the sea chest is 51.6 square inches.

<u>INPUTS</u>	
Units Used: US	
$A_p =$	7.39 in ² Total area of pipes taking suction from sea chest
$\%_{fa} =$	50% Strainer percent free (clear) area
$R_{min} =$	1.5 ABS Required strainer clear area to suction area
$R =$	3 Chosen clear area ratio, not less than R_{min} .

<u>CALCULATION OF SEA CHEST CROSS SECTIONAL AREA</u>	
$A_{sc} = A_p * R / \%_{fa}$	Sea chest cross sectional area
$A_{sc} =$ 44.36 in²	Sea chest cross sectional area

REFERENCES

- [1] R. L. Harrington, Marine Engineering, Jersey City, NJ: SNAME, 1992.
- [2] Elliott Bay Design Group, "Profiles and Arrangements," 16109-003-101 , Seattle, WA.

Appendix D

Fire Main

1 DESCRIPTION

This appendix documents the calculations used in designing the fire main system. These calculations establish required pump capacity and quantity in accordance with regulatory requirements. Estimated losses through the system piping are calculated to establish the total dynamic head (TDH) of the fire pump.

2 PROCEDURE

Calculations are presented in the following sequence:

- Fire main pipe nominal velocity calculation
- Fire pump total dynamic head (TDH)

Minimum fire pump capacity is based upon the requirements found in [1].

Initial pipe sizes are based on the nominal velocity limits found in [2], Chapter 20, Table 3.

Frictional losses through the piping system are calculated by constructing a model using PIPE-FLO Professional software.

3 GIVEN AND ASSUMED PARAMETERS

- Fire main system is to be constructed of sch 40 aluminum piping.
- System pipe lengths, routing and fittings are estimated based on the Profiles and Arrangements, [3].
- In accordance with [1], the fire pump is required to produce 50 gpm with a 60 psig discharge pressure at the outlet of the pump.
- System will be equipped with 1-1/2" UL listed fire hoses and USCG approved nozzles.

4 FORMULAS

(not used)

5 CALCULATIONS

5.1 Pipe Nominal Velocity Calculation

Pipe sizes are based on the nominal velocity limits found in [2]. Table 1 shows the flows occurring in all branches of the system, and the resulting pipe sizes:

Table 1: Nominal Pipe Velocities


Pipe Segment	Flow Rate gpm	Pipe Size (NPS)	ID in	Design Velocity (ft/s)		V ft/s
				Nominal	Limit	
Firemain Suction	50	2" Sch 40	2.067	4.31	15.00	4.66
Firemain Discharge	50	2" Sch 40	2.067	7.19	15.00	4.66
Firemain Branch	50	1-1/2" Sch 40	1.610	6.34	15.00	7.67

5.2 Fire Pump TDH and NPSH Calculation

From the attached PIPE-FLO model, the fire pump is required to produce about 150 feet TDH at the required flow rate of 51 gpm.

REFERENCES

- [1] USCG, "46 CFR, Chapter I, Subchapter T, Part 181 Fire Protection Equipment," 12/8/2016.
- [2] R. L. Harrington, Marine Engineering, Jersey City, NJ: SNAME, 1992.
- [3] Elliott Bay Design Group, "Profiles and Arrangements," 16109-003-101 , Seattle, WA.



PIPE-FLO Professional	Units Used	Project Information
Program Version: 15.2.37316 Calculation Method: Darcy-Weisbach Maximum Iterations: 100 Iteration Tolerance: 0.01 Laminar Cutoff Re: 2100	Flow rate: gpm Velocity: ft/s Pressure: psi g Elevation: ft Length: ft Size: in. Power: hp Temperature: °F Density: lb/ft³ Viscosity: cP Atmospheric Pressure: 14.7 psi a	Company: EBDG Project: 16109.00 Drawn by: LGB File Name: 16109-521rev-pipe Lineup: Upper Deck Station Print Date: Friday, March 03, 2017 09:57 AM

List Report

File Name: 16109-521rev-pipe
 Lineup: Upper Deck Station
 Program Name: PIPE-FLO Professional
 Version: 15.2.37316

Calculation Method: Darcy-Weisbach
 Laminar Cutoff Re: 2100
 Max Iterations: 100
 Iteration Tolerance: 0.01
 Atmospheric Pressure: 14.7 psi a

Company: EBDG
 Project: 16109.00
 by: LGB
 Date: Friday, March 03, 2017 09:55 AM

Specification Name	Material Schedule	Pipe Specifications			Sizing Criteria		Design Limits		Reynolds Number
		Absolute Roughness	Hazen Williams C Factor	Velocity	Pressure	Pressure			
Cu/Ni Class 200 standard	Copper Nickel MIL-T-16420K Schedule:Class 200	6E-05 in	150	to	to	psi g	to	to	
Al B241 sch 40 standard	Aluminum B241 Schedule:40	6E-05 in	140	to	to	psi g	to	to	

Fluid Zones

Table Name	Temperature	Pressure	Fluid State	Density	Viscosity	Vapor Pressure	Critical Pressure	Specific Heat Ratio (k)	Relative Molecular Mass
Seawater	65 °F	0 psi g	Liquid	64 lb/ft³	1.127 cP	0.2997 psi a	3199 psi a	--	29

Centrifugal Pumps

Pump Name	Test Speed	Operating Speed	Suction Elevation	Suction Pressure	Discharge Elevation	Discharge Pressure	Total Head dp	Flow Rate	Power	Flow Rate	Efficiency	BEP Efficiency	NPSHa	Design NPSH	Margin Ratio	
Sizing Pump 3	3500 rpm	3500 rpm	2 ft	2 ft	2 ft	66.17 psi g	149.8 ft	51.23 gpm	46.2 %	31.49 ft	46.2 %	51 %	31.49 ft	9.998 ft	--	
Fixed Speed			-0.4013 psi g	66.17 psi g		66.57 psi		4.279 hp								

Company: Ampco Pumps
 Curve: Catalog Pump
 Type: Z-SERIES
 Size: 1.5x1.25SS
 Diameter: 6 in
 POR: from -- to --

Sizing Pump 2	Test Speed	Operating Speed	Suction Elevation	Suction Pressure	Discharge Elevation	Discharge Pressure	Total Head dp	Flow Rate	Power	Flow Rate	Efficiency	BEP Efficiency	NPSHa	Design NPSH	Margin Ratio
Fixed Speed			2 ft	2 ft	2 ft										

Company: Ampco Pumps
 Curve: Catalog Pump
 Type: Z-SERIES
 Size: 1.5x1.25SS
 Diameter: 6 in
 POR: from -- to --

Pipelines

Pipeline Name	Specification	Fluid Zone	Size	Inside Diameter	Length	Inlet Elevation	Outlet Elevation	Flow Rate	Fluid Velocity	Reynolds Number	Total Head Loss	V&F Head Loss	Inlet Pressure	Outlet Pressure	Total dp	Pipe Friction Factor	V&F Friction Factor	V&F Resistance K
Pipe 2	Al B241 sch 40 Seawater		2 in	2.067 in	35 ft	2 ft	16 ft	51.23 gpm	4.899 ft/s	71293	3.493 ft	2.018 ft	66.17 psi g	58.39 psi g	7.775 psi	0.01946	0.01899	5.41
			Inlet Device: Sizing Pump 3					Outlet Device: Node 1										
Pipe 4	Al B241 sch 40 Seawater		1.5 in	1.61 in	30 ft	16 ft	16 ft	--	--	--	--	--	58.39 psi g	--	--	--	--	9.28
			Inlet Device: Node 1					Outlet Device: Node 2										
Pipe 3	Al B241 sch 40 Seawater		1.5 in	1.61 in	15 ft	16 ft	23 ft	51.23 gpm	8.074 ft/s	91529	8.225 ft	6.128 ft	58.39 psi g	51.63 psi g	6.767 psi	0.01852	0.02018	6.05
			Inlet Device: Node 1					Outlet Device: Node 3										

PipeLines											
Pipeline Name Specification Fluid Zone	Size Inside Diameter Length	Inlet Elevation Outlet Elevation	Flow Rate Fluid Velocity Reynolds Number	Total Head Loss V&F Head Loss	Inlet Pressure Outlet Pressure	Total dP V&F dP	Pipe Friction Factor V&F Friction Factor V&F Resistance K				
Pipe 1 Al B241 sch 40 Seawater	2 in 2.067 in 5 ft	0 ft 2 ft	51.23 gpm 4.699 f/s 71293	1.117 ft 0.9065 ft	1.556 psi/g 0.1702 psi/g	1.385 psi 0.4029 psi	0.01946 0.01899 2.43				
Inlet Device: SEA WATER											
Pipe 5 Al B241 sch 40 Seawater	2 in 2.067 in 2.5 ft	2 ft 2 ft	51.23 gpm 4.699 f/s 71293	0.1053 ft 0 ft	-0.3545 psi/g -0.4013 psi/g	0.0468 psi 0 psi	0.01946 0.01899 0.00				
Inlet Device: 2" Eaton Model 72											
HOSE Al B241 sch 40 Seawater	1.5 in 1.61 in 50 ft	16 ft 16 ft	-- --	-- --	-- --	-- --	-- -- 0.00				
Inlet Device: Node 2											
spray1 Al B241 sch 40 Seawater	1.5 in 1.61 in 0.01 ft	16 ft 16 ft	-- --	-- --	-- --	-- --	-- -- 0.00				
Inlet Device: Fire Nozzle											
HOSE2 Al B241 sch 40 Seawater	1.5 in 1.61 in 50 ft	23 ft 23 ft	51.23 gpm 8.074 f/s 91529	6.991 ft 0 ft	51.63 psi/g 48.52 psi/g	3.107 psi 0 psi	0.01852 0.02018 0.00				
Inlet Device: Node 3											
spray Al B241 sch 40 Seawater	1.5 in 1.61 in 0.01 ft	23 ft 23 ft	51.23 gpm 8.074 f/s 91529	1.398E-03 ft 0 ft	6.214E-04 psi/g 0 psi/g	6.214E-04 psi 0 psi	0.01852 0.02018 0.00				
Inlet Device: Fire Nozzle1											
Inlet Device: Upper Deck Aft; Sbd Station											
Tanks											
Tank Name Fluid Zone	Bottom Elevation Liquid Level	Surface Pressure Bottom Pressure	Hydraulic Grade	Pipeline Name	Penetration Height	Connecting Pipelines Pipeline Flow Rate	Pressure at Penetration				
SEA WATER Seawater	0 ft 3.5 ft	0 psi/g 1.556 psi/g	3.5 ft	Pipe 1	0 ft	51.23 gpm	1.556 psi/g				
Fire Nozzle 1/2 Fire Nozzle	16 ft --	-- --	16 ft --	-- --	-- --	-- --	-- --				
Fire Nozzle1 1/2 Fire Nozzle	23 ft 48.52 psi/g	6.214E-04 psi/g	23 ft	48.52 psi 109.2 ft	51.23 gpm	51.23 gpm	0.01852 0.02018 0.00				
Nodes											
Node Name	Elevation	Pressure	Hydraulic Grade								
Node 1	16 ft	58.39 psi/g	146.7 ft								
Node 2	16 ft	--	--								
Node 3	23 ft	51.63 psi/g	138.1 ft								
Pressure Boundaries											
Pressure Boundary Name	Elevation	Pressure	Hydraulic Grade	Flow Rate							
Upper Deck Aft; Sbd Station	23 ft	0 psi/g	21.99 ft	51.23 gpm							
Main Deck Aft; port Station1	16 ft	0 psi/g	--	--							

Bill of Materials Report

File Name: 16109-521rev-.pipe
Lineup: Upper Deck Station
Program Name: PIPE-FLO Professional
Version: 15.2.37316

Company: EBDG
Project: 16109.00
by: LGB
Date: Friday, March 03, 2017 09:55 AM

Pipelines				
Pipeline	Specification	Size	Length	Valves and Fittings
Pipe 2	Al B241 sch 40	2 in	35 ft	8 x Elbow - Standard 90° 1 x Butterfly
Pipe 4	Al B241 sch 40	1.5 in	30 ft	1 x Reducer - Contraction (1.5 in x 2 in - 8 x Elbow - Standard 90° 1 x Tee - Flow Thru Branch 1 x Globe - 90°, Plug In Flow Path
Pipe 3	Al B241 sch 40	1.5 in	15 ft	4 x Elbow - Standard 90° 1 x Tee - Flow Thru Run 1 x Reducer - Contraction (1.5 in x 2 in - 1 x Globe - 90°, Plug In Flow Path
Pipe 1	Al B241 sch 40	2 in	5 ft	1 x Gate - Plug Type 4 x Elbow - Standard 90°
Pipe 5	Al B241 sch 40	2 in	2.5 ft	
HOSE	Al B241 sch 40	1.5 in	50 ft	
spray1	Al B241 sch 40	1.5 in	0.01 ft	
HOSE2	Al B241 sch 40	1.5 in	50 ft	
spray	Al B241 sch 40	1.5 in	0.01 ft	

Pipeline Material Summary				
Specification	Material	Size	Total Length	Valves & Fittings
Al B241 sch 40	Aluminum B241 Schedule: 40	1.5 in	145.02 ft	12 x Elbow - Standard 90° 2 x Globe - 90°, Plug In Flow Path 2 x Reducer - Contraction (1.5 in x 2 in - 0 in) 1 x Tee - Flow Thru Branch 1 x Tee - Flow Thru Run
Al B241 sch 40	Aluminum B241 Schedule: 40	2 in	42.50 ft	1 x Butterfly 12 x Elbow - Standard 90° 1 x Gate - Plug Type

Appendix E

Sanitary Drains and Sewage Discharge

1 DESCRIPTION

This appendix documents the calculations used in designing the sewage discharge system. These calculations establish minimum discharge pipe sizes and required pump capacity. Estimated losses through sewage discharge piping are calculated to establish total dynamic head required for the sewage discharge pump.

2 PROCEDURE

Calculations are presented in the following sequence:

- Sewage discharge pump capacity calculations
- Sewage discharge pipe nominal velocity calculations
- Sewage pump total dynamic head (TDH) calculation

Initial sewage pump capacity is based on the desire to empty the sewage-holding tank in approximately 5 minutes.

Initial pipe sizes are also based on the nominal velocity limits found in [1], Chapter 20, Table 3.

Frictional losses through the piping system are calculated by constructing a model using PIPE-FLO Professional software.

3 GIVEN AND ASSUMED PARAMETERS

- Sewage discharge piping is to be constructed of aluminum.
- System pipe lengths, routing and fittings are estimated based on Profiles and Arrangements [2].
- Shore side facilities are conservatively estimated as 50 feet of 2 inch hose and 200 feet of 2 inch schedule 80 steel piping with a storage tank elevation of 20 feet.

4 FORMULAS

(not used)

5 CALCULATIONS

5.1 Sewage Discharge Pump Capacity Calculation

The sewage pump capacity is based on the ability to empty the sewage-holding tank in approximately 5 minutes. With a tank of 200 gallon this results in a pump capable of approximately 40 gpm.

5.2 Pipe Nominal Velocity Calculation

Initial pipe sizes are also based on the nominal velocity limits found in [1]. Table 1 shows the flows occurring in all portions of the system, and the resulting pipe sizes:

Table 1: Nominal Pipe Velocities

Pipe Segment	Flow Rate gpm	Pipe Size (NPS)	ID in	Design Velocity (ft/s)		V ft/s
				Nominal	Limit	
Pump Suction	40	3" Sch 80	2.900	5.11	15.00	1.89
Sewage Discharge	40	2" Sch 80	1.940	6.96	15.00	4.23


5.3 Sewage Pump TDH Calculation

From the attached PIPE-FLO model, the sewage discharge pump is required to produce about 36 feet TDH at 40 gpm.

6 REFERENCES

[1] R. L. Harrington, Marine Engineering, Jersey City, NJ: SNAME, 1992.

[2] Elliott Bay Design Group, "Profiles and Arrangements," 16109-003-101-1, Seattle, WA.



Project Information	
Company: EBDG Project: 16109 Drawn by: JHP File Name: 16109-003-528.pipe Lineup: <Design Case> Print Date: Wednesday, January 18, 2017 12:32 PM	
PIPE-FLO Professional	Units Used
Program Version: 15.2.37316 Calculation Method: Darcy-Weisbach Maximum Iterations: 100 Iteration Tolerance: 0.01 Laminar Cutoff Re: 2100	Flow rate: gpm Velocity: ft/s Pressure: psi g Elevation: ft Length: ft Size: in Power: Temperature: °F Density: lb/ft³ Viscosity: cP Atmospheric Pressure: 14.7 psi a

List Report

File Name: 16109-003-528.pipe
 Lineup: <Design Case>
 Program Name: PIPE-FLO Professional
 Version: 15.2.37316

Calculation Method: Darcy-Weisbach
 Laminar Cutoff Re: 2100
 Max Iterations: 100
 Iteration Tolerance: 0.01
 Atmospheric Pressure: 14.7 psi a

Company: EBDG
 Project: 16109
 by: JHP
 Date: Wednesday, January 18, 2017 12:33 PM

Specification Name	Material Schedule	Pipe Specifications		Design Limits	
		Absolute Roughness Hazen Williams C Factor	Sizing Criteria	Pressure	Reynolds Number
AL B241 sch 80 standard	Aluminum B241 Schedule:80	6E-05 in 140	0.0	to psi g	to
Steel A53-B36-10 Sch 80 standard	Steel A53-B36-10 Schedule:80	1.800E-03 in 140	0.0	to psi g	to

Fluid Zone Name Table Name	Temperature	Pressure	Fluid State	Density Viscosity	Vapor Pressure Critical Pressure	Specific Heat Ratio (k) Relative Molecular Mass

Pump Name	Suction Elevation	Inlet Elevation	Discharge Elevation	Discharge Pressure	Flow Rate	NPSHa
	0.3256 psi g	15.96 psi g	15.64 psi			

Pipe Name Specification Fluid Zone	Size Inside Diameter Length	Inlet Elevation	Outlet Elevation	Flow Rate Fluid Velocity Reynolds Number	Total Head Loss V&F Head Loss	Inlet Pressure Outlet Pressure	Pipe Friction Factor V&F Friction Factor V&F Resistance K
Discharge	2 in 1.939 in 25 ft	-1.5 ft 10 ft	40 gpm 4.346 ft/s 51418	2.324 ft 1.376 ft	15.96 psi g 9.989 psi g	5.991 psi 0.5962 psi 4.69	

Hose	Inlet Device	Inlet Elevation	Outlet Elevation	Flow Rate	Total Head Loss	Inlet Pressure	Pipe Friction Factor
				4.346 ft/s	0.8491 ft	6.5 psi g	0.01928

Shore pipe	Inlet Device	Inlet Elevation	Outlet Elevation	Flow Rate	Total Head Loss	Inlet Pressure	Pipe Friction Factor
				4.346 ft/s	1.376 ft	0 psi g	0.01928

Tank Name Fluid Zone	Bottom Elevation Liquid Level	Surface Pressure Bottom Pressure	Hydraulic Grade	Connecting Pipelines	
				Pipeline Name	Penetration Height Pipeline Flow Rate Pressure at Penetration
SEWAGE TANK	-1.5 ft 1 ft	0 psi g 0.4334 psi g	-0.5 ft		

Tanks										
Tank Name	Fluid Zone	Bottom Elevation	Surface Pressure	Bottom Pressure	Hydraulic Grade	Pipeline Name	Penetration Height	Connecting Pipelines	Pipeline Flow Rate	Pressure at Penetration
SEWAGE TANK	Water	-1.5 ft 1 ft	0 psi g 0.4334 psi g		-0.5 ft	Suction	0 ft		40 gpm	0.4334 psi g
Nodes										
Node Name	Elevation	Pressure	Hydraulic Grade							
VESSEL CONNECTION	10 ft	9.969 psi g	32.71 ft							
TANK ON SHORE	15 ft	6.5 psi g	29.7 ft							
Pressure Boundaries										
Pressure Boundary Name	Elevation	Pressure	Hydraulic Grade	Flow Rate						
TANK ON SHORE1	20 ft	0 psi g	19.71 ft	40 gpm						

Bill of Materials Report

File Name: 16109-003-528.pipe
Lineup: <Design Case>
Program Name: PIPE-FLO Professional
Version: 15.2.37316

Company: EBDG
Project: 16109
by: JHP
Date: Wednesday, January 18, 2017 12:32 PM

Pipelines				
Pipeline	Specification	Size	Length	Valves and Fittings
Suction	AL B241 sch 80	3 in	10 ft	6 x Elbow - Standard 90° 1 x Gate - Double Disc
Discharge	AL B241 sch 80	2 in	25 ft	8 x Elbow - Standard 90° 1 x Ball
Hose	Steel A53-B36.10 Sch 80	2 in	50 ft	5 x Elbow - Standard 90°
Shore pipe	Steel A53-B36.10 Sch 80	2 in	200 ft	8 x Elbow - Standard 90° 1 x Ball

Pipeline Material Summary				
Specification	Material	Size	Total Length	Valves & Fittings
AL B241 sch 80	Aluminum B241 Schedule: 80	2 in	25.00 ft	1 x Ball 8 x Elbow - Standard 90°
AL B241 sch 80	Aluminum B241 Schedule: 80	3 in	10.00 ft	6 x Elbow - Standard 90° 1 x Gate - Double Disc
Steel A53-B36.10 Sch 80	Steel A53-B36.10 Schedule: 80	2 in	250.00 ft	1 x Ball 13 x Elbow - Standard 90°

Appendix F

Bilge System

1 DESCRIPTION

This appendix documents the calculations used in designing the bilge system. These calculations establish required pump capacity and quantity in accordance with regulatory requirements. Estimated losses through bilge system piping are calculated to establish the total dynamic head (TDH) for all of the bilge pumps.

2 PROCEDURE

Calculations are presented in the following sequence:

- Bilge pump capacity and quantity calculations
- Bilge pipe nominal velocity calculations
- Bilge pump TDH calculation

Bilge pump capacity calculations are based on the requirements found in [1].

Initial pipe sizes are also based on the nominal velocity limits found in [2], Chapter 20, Table 3.

Frictional losses through the piping system are calculated by constructing a model using PIPE-FLO Professional software.

3 GIVEN AND ASSUMED PARAMETERS

- Each water tight compartment will be equipped with a submersible bilge pump. Each Engine Room will be equipped with two submersible bilge pumps. The forward most void will be equipped with a manual pump.
- Bilge system is to be constructed of flexible hose and schedule 80 aluminum pipe.
- Bilge overboard discharges are assumed to be 9 feet above baseline.
- System pipe lengths, routing and fittings are estimated based on the Profiles and Arrangements, [3].

4 FORMULAS

(not used)

5 CALCULATIONS

5.1 Bilge Pipe Size and Pump Capacity Calculation

From the attached calculations, each demi-hull is required to have a total bilge pump capacity of 30 cubic meters per hour, or 136 gallons per minute. Each pump must have minimum capacity of 7.7 cubic meters per hour, or 34 gallons per minute. However, per [1], the required minimum bilge pump capacity is 8 cubic meters per hour, or 35 gallons per minute.

5.2 Bilge Pipe Nominal Velocity Calculation

Initial pipe sizes are also based on the nominal velocity limits found in [2]. Table 1 shows the flows occurring in all portions of the system, and the resulting pipe sizes:

Table 1: Nominal Bilge Pipe Velocities

Pipe Segment	Flow Rate gpm	Pipe Size (NPS)	ID in	Design Velocity (ft/s)		V ft/s
				Nominal	Limit	
Bilge Hose	35	2" ID Hose	2.000	7.07	15.00	3.48
Bilge Overboard	35	1-1/2" Sch 80	1.500	6.12	15.00	6.19

5.3 Bilge Pump Total Head and Net Positive Suction Head (NPSH) Calculation

From the attached PIPE-FLO model, each bilge pump is required to produce about 10 feet TDH at the required flow rate of 35 gpm.

6 REFERENCES

- [1] Lloyd's Register, "Rules and Regulations for the Classification of Special Service Craft," 2015.
- [2] R. L. Harrington, Marine Engineering, Jersey City, NJ: SNAME, 1992.
- [3] Elliott Bay Design Group, "Profiles and Arrangements," 16109-003-101-0, Seattle, WA.

Size of Bilge Main Suction Pipes

Per Lloyd's Register Rules and Regulations for the Classification of Special Service Craft Chapter 15, Section 12, Paragraph 12.3.1

Where a bilge main is fitted in each hull, it's internal diameter d_m is not to be less than that required by the following formula:

$$d_m = 1.68\sqrt{L(B + D)} + 25 [mm]$$

where

B = breadth of a demi-hull in meters

D = moulded depth to the watertight deck, in meters

L = Length of craft in meters

B =	9 feet	2.74 meters
D =	11.5 feet	3.51 meters
L =	92 feet	28.04 meters

$d_m =$	47.24 mm	1.86 inch
---------	----------	-----------

Size of Bilge Branch Suctions

Per Lloyd's Register Rules and Regulations for the Classification of Special Service Craft Chapter 15, Section 12, Paragraph 12.3.2

The diameter d_b of a branch bilge suction pipes is to be not less than that required by the following formula

$$d_b = 2.15\sqrt{C(B + D)} + 12.5 [mm]$$

where

C = length of the compartment in meters

Space	C (ft)	C (m)	d_b (mm)	d_b (in)
Jet Room	10.00	3.05	29.50	1.16
Engine Room	22.00	6.71	37.71	1.48
Tank Room	32.00	9.75	42.90	1.69
Void 2	12.00	3.66	31.12	1.23

Total Capacity Fixed Submersible Pumps

Per Lloyd's Register Rules and Regulations for the Classification of Special Service Craft Chapter 15, Section 12, Paragraph 12.4.5

Where fixed submersible bilge pumps are fitted, the total capacity, Q_t of the pumps in each hull is to be not less than that required by the following formula:

$$Q_t = \frac{13.8}{10^3} * d_m^2 [m^3/hr]$$

$Q_t =$	30.8 m ³ /hr	136 gpm
---------	-------------------------	---------

Total Capacity Fixed Submersible Pumps

Per Lloyd's Register Rules and Regulations for the Classification of Special Service Craft Chapter 15, Section 12, Paragraph 12.4.6

The capacity Q_n of each submersible pump is to be not less than required by the following formula:

$$Q_n = \frac{Q_t}{(N-1)} [m^3/hr]$$


Where

N = number of fixed submersible pumps in each hull

Q_t = Total Capacity as defined above

Q_n is in no case to be less than 8 m³/hr

$N =$	5	
$Q_n =$	7.7 m ³ /hr	34 gpm



PIPE-FLO Professional	Units Used	Project Information
Program Version: 15.2.37316 Calculation Method: Darcy-Weisbach Maximum Iterations: 100 Iteration Tolerance: 0.01 Laminar Cutoff Re: 2100	Flow rate: Power: hp Velocity: ft/s Temperature: °F Pressure: psi Density: lb/ft³ Elevation: ft Viscosity: cP Length: ft Atm Pressure: 14.7 psi a Size: in	Company: EBDG Project: 16109 Drawn by: LGB File Name: 16109-529.pipe Lineup: <Design Case> Print Date: Wednesday, January 11, 2017 08:43 AM

List Report

File Name: 16109-529-pipe
 Lineup: <Design Case>
 Program Name: PIPE-FLO Professional
 Version: 15.2.37316

Calculation Method: Darcy-Weisbach
 Laminar Cutoff Re: 2100
 Max Iterations: 100
 Percent Tolerance: 0.01
 Allowable Deviation: 1. %

Company: EBDG
 Project: 16109
 by: LGB
 Date: Wednesday, January 11, 2017 08:45 AM
 Atmospheric Pressure: 14.7 psi a

Specification Name		Material Schedule		Pipe Specifications		Sizing Criteria		Design Limits								
Valve Table		Absolute Roughness	Hazen Williams C Factor	Velocity	Pressure	Reynolds Number										
Aluminum B241 Sch 80 standard	Aluminum B241 Schedule:80	6E-05 in	140	0.0	0.0	Min: psi g	Max: psi g									
Hose standard	Sanitary Tubing Schedule:STD	6E-05 in	100	0.0	0.0	Min: psi g	Max: psi g									
Fluid Zones																
Fluid Zone Name	Temperature Pressure	Fluid State	Relative Molecular Mass	Density	Viscosity	Vapor Pressure	Critical Pressure	Specific Heat Capacity (cp)	Specific Heat Ratio (k)							
Sea Water	65 °F	Liquid	29	64 lb/ft ³	1.127 cP	0.2997 psi a	3199 psi a	--	--							
Seawater 3.5% Salinity	0 psi g															
Sizing Pumps																
Pump Name	Suction Elevation	Discharge Elevation	Discharge Pressure	Total Head	Flow Rate	NPSHa										
Sizing Pump 1	0 ft	0 ft	4.338 psi g	9.764 ft	35 gpm	32.39 ft										
	-1.288E-03 psi g			4.34 psi												
Pipelines																
Pipeline Name	Size	Inlet Device	Inlet Elevation	Outlet Device	Outlet Elevation	Inlet Total Pressure	Inlet Static Pressure	Inlet Energy Grade	Total dp	Outlet Total Pressure	Outlet Static Pressure	Outlet Energy Grade	V&F Friction Factor	V&F Resistance K	V&F dp	V&F Head Loss
Pipe 1	2 in	Sizing Pump 1	0 ft	Sizing Pump 1	9 ft	4.338 psi g	4.223 psi g	9.762 ft	0.7119 ft	0.02203 psi g	-0.09343 psi g	9.05 ft	0.82	0.09434 psi	0.2123 ft	
Hose	1.87 in	Nodes 1	0 ft	Nodes 1	9 ft	4.338 psi g	4.223 psi g	9.762 ft	0.7119 ft	-0.09343 psi g	-0.09343 psi g	9.05 ft	0.82	0.09434 psi	0.2123 ft	
Sea Water	14.5 ft					9.502 ft	9.502 ft	9.502 ft	8.79 ft	8.79 ft	8.79 ft	8.79 ft				
Pipe 2	2 in	Tank 1	0 ft	Sizing Pump 1	9 ft	0 psi g	-0.09343 psi g	0 ft	2.897E-03 ft	-1.288E-03 psi g	-0.1012 psi g	-0.2276 ft	0.0	0	0	
Aluminum B241 Sch 80	1.939 in	Sizing Pump 1	0 ft	Sizing Pump 1	9 ft	0 psi g	-0.09343 psi g	0 ft	2.897E-03 ft	-1.288E-03 psi g	-0.1012 psi g	-0.2276 ft	0.0	0	0	
Sea Water	0.1 ft					0.02203 psi g	0.02203 psi g	0.02203 psi g	0.02203 psi g	0.02203 psi g	0.02203 psi g	0.02203 psi g	0.0	0	0	
Pipe 3	1.5 in	Nodes 1	9 ft	Pressure Boundary 1	9 ft	0.02203 psi g	-0.2569 psi g	9.05 ft	0.04958 ft	0.02203 psi g	-0.2789 psi g	8.372 ft	0.02054	0.00	0.00	
Aluminum B241 Sch 80	1.5 in	Pressure Boundary 1	9 ft	Pressure Boundary 1	9 ft	0.02203 psi g	-0.2569 psi g	9.05 ft	0.04958 ft	0.02203 psi g	-0.2789 psi g	8.372 ft	0.02054	0.00	0.00	
Sea Water	0.5 ft					8.422 ft	8.422 ft	8.422 ft	8.372 ft	8.372 ft	8.372 ft	8.372 ft	0.0	0	0	
Tanks																
Tank Name	Bottom Elevation	Surface Pressure	Bottom Pressure	Hydraulic Grade	Penetration Height	Pipeline Name	Penetration Height	Pipeline Flow Rate	Pressure at Penetration							
Fluid Zone	Liquid Level															
Tank 1	0 ft	0 psi g	0 psi g	0 ft	0 ft	Pipe 2	0 ft	35 gpm	0 psi g							
	0 ft															

Nodes			
Node Name	Elevation	Pressure	Hydraulic Grade
Node 1	9 ft	0.02203 psi g	8.606 ft
Pressure Boundaries			
Pressure Boundary Name	Elevation	Pressure	Hydraulic Grade
Pressure Boundary 1	9 ft	0 psi g	8.372 ft
			Flow Rate
			35 gpm

Bill of Materials Report

File Name: 16109-529.pipe
 Lineup: <Design Case>
 Program Name: PIPE-FLO Professional
 Version: 15.2.37316

Company: EBDG
 Project: 16109
 by: LGB
 Date: Wednesday, January 11, 2017 08:45 AM

Sizing Pumps

Sizing Pump Name Operation	Flow Rate	Design Point Total Head
Sizing Pump 1 Flow @ 35 gpm	35 gpm	9.764 ft

Tanks

Tank Name
Tank 1

Pipelines

Pipeline	Specification	Size	Length	Valves and Fittings
Pipe 1	Hose	2 in	14.5 ft	3 x Elbow - Long radius, r/d 1.5 (90°)
Pipe 2	Aluminum B241 Sch 80	2 in	0.1 ft	
Pipe 3	Aluminum B241 Sch 80	1.5 in	0.5 ft	

Pipeline Material Summary

Specification	Material	Size	Total Length	Valves & Fittings
Aluminum B241 Sch 80	Aluminum B241 Schedule: 80	1.5 in	0.50 ft	
Aluminum B241 Sch 80	Aluminum B241 Schedule: 80	2 in	0.10 ft	
Hose	Sanitary Tubing Schedule: STD	2 in	14.50 ft	3 x Elbow - Long radius, r/d 1.5 (90°)

Appendix G

Potable Water

1 DESCRIPTION

This appendix documents the calculations used in designing the potable water system. These calculations were used to determine flow demand and pipe sizes for the potable water piping and to size the potable water pressure tank and pump.

2 PROCEDURE

Calculations are presented in the following sequence:

- Demand water supply calculation
- Potable water tank sizing calculation

System sizing is based on the guidance found in Appendix A of Reference [1].

3 GIVEN AND ASSUMED PARAMETERS

- The system is to be pressurized by a single pump which will cycle on at 40psig and off at 60 psig.
- The heads will be Headhunter brand with less than 1 gpm per flush.
- The potable water consumers on the vessel: 2 heads, 2 lavatories, 1 sink in the food service area and 3 exterior hose bibs.

4 FORMULAS

The following formulas, taken from [2], are used to estimate the size of the potable water pressure tank:

$$\begin{aligned} \text{Eq 1: Supplemental Drawdown (gal)} \\ &= (\text{Peak demand (gpm)} - \text{pump capacity(gpm)}) \\ &\times \text{Peak Demand Time (min)} \end{aligned}$$

$$\text{Eq 2: Total Pressure Tank Volume} = \frac{\text{Minimum Drawdown} + \text{Supplemental Drawdown}}{\text{Acceptance Factor}}$$

$$\text{Eq 3: Acceptance Factor} = 1 - \frac{P1 (\text{tank precharge}) + 14.7}{P2 (\text{cutout}) + 14.7}$$

5 CALCULATIONS

5.1 Demand Water Supply Calculations

Table 1: Water Supply

Level	Item	Qty	Water Supply Fixture Units, Table A-2	Item Totals
Main Deck	Food Service Sink	1	1.5	1.5
	Lavatory	2	1	2
	Hose Bib*	1	2.5	2.5
	Hose Bib	2	1	2
	Head	2	5	10
	Total, 03 Deck:			
Total WSFU for Vessel			18	
Supply demand, from [1], Ch A-3, line 1			30 GPM	
Excluding water closets, from [1], Ch A-3, Line 2			7 GPM	
*First hose bib is 2.5 WSFU, additional are 1.0				

Demand flow from Chart A-3, Line 1 is 30 gpm, from [1]. This flow rate is for land side toilets that require 1.6 gpf. The toilets to be installed use less than 1 gpf. For a water system with 2 heads a 10 gpm at 50 psi would be sufficient, per [3].

5.2 Pressure Tank Sizing Calculation

Table 2: Pressure Tank Sizing

	Item	Qty		Note / Reference
(1)	Pump Capacity	10	gpm	
(2)	Minimum Drawdown	5	gallons	
(4)	Peak Demand Estimation	15	gpm	
(5)	Peak Demand Time	0.08	minutes	
(6)	P1 pressure tank precharge	40	psi	
(7)	P2 cutout pressure	60	psi	
(9)	Supplemental Drawdown	0.40	gallons	Eq. 1: [(4) - (1)] * (5)
(10)	Total Required Drawdown	5.40	gallons	Eq. 2: (2) + (9)
(11)	Acceptance Factor	0.27		Eq. 3: 1 - [(6) + 14.7] / [(7) + 14.7]
(12)	Total Calculated Tank Size	20	gallons	Eq. 4 (10) / (11)

The toilet manufacture recommends a pressure tank with at least a 2 gallon draw down for a water system with 2 heads [3]. For approximately 5 gallon drawdown, a 20 gallon pressure tank is needed.

6 REFERENCES

- [1] IAPMO/ANSI UPC 1 - 2009: Uniform Plumbing Code, Ontario, CA: International Association of Plumbing and Mechanical Officials, 04/2009.
- [2] Water Systems Council, Wellcare Information For You About Sizing a Pressure Tank, Washington, DC.
- [3] Scott at Headhunter (2017,Jan. 13), *Headhunter Toilet Questions*, phone call, 01/13/17.