

ECONOLITE ASC/3-2070 PED 3 PROGRAMMING ASSIGNMENT DETAIL

(program controller as shown)

1. From Main Menu select 6. DETECTORS
2. From DETECTOR Submenu select 3. PED DETECTOR INPUT ASSIGNMENT

PED DET PHASE ASSIGNMENT MODE: NTCIP								
PHASE	1	2	3	4	5	6	7	8
DETECTOR	0	2	8	0	0	6	0	0
PHASE	9	10	11	12	13	14	15	16
DETECTOR	0	0	0	0	0	0	0	0

← NOTICE PED DETECTOR 8
ASSIGNED TO PHASE 3

1. From Main Menu select 1. CONFIGURATION
2. From CONFIGURATION Submenu select 3. LOAD SW ASSIGN

LD SWITCH ASSIGN									
PHASE /OVLP	TYPE	DIMMING			---FLASH---			TGR	
		R	Y	G D	PWR	AUT			
1	1	V	.	.	.	+	A	R	X
2	2	V	.	.	.	+	A	Y	.
3	3	V	.	.	.	+	A	R	X
4	4	V	.	.	.	+	A	R	.
5	5	V	.	.	.	-	A	R	.
6	6	V	.	.	.	-	A	Y	X
7	7	V	.	.	.	-	A	R	.
8	8	V	.	.	.	-	A	R	X
9	1	O	.	.	.	+	A	R	X
10	2	O	.	.	.	+	A	R	X
11	3	O	.	.	.	-	A	R	.
12	4	O	.	.	.	-	A	R	.
13	2	P	.	.	.	+	A	.	.
14	4	P	.	.	.	-	A	.	.
15	6	P	.	.	.	+	A	.	.
16	3	P	.	.	.	-	A	.	.

→ NOTICE PHASE 3 PED
ASSIGNED TO LD SWITCH 16

THIS ELECTRICAL DETAIL IS FOR
THE SIGNAL DESIGN: 06-0224T3
DESIGNED: March 2018
SEALED: 03-29-2018
REVISED: N/A

Temporary Design 3 - TMP Phase III
Electrical Detail - Sheet 2 of 2

DOCUMENT NOT CONSIDERED FINAL
UNLESS ALL SIGNATURES COMPLETED

<p style="font-size: x-small;">Stantec Consulting Services Inc. 801 Jones Franklin Road-Suite 300 Raleigh, NC 27606 Tel. (919) 851-6866 Fax. (919) 851-7024 www.stantec.com License No. F-0672</p>	<p style="font-size: x-small;">ELECTRICAL AND PROGRAMMING DETAILS FOR:</p> <p style="text-align: center; font-size: x-small;">Prepared in the Offices of:</p> <p style="font-size: x-small;">750 N. Greenfield Pkwy, Garner, NC 27529</p>	<p style="text-align: center;">US 401 Business (Raeford Road) at Purdue Drive/ SteinMart Driveway</p> <p style="font-size: x-small;">Division 6 Cumberland County Fayetteville</p> <table style="width: 100%; font-size: x-small;"> <tr> <td>PLAN DATE: March 2018</td> <td>REVIEWED BY: L Overn</td> </tr> <tr> <td>PREPARED BY: G B Spell</td> <td>REVIEWED BY:</td> </tr> </table> <table style="width: 100%; font-size: x-small;"> <tr> <th>REVISIONS</th> <th>INIT.</th> <th>DATE</th> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>	PLAN DATE: March 2018	REVIEWED BY: L Overn	PREPARED BY: G B Spell	REVIEWED BY:	REVISIONS	INIT.	DATE				<p style="text-align: center; font-size: x-small;">SEAL</p> <p style="font-size: x-small;">3/29/2018</p> <p style="font-size: x-small;">DATE</p> <p style="font-size: x-small;">SIG. INVENTORY NO. 06-0224T3</p>
PLAN DATE: March 2018	REVIEWED BY: L Overn												
PREPARED BY: G B Spell	REVIEWED BY:												
REVISIONS	INIT.	DATE											

DATE: 03/29/2018 10:45:12 AM
User: rfmancey