

## ECONOLITE ASC/3-2070 LOAD SWITCH ASSIGNMENT DETAIL

(program controller as shown)

To assign load switches 2 and 5 as vehicle load switches, program LD SWITCH 2 as PHASE '2' TYPE 'V' and LD SWITCH 5 as PHASE '5' TYPE 'V' as shown below.



1. From Main Menu select 1. CONFIGURATION
2. From CONFIGURATION Submenu select 3. LOAD SW ASSIGN

LD SWITCH ASSIGN								
	PHASE		DIMMING				---FLASH---	
	/OVLP	TYPE	R	Y	G	D	PWR	AUT TGR
→	1	1	V	.	.	.	+	A R X
→	2	2	V	.	.	.	+	A Y .
	3	3	V	.	.	.	+	A R X
	4	4	V	.	.	.	+	A R .
→	5	5	V	.	.	.	-	A R .
	6	6	V	.	.	.	-	A Y X
	7	7	V	.	.	.	-	A R .
	8	8	V	.	.	.	-	A R X
	9	2	P	.	.	.	+	A R X
	10	4	P	.	.	.	+	A R X
	11	6	P	.	.	.	-	A R .
	12	8	P	.	.	.	-	A R .
	13	1	O	.	.	.	+	A . .
	14	2	O	.	.	.	-	A . .
	15	3	O	.	.	.	+	A . .
	16	4	O	.	.	.	-	A . .

THIS ELECTRICAL DETAIL SUPERSEDES  
THE DETAIL SEALED ON 8/1/2019.

THIS ELECTRICAL DETAIL IS FOR  
THE SIGNAL DESIGN: 05-1168T3  
DESIGNED: September 2019  
SEALED: 10/2/2019  
REVISED: N/A

Electrical Detail - Temp Design 3 (TMP Phase III, Step B)  
Sheet 3 of 3

<p>ELECTRICAL AND PROGRAMMING DETAILS FOR:</p> <p style="text-align: center;">Prepared In the Offices of:</p>  <p style="font-size: 8px;">750 N. Greenfield Pkwy, Garner, NC 27529</p>	<p><b>SR 3015 (Airport Boulevard)</b> at <b>I-40 WB Ramps</b></p> <p>Division 5      Wake County      Morrisville</p> <p>PLAN DATE: October 2019      REVIEWED BY:</p> <p>PREPARED BY: S. Armstrong      REVIEWED BY:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>REVISIONS</th> <th>INIT.</th> <th>DATE</th> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>	REVISIONS	INIT.	DATE							<p style="text-align: center; font-weight: bold;">DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED</p> <p style="text-align: center;">SEAL</p>  <p style="font-size: 8px;">DocuSigned by: <b>Ryan W. Hough</b>      10/8/2019 DATE</p> <p style="font-size: 8px;">SIG. INVENTORY NO. 05-1168T3</p>
REVISIONS	INIT.	DATE									