UTILITY CONSTRUCTION

GENERAL NOTES:

- 1. THE PROPOSED UTILITY CONSTRUCTION
 SHALL MEET THE APPLICABLE REQUIREMENTS
 OF THE NC DEPARTMENT OF
 TRANSPORTATION'S "STANDARD
 SPECIFICATIONS FOR ROADS AND
 STRUCTURES" DATED JANUARY 2018 AND THE
 SPECIAL PROVISIONS TO NCDOT
 SPECIFICATION DIVISION 15.
- 2. FAYETTEVILLE PWC OWNS AND OPERATES THE EXISTING WATER AND SEWER UTILITIES EXCEPT FOR THE WATER UTILITIES IDENTIFIED AS AQUA AMERICA.
- 3. ALL WATER LINES TO BE INSTALLED
 WITHIN COMPLIANCE OF THE RULES AND
 REGULATIONS OF THE NORTH CAROLINA
 DEPARTMENT OF ENVIRONMENTAL QUALITY,
 DIVISION OF WATER RESOURCES, PUBLIC
 WATER SUPPLY SECTION. ALL SEWER LINES
 TO BE INSTALLED WITHIN COMPLIANCE OF
 THE RULES AND REGULATIONS OF THE NORTH
 CAROLINA DEPARTMENT OF ENVIRONMENT
 QUALITY, DIVISION OF WATER RESOURCES,
 WATER QUALITY SECTION. PERFORM ALL WORK
 IN ACCORDANCE WITH THE APPLICABLE
 PLUMBING CODES.
- 4. FAYETTEVILLE PWC OWNS THE EXISTING UTILITY FACILITIES AND WILL OWN THE NEW UTILITY FACILITIES AFTER ACCEPTANCE BY THE DEPARTMENT. THE DEPARTMENT OWNS THE CONSTRUCTION CONTRACT AND HAS ADMINISTRATIVE AUTHORITY. COMMUNICATIONS AND DECISIONS BETWEEN THE CONTRACTOR AND UTILITY OWNER ARE NOT BINDING UPON THE DEPARTMENT OR THIS CONTRACT UNLESS AUTHORIZED BY THE ENGINEER. AGREEMENTS BETWEEN THE UTILITY OWNER AND CONTRACTOR FOR THE WORK THAT IS NOT PART OF THIS CONTRACT OR IS SECONDARY TO THIS CONTRACT ARE ALLOWED, BUT ARE NOT BINDING UPON THE DEPARTMENT.
- 5. THE CONTRACTOR SHALL PROVIDE ACCESS
 FOR THE DEPARTMENT PERSONNEL AND THE
 OWNER'S REPRESENTATIVES TO ALL PHASES
 OF CONSTRUCTION. NOTIFY DEPARTMENT
 PERSONNEL AND THE UTILITY OWNER TWO
 WEEKS PRIOR TO COMMENCEMENT OF ANY WORK
 AND ONE WEEK PRIOR TO SERVICE
 INTERRUPTION. KEEP UTILITY OWNERS'
 REPRESENTATIVES INFORMED OF WORK
 PROGRESS AND PROVIDE OPPORTUNITY FOR
 INSPECTION OF CONSTRUCTION AND TESTING.
- 6. MAKE FINAL CONNECTIONS OF THE NEW WORK TO THE EXISTING SYSTEM WHERE INDICATED ON THE PLANS, AS REQUIRED TO FIT THE ACTUAL CONDITIONS, OR AS DIRECTED.

- 7. THE PLANS DEPICT THE BEST AVAILABLE INFORMATION FOR THE LOCATION, SIZE, AND TYPE OF MATERIAL FOR ALL EXISTING UTILITIES. MAKE INVESTIGATIONS FOR DETERMINING THE EXACT LOCATION, SIZE, AND TYPE MATERIAL OF THE EXISTING FACILITIES AS NECESSARY FOR THE CONSTRUCTION OF THE PROPOSED UTILITIES AND FOR AVOIDING DAMAGE TO EXISTING FACILITIES. REPAIR ANY DAMAGE INCURRED TO EXISTING FACILITIES TO THE ORIGINAL OR BETTER CONDITION AT NO ADDITIONAL COST TO THE DEPARTMENT.
- 8. MAKE CONNECTIONS BETWEEN EXISTING AND PROPOSED UTILITIES AT TIMES MOST CONVENIENT TO THE PUBLIC, WITHOUT ENDANGERING THE UTILITY SERVICE, AND IN ACCORDANCE WITH THE UTILITY OWNER'S REQUIREMENTS. MAKE CONNECTIONS ON WEEKENDS, AT NIGHT, AND ON HOLIDAYS IF NECESSARY.
- 9. ALL UTILITY MATERIALS SHALL BE APPROVED PRIOR TO DELIVERY TO THE PROJECT. SEE 1500-7, "SUBMITTALS AND RECORDS" IN SECTION 1500 OF THE STANDARD SPECIFICATIONS.
- 10. PRIOR TO PLACEMENT OF PROPOSED SANITARY GRAVITY SEWER THE CONTRACTOR SHALL LOCATE ALL EXISTING SEWER SERVICE LATERALS (DEPTH AND PIPE DIAMETER) AND NOTIFY THE RESIDENT ENGINEER IF THERE ARE COMPLICATIONS WITH CONNECTING TO THE PROPOSED SANITARY GRAVITY SEWER. THE CONTRACTOR'S COST FOR ALL WORK ASSOCIATED WITH SEWER SERVICES, IS INCIDENTAL TO SEWER SERVICE PAYMENT ITEM.
- 11. PRIOR TO PLACEMENT OF PROPOSED
 WATERLINE THE CONTRACTOR SHALL LOCATE
 ALL EXISTING WATER SERVICE LATERALS
 (DEPTH AND PIPE DIAMETER) AND NOTIFY
 THE RESIDENT ENGINEER IF THERE ARE
 COMPLICATIONS WITH CONNECTING TO THE
 PROPOSED WATERLINE. THE CONTRACTOR'S
 COST FOR ALL WORK ASSOCIATED WITH WATER
 SERVICES, IS INCIDENTAL TO WATER
 SERVICE PAYMENT ITEM.
- 12. THE CONTRACTOR SHALL REFER TO THE "UTILITIES BY OTHERS" PLANS FOR PROPOSED GAS, TELECOMMUNICATIONS, AQUA AMERICA WATER, AND POWER UTILITY RELOCATIONS.

PROJECT SPECIFIC NOTES:

- 1. ALL PROPOSED WATER LINE 2" IN DIAMETER SHALL BE SDR21, PRESSURE CLASS 200 IN ACCORDANCE WITH ASTM D 2241 OR SDR-17 WITH A PRESSURE RATING OF 250 PSI, IN ACCORDANCE WITH ASTM D-224. ALL PROPOSED WATER LINE 4"-12" IN DIAMETER SHALL BE DI (DUCTILE IRON PUSH-ON) PC 350 PIPE, UNLESS SPECIFIED TO BE RESTRAINED JOINT PIPE AND/OR SPECIAL THICKNESS CLASS AS SHOWN ON THE PLAN/PROFILE. ALL PROPOSED WATERLINE LINE 16" IN DIAMETER AND LARGER SHALL BE DI (DUCTILE IRON PUSH-ON) PC 250 PIPE, UNLESS SPECIFIED TO BE RESTRAINED JOINT PIPE AND/OR SPECIAL THICKNESS CLASS AS SHOWN ON THE PLAN/PROFILE.
- 2. ALL PROPOSED GRAVITY SEWER LINES 12"
 IN DIAMETER AND SMALLER SHALL BE
 CERAMIC EPOXY LINED DI (DUCTILE IRON
 PUSH ON) PC 350 PIPE UNLESS OTHERWISE
 SPECIFIED. ALL PROPOSED GRAVITY SEWER
 LINES 16" IN DIAMETER AND GREATER SHALL
 BE CERAMIC EPOXY LINED DI (DUCTILE IRON
 PUSH ON) PC 250, UNLESS OTHERWISE
 SPECIFIED.
- 3. CONTRACTOR'S ATTENTION IS DIRECTED TO SECTIONS 102, 107, AND 1550 OF THE STANDARD SPECIFICATIONS CONCERNING TRENCHLESS INSTALLATION. IT IS CONTRACTOR'S RESPONSIBILITY TO HAVE BORE DESIGNED AND SEALED BY A LICENSED NORTH CAROLINA PROFESSIONAL ENGINEER. NO DAMAGE IS ALLOWED TO RIVER, WETLANDS, OR BUFFER ZONES.
- 4. IF HDPE PIPE IS INSTALLED BY DIRECTIONAL DRILL. IT SHALL BE FILLED WITH WATER AND NOT BE CONNECTED TO ANY OTHER PIPE OR FITTINGS FOR ONE WEEK FROM THE TIME OF INSTALLATION.
- 5. ALL CONSTRUCTION TO BE IN ACCORDANCE WITH ALL FAYETTEVILLE PWC AND/OR NCDOT STANDARDS AND SPECIFICATIONS.
- 6. TEMPORARY SHORING IF REQUIRED FOR BUILDING FOUNDATION PROTECTION OR MAINTENANCE OF TRAFFIC WILL BE PAID AS TEMPORARY SHORING IN SQUARE FEET BELOW GROUND SURFACE. THIS REQUIREMENT IS APPLICABLE TO ALL UTILITY CONSTRUCTION SHEETS.

T NOOLCT TILL LINEINGL	110.	5
U-4405		UC-3
DESIGNED BY: AMH		
DRAWN BY: AMH/AB		
CHECKED BY: AMH		
APPROVED BY: BRO		
REVISED:		
NORTH CAROLINA DEPARTMENT OF TRANSPORTATION		
UTILITIES ENGINEERING SEC. PHONE: (919)707-6690 FAX: (919)250-4151	UTILI	TY CONSTRUCTION PLANS ONLY

UTILITY CONSTRUCTION

DOCUMENT NOT CONSIDERED FINAL UNTIL ALL SIGNATURES ARE COMPLETED

- 7. UTILITY CONSTRUCTION NOTE SHEETS PROVIDE SEQUENCE OPTIONS FOR THE CRITICAL INSTALLATIONS AND KILL OUTS OF THE PROPOSED WATER AND SEWER LINES. CONTRACTOR SHALL PROVIDE A CONSTRUCTION SEQUENCE FOR ALL WATER LINE AND SEWER LINE SEGMENTS AND KILLOUTS PRIOR TO INSTALLATION FOR REVIEW AND APPROVAL BY ENGINEER. CONTRACTOR SHALL UPDATE CONSTRUCTION SEQUENCES WHERE ACTUAL CONDITIONS REQUIRE AJDUSTMENTS OR ALTERATIONS TO THE PLANNED WORK. CONSTRUCTION SEQUENCE OPTIONS THAT ARE PROVIDED ARE INTENDED TO MINIMIZE IMPACTS TO WATER AND SEWER OPERATIONS. INSTALLATION SHALL NOT BEGIN UNTIL AN APPROVED SEQUENCE PLAN IS IN PLACE.
- 8. ALL EXISTING VALVES, AIR RELEASE VALVES, FIRE HYDRANTS AND MANHOLE RING AND COVERS TO BE REMOVED SHALL BE RETURNED TO PWC
- 9. SEE PROFILE SHEETS FOR REFERENCE TO PIPE MATERIALS AND VALVE TYPES.