



\$\$\$\$\$\$\$\$Y\$TIME\$\$\$\$\$ \$\$\$\$\$\$\$\$\$\$\$\$\$\$ \$\$\$\$!IGFRNAMF**\$\$\$**

PROJECT TYPICAL DETAILS (SOUTHERN PINES)

<u>NOTE:</u> FITTING SHALL BE NO CONCRETE SHA	WRAPPED WITH LL COVER BOLI	A MINIMUM 4 I S OR GLANDS.	MIL PLASTIC,			
			A'12A'72			
	MIMIMUM DIMENSION A (IN FEET)					
	NOM. PIPE DIA. IN.	TEES & DEAD ENDS	90° BEND	45° BEND	22–1/2° BEND	11–1/4 BEND
	2	1.6	1.5	1.0	0.8	0.8
	4	1.9	1.9	1.4	1.0	1.0
	6	2.8	2.8	2.1	1.5	1.1
	8	3.8	3.8	2.8	2.0	1.5
	10	4.7	4.7	3.5	2.5	1.8
	12	5.9	5.9	4.3	3.1	2.2
	14	6.6	7.5	5.5	4.0	2.2
	16	7.5	7.5	5.5	4.0	2.2
	18	8.5	8.5	6.2	4.5	3.2
	20	9.4	9.4	6.9	4.9	3.6
NOT TO SCALE	* CONCRETE S	SHALL BE 2500	P.S.I. MIX.			
TOWN OF SOUTHERN PINES CONCRETE THURST BLOCK						

IOWN OF SOUTHERN PINES JANUARY 2009

DETAIL







