



NOTES

- 1. CONTRACTOR IS RESPONSIBLE FOR FURNISHING ELEVATION DRAWINGS FOR ENGINEER'S APPROVAL.
- 2. PROVIDE A FIXED LADDER LEADING TO THE ACCESS PLATFORM.
- 3. EQUIP THE LADDER WITH A SECURITY COVER (LADDER GUARD).
 START THE FIRST LADDER RUNG NO MORE THAN 18 INCHES ABOVE A CONCRETE LANDING PAD. DESIGN RUNGS ON 12 INCH CENTER-TO-CENTER TYPICAL SPACING.
- 4. INSTALL A CONCRETE LANDING PAD MEASURING A MINIMUM 4 INCHES DEEP, 24 INCHES WIDE, AND 36 INCHES LONG DIRECTLY BENEATH THE LADDER.
- 5. USE ACTUAL DIMENSIONS AND WEIGHT OF THE DMS TO COMPLETE THE DESIGN OF THE DMS STRUCTURE.
- 6. FIELD VERIFY ALL FOOTING ELEVATIONS AND GROUND SLOPES AT THE FOOTING USING THE LATEST NCDOT STANDARD SPECIFICATIONS FOR ROADS AND STRUCTURES.
- 7. ENSURE THAT THE TOP OF THE FOOTING EXTENDS AT LEAST 6 INCHES AND NOT MORE THAN 24 INCHES ABOVE THE HIGHEST POINT OF THE GROUND SURFACE AT THE FOOTING.
- 8. VERIFY ALL UNDERGROUND UTILITY LOCATIONS BEFORE BEGINNING ANY UNDERGROUND WORK. DO NOT DAMAGE ANY EXISTING UTILITIES OR NCDOT CABLES DURING CONSTRUCTION.
- 9. DESIGN THE STRUCTURE AND DMS ENCLOSURE TO WITHSTAND WIND VELOCITIES OF 90 MPH.
- 10. SEE ROADWAY PLANS FOR GUARDRAIL DETAILS.





N/A

Prepared in the Offices of:

ELEVATION DETAIL

DIVISION 09 FORSYTH CO. WINSTON-SALEM

PLAN DATE: AUGUST 2021 REVIEWED BY: A. SKUCE 750 N. Greenfield Pkwy., Garner, NC 27529 PREPARED BY: B. CHRISTIAN REVIEWED BY: REVISIONS INIT. DATE

050152 AND ANGINEER SKILL