



## SECTION B-B

JOINT REPAIR QUANTITY TABLE			
	BRIDGE JOINT DEMOLITION	FOAM JOINT SEALS FOR PRESERVATION	ELASTOMERIC CONCRETE FOR PRESERVATION
BENT 1	110.0 SQ.FT.	112 <b>.</b> 3 LF	27.5 CU.FT.
BENT 2	110.0 SQ.FT.	112 <b>.</b> 3 LF	27 <b>.</b> 5 CU.FT.
BENT 3	110.0 SQ.FT.	112 <b>.</b> 3 LF	27.5 CU.FT.
BENT 4	110.0 SQ.FT.	112 <b>.</b> 3 LF	27.5 CU.FT.
* TOTAL	440.0 SQ.FT.	449 <b>.</b> 2 LF	110.0 CU.FT.

\*BASED ON THE MINIMUM BLOCKOUT SHOWN.



JOINT SEAL DETAILS



MEDIAN DETAIL

FOAM JOINT SEAL SHALL BE FACTORY
FORMED OR CUT, HEAT WELDED AND TURNED
UP PARALLEL TO FACE OF MEDIAN.

NOTE

THE CONTRACTOR SHALL FIELD VERIFY THE EXISTING JOINT OPENING PRIOR TO ORDERING JOINT SEAL MATERIAL. IF ACTUAL JOINT OPENING VARIES FROM THE OPENING INDICATED IN DETAIL BY MORE THAN 1/4", NOTIFY ENGINEER. REVISION TO THE JOINT SEAL SIZE MIGHT BE NECESSARY.

FINAL JOINT SEALS SHALL NOT BE INSTALLED UNTIL THE LMC-VES OVERLAY IS COMPLETE.

THE CONTRACTOR SHALL TAKE CARE DURING JOINT REHAB OPERATIONS NOT TO DROP ANY MATERIAL BELOW THE BRIDGE WITHOUT PROTECTIVE DEVICES BELOW TO CATCH THE MATERIAL. ANY MATERIAL THAT FALLS BELOW THE BRIDGE SHALL BE CONTAINED, REMOVED AND DISPOSED OF BY THE CONTRACTOR AT NO EXTRA COST TO THE DEPARTMENT. IF THE ENGINEER DETERMINES THAT THE PROTECTIVE DEVICES ARE NOT ADEQUATE OR NOT BEING EMPLOYED, THE WORK SHALL BE SUSPENDED UNTIL ADEQUATE PROTECTION IS PROVIDED.

THE CONTRACTOR WILL NOT BE PERMITTED TO FORM THE JOINTS IN LIEU OF SAWING THE JOINT.

DURING THE JOINT INSTALLATION PROCEDURE, THE JOINT AND SURROUNDING AREA SHALL BE KEPT CLEAN AND FREE OF DEBRIS.

FOR FOAM JOINT SEALS FOR PRESERVATION, SEE SPECIAL PROVISIONS.

THE MANUFACTURER IS TO RECOMMEND AND PROVIDE THE NOMINAL UNCOMPRESSED SEAL WIDTH OF THE FOAM JOINT SEAL FOR THE SIZE OF THE OPENING ON THE PLANS AND ACCOMMODATE THE MINIMUM EXPANSION SHOWN ON THE PLANS.

A MANUFACTURER'S CERTIFIED TRAINED REPRESENTATIVE SHALL BE PRESENT DURING THE INSTALLATION OF THE FIRST JOINT OF THE PROJECT, OR UNTIL THE ENGINEER IS SATISFIED WITH THE INSTALLATION PROCESS.

THE INSTALLATION OF THE JOINT SEAL SHALL BE WATERTIGHT.

FINAL SURFACE OF THE JOINT DEMOLITION AREA PRIOR TO PLACEMENT OF CONCRETE REPAIR MATERIAL OR ELASTOMERIC CONCRETE SHOULD BE REASONABLY FLAT AND LEVEL. ENGINEER SHALL DETERMINE THE ACCEPTABILITY OF THE SURFACE PRIOR TO PLACEMENT OF REPAIR CONCRETE.

PROJECT NO. 15BPR.55

FORSYTH COUNTY
BRIDGE NO. 330227

SHEET 2 OF 2

01/26/2022

SEAL 031583

CHCINEER

Krishna P. Sedai

STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
RALETGH

JOINT DETAILS

REVISIONS SHEET NO SOLUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED 2 A 79

DRAWN BY: A. SORSENGINH DATE: 12/2020
CHECKED BY: M. G. SHAIKH DATE: 7/2021