Dewberry

PROJECT REFERENCE NO. DESIGNED BY:

> DRAWN BY: CHECKED BY:

REVISED:

APPROVED BY:

UC-3A B-5318 NORTH CAROLINA DEPARTMENT OF TRANSPORTATION UTILITIES ENGINEERING SEC PHONE: (919)707-6690 UTILITY CONSTRUCTION FAX: (919)250-4151 PLANS ONLY

SHEET NO.

UTILITY CONSTRUCTION

SITE PERMITTING APPROVAL

Water and Sewer Permits (If applicable)

The City of Raleigh consents to the connection and extension of the City's Public Sewer System as shown on this plan. The material and Construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook. City of Raleigh Public Utilities Department Permit # S-4929

The City of Raleigh consents to the connection and extension of the City's Public Water System as shown on this plan. The material and Construction methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook. City of Raleigh Public Utilities Department Permit # W-3587


The City of Raleigh consents to the connection to its public sewer system and extension of the private sewer collection system as shown on this plan. The material and constructions methods used for this project shall conform to the standards and specifications of the City's Public Utilities Handbook.


City of Raleigh Public Utilities Department Permit # ____N/A


CITY OF RALEIGH - PLANS AUTHORIZED FOR CONSTRUCTION


Plans for the proposed use have been reviewed for general compliance with applicable codes. This limited review, and authorization for construction is not to be considered to represent total compliance with all legal requirements for development and construction. The property owner, design consultants, and contractors are each responsible for compliance with all applicable City, State and Federal laws. This specific authorization below is not a permit, nor shall it be construed to permit any violation of City, State or Federal Law. All Construction must be in accordance with all Local, State, and Federal Rules and Regulations.


Electronic Approval: This approval is being issued electronically. This approval is valid only upon the signature of a City of Raleigh Review Officer below. The City will retain a copy of the approved plans. Any work authorized by this approval must proceed in accordance with the plans kept on file with the City. This electronic approval may not be edited once issued. Any modification to this approval once issued will invalidate this approval.











CLASS I, II, OR III MATERIAL

UNDISTURBED

DENSELY COMPACTED

BACKFILL, TAMPED IN 6"

LIFTS

CITY OF RALEIGH

DEPARTMENT OF PUBLIC UTILITIES

2.5' MIN.

PIPE SPRINGLINE -

6" MIN. / 12" MAX. WHEN NO TRENCH BOX-

REQUIRED (TYPICAL)

