	GROUNDWATER DEPTH BELOW BOTTOM OF REINFORCED ZONE (SEE NOTE 6 ON SHEET 2) (FT)	SHORING BACKFILL TYPE IN THE REINFORCED ZONE (SEE NOTE 7 ON SHEET 2)	H - WALL HEIGHT (FT)																								
SLOPE OR SURCHARGE CASE			< 4	5	6	7	8	9	10	//	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
SLOPE CASE	> 0	CLASS II,TYPE I, CLASS III,CLASS V OR CLASS VI SELECT MATERIAL	6	6	7	8	9	//	12	13	13	14	15	16	17	18	19	20	21	22	23	24	24	25	26	27	27
SURCHARGE CASE	> 0 TO 7 FOR H < 20° > 0 TO 10 FOR H ≥ 20°	ALL SHORING BACKFILL TYPES	6	7	7	8	8	9	9	10	//	//	12	12	13	14	14	15	<i>1</i> 6	17	17	18	19	19	20	21	22
	> 7 FOR H < 20° > 10 FOR H ≥ 20°	A-2-4 SOIL	6	6	7	8	8	9	9	10	//	//	12	12	13	14	14	15	16	16	17	18	18	19	20	20	21
		CLASS II,TYPE I OR CLASS III SELECT MATERIAL	6	6	7	7	8	8	9	10	10	11	//	12	12	13	14	15	15	16	16	17	17	18	18	19	20
		CLASS V OR CLASS VI SELECT MATERIAL	6	6	7	7	7	8	8	9	9	10	10	11	12	13	13	14	14	<i>1</i> 5	<i>1</i> 5	16	17	17	18	19	19

L – MINIMUM REQUIRED REINFORCEMENT LENGTH (FT) (FOR ALL REINFORCEMENT TYPES)

	Г	0.100,110								
	SHORING BACKFILL TYPE IN THE REINFORCED ZONE (SEE NOTE 7 ON SHEET 2)									
	SLOPE	CASE	SURCHARGE CASE							
REINFORCEMENT LAYER NUMBER*	CLASS II,TYPE I OR CLASS III SELECT MATERIAL	CLASS V SELECT MATERIAL	A-2-4 SOIL	CLASS II,TYPE I OR CLASS III SELECT MATERIAL	CLASS V SELECT MATERIAL					
1	2400	2400	2400	2400	2400					
2	2400	2400	2400	2400	2400					
3	2400	2400	2400	2400	2400					
4	2400	2400	2500	2400	2400					
5	2500	2400	3000	2400	2400					
6	3000	2400	3500	2800	2400					
7	3500	2700	4000	3200	2600					
8	4000	3100	4500	3600	2900					
9	4500	3500	5000	4000	3200					
Ю	5000	3900	5500	4400	3500					
//	5500	4300	6000	4800	3800					
12	6000	4700	6500	5200	4100					
13	6500	5/00	7000	5600	4400					
14	7000	5400	7500	6000	4700					
<i>1</i> 5	7500	5800	8000	6400	5000					
16	8000	6200	8500	6800	5300					
17	8500	6600	9000	7200	5600					
18	9000	7000	9500	7600	5900					
19	9500	7400	10000	8000	6200					
20	10000	7800	10500	8400	6500					

	SHORING BACKFILL TYPE IN THE REINFORCED ZONE (SEE NOTE 7 ON SHEET 2)								
	SLOPE	CASE	SURCHARGE CASE						
REINFORCEMENT LAYER NUMBER*	CLASS II,TYPE I OR CLASS III SELECT MATERIAL	CLASS V OR CLASS VI SELECT MATERIAL	A-2-4 SOIL	CLASS II,TYPE I OR CLASS III SELECT MATERIAL	CLASS V OR CLASS VI SELECT MATERIAL				
1	240	200	340	290	240				
2	380	310	520	430	350				
3	530	420	700	570	460				
4	690	550	870	720	570				
5	860	690	1050	860	680				
6	1030	830	1220	1000	790				
7	1200	970	1400	1150	900				
8	1370	IIIO	1580	1290	1010				
9	1550	1240	1750	1430	1120				
10	1720	1380	1930	1580	1230				
//	1890	1520	2100	1720	1340				
12	2060	1660	2280	1860	1450				
/3	2240	1800	2450	2010	/560				
14	2410	1940	2630	2/50	1670				
15	2580	2080	2800	2290	1780				
16	2750	2220	2980	2440	1890				
17	2930	2360	3160	2580	2000				
18	3100	2500	3330	2720	2110				
19	3270	2640	3510	2860	2220				
20	3440	2780	3690	3000	2330				

PROJECT REFERENCE	CE NO.	SHEET	NO.			
BR-0043		2G-4				
GEOTECHNICAL ENGINEER		ENGINEER				
THE CAROLAN						
SEAL 022246						
Scott a. Hidden 01/26/2023						
SIGNATURE DATE	SIGNAT	URE	DATE			
DOCUMENT NOT C UNLESS ALL SIGNA						

WALL HEIGHT (H) + WALL EMBEDMENT (FT)	NUMBER OF REINFORCEMENT LAYERS*
2.5 - 4	3
4 - 5.5	4
5.5 - 7	5
7 - 8.5	6
8 . 5 - 10	7
10 - 11.5	8
11.5 - 13	9
13 - 14.5	10
14.5 - 16	//
16 - 17.5	12
17.5 - 19	/3
<i>19 - 20.</i> 5	14
20.5 - 22	<i>1</i> 5
<i>22 - 23.</i> 5	16
<i>23.</i> 5 - <i>2</i> 5	17
<i>25 - 26.</i> 5	18
<i>26.</i> 5 - <i>28</i>	19
<i>28 - 29.</i> 5	20

*BASED ON VERTICAL REINFORCEMENT SPACING SHOWN ON SHEET 1.


GEOTEXTILE REINFORCEMENT
ULTIMATE TENSILE STRENGTH (LB/FT)

GEOGRID REINFORCEMENT
SHORT-TERM DESIGN STRENGTH (LB/FT)

(SEE NOTE 10 ON SHEET 2.)

MINIMUM REQUIRED REINFORCEMENT STRENGTH IN MD

(SEE NOTE 9 ON SHEET 2.)
*SEE PARTIAL ELEVATION ON SHEET 1
FOR REINFORCEMENT LAYER NUMBERING.



NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION
DIVISION OF HIGHWAYS

GEOTECHNICAL ENGINEERING UNIT STANDARD DETAIL NO. 1801.02

STANDARD TEMPORARY WALL SHEET 3 OF 3

DATE: 11-19-13