

INDEX OF SHEETS


SHEET NUMBER	SHEET
UC-1	TITLE SHEET
UC-2	INDEX OF SHEETS AND GENERAL NOTES
UC-3	UTILITIES PLAN SHEET SYMBOLS
UC-4	PLAN SHEET
UC-5	PLAN & PROFILE SHEET (WL-1 STA. 1+00 TO 10+00)
UC-6	PLAN & PROFILE SHEET (WL-1 STA. 10+00 TO 24+00)
UC-7	PLAN & PROFILE SHEET (WL-1 STA. 24+00 TO 34+00)
UC-8	PLAN & PROFILE SHEET (WL-2 STA. 1+00 TO 7+00)
UC-9	PLAN & PROFILE SHEET (WL-2 STA. 7+00 TO 21+00)
UC-10	PLAN & PROFILE SHEET (WL-2 STA. 21+00 TO 35+00)
UC-11	PLAN & PROFILE SHEET (WL-2 STA. 35+00 TO 47+00)
UC-12	PLAN & PROFILE SHEET (SS)
UC-13	PLAN & PROFILE SHEET (SS)
UC-14	PLAN & PROFILE SHEET (SS)
UC-15	DETAIL SHEET
UC-16	DETAIL SHEET

PROJECT SPECIFIC NOTES:

- ALL 12-INCH AND SMALLER DIAMETER PIPE SHALL BE DUCTILE IRON, PUSH-ON JOINT PRESSURE CLASS 350, UNLESS OTHERWISE NOTED ON THE UTILITY CONSTRUCTION PLANS.
- ALL 16-INCH AND LARGER DIAMETER PIPE SHALL BE DUCTILE IRON, PUSH-ON JOINT PRESSURE CLASS 250 UNLESS OTHERWISE NOTED ON THE UTILITY CONSTRUCTION PLANS.
- VALVES ON WATER MAINS SMALLER THAN 20-INCH IN DIAMETER SHALL BE DIRECT BURY GATE VALVES, UNLESS OTHERWISE NOTED ON THE UTILITY CONSTRUCTION PLANS.
- WALL BLOCKING SHALL BE USED ON EXISTING WATER LINES AT PROPOSED RELOCATION TIE-IN POINTS.
- CONTRACTOR SHALL CONNECT ALL WATER LINES AND SERVICE CONNECTIONS USING NECESSARY FITTINGS.
- ALL BACKFLOW PREVENTORS ARE THE RESPONSIBILITY OF THE PROPERTY OWNER.
- FOR FIRE HYDRANTS TO BE REMOVED, THE CONTRACTOR SHALL COORDINATE WITH THE TOWN OF TARBORO TO DETERMINE A SUITABLE LOCATION TO STOCKPILE THE FIRE HYDRANTS AND ASSOCIATED ITEMS.
- CONTRACTORS ATTENTION IS DIRECTED TO SECTIONS 102, 107, AND 1550 OF THE NCDOT STANDARD SPECIFICATIONS CONCERNING TRENCHLESS INSTALLATION. IT IS CONTRACTOR'S RESPONSIBILITY TO HAVE BORE DESIGNED AND SEALED BY A LICENSED NORTH CAROLINA PROFESSIONAL ENGINEER. NO DAMAGE IS ALLOWED TO RIVER, WETLANDS, OR BUFFER ZONES.
- EXISTING SANITARY SEWER MANHOLES ARE TO BE EVALUATED AT THE TIME OF CONSTRUCTION, BY A STRUCTURAL ENGINEER, REGISTERED IN THE STATE OF NORTH CAROLINA, TO DETERMINE IF FULL REPLACEMENT OF THE STRUCTURE IS REQUIRED FOR IT TO SUPPORT ANTICIPATED LIVE LOADS. IF THE EXISTING STRUCTURE IS DEEMED STRUCTUALLY ADEQUATE, THE PROPOSED REPLACEMENT MANHOLE CAN BE OMITTED.

GENERAL UTILITY NOTES:

- ALL WATER AND SEWER CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE TOWN OF TARBORO STANDARD DETAILS AND SPECIFICATIONS AND NCDOT UTILITY STANDARDS.
- EXISTING UNDERGROUND UTILITIES SHOWN IN PROFILES ARE SHOWN APPROXIMATE UNLESS TEST HOLE INFORMATION IS PROVIDED.
- EXISTING UTILITIES ARE ILLUSTRATED FOR INFORMATION PURPOSES ONLY. NCDOT WILL NOT BE HELD RESPONSIBLE FOR THE ACCURACY OF UTILITY LOCATIONS, SIZES, DEPTHS, OR THE COMPLETENESS OF UTILITY INFORMATION. CONTRACTOR IS RESPONSIBLE FOR VERIFYING ALL UTILITY INFORMATION.
- CONTRACTOR IS RESPONSIBLE FOR COORDINATING ALL INTERRUPTION OF WATER SERVICE WITH AFFECTED BUSINESSES, RESIDENTS, AND CHARLOTTE WATER AT LEAST 72 HOURS PRIOR TO THE PLANNED INTERRUPTION OF SERVICE.
- CONTRACTOR SHALL PHASE WATER UTILITY CONSTRUCTION TO MINIMIZE THE FREQUENCY AND DURATION OF WATER SERVICE INTERRUPTIONS. CONTRACTOR IS RESTRICTED TO WORKING ON INDIVIDUAL 12" AND LARGER WATERMANS, ONE AT A TIME. NO TWO WATERMANS, 12" AND LARGER, MAY BE SHUT DOWN CONCURRENTLY W/O TOWN OF TARBORO APPROVAL.
- CONTRACTOR SHALL PERFORM WATER LINE ACCEPTANCE TESTING IN ACCORDANCE WITH THE RESPECTIVE OWNER, AND NCDENR (DIVISION OF ENVIRONMENTAL HEALTH, PUBLIC WATER SUPPLY SECTION) REQUIREMENTS.
- PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY ALL UTILITY OWNERS WHOSE FACILITIES WILL BE AFFECTED TO DETERMINE UTILITY LOCATIONS. CONTRACTOR IS RESPONSIBLE FOR LOCATING ALL EXISTING WATER AND SANITARY SEWER SERVICES AND ENSURING THAT ALL EXISTING SERVICES, WITH THE LIMITS OF THE PROPOSED WATER AND SANITARY SEWER RELOCATION, ARE RECONNECTED TO THE NEW MAINS.
- CONTRACTOR IS RESPONSIBLE FOR LOCATING ALL EXISTING UTILITIES PRIOR TO START OF CONSTRUCTION.
- CONTRACTOR SHALL PROTECT ALL UTILITIES FROM DAMAGE CAUSED BY HIS OPERATIONS OR THOSE OF HIS AGENTS. CONTRACTOR SHALL HOLD THE NCDOT HARMLESS FOR ANY THIRD PARTY INCONVENIENCE CREATED BY WORK OF HIS OWN FORCES OR THAT OF HIS AGENTS.
- CONTRACTOR SHALL ADJUST VALVE BOXES, MANHOLES, AND OTHER UTILITIES TO THE FINISHED GRADE, AS NECESSARY.
- THE CONTRACTOR SHALL NOTE THAT GRAPHICAL REPRESENTATIONS OF VALVE, TEE, HYDRANT, METER, ETC, LOCATIONS SHOWN IN PLANS ARE APPROXIMATE ONLY.
- EXISTING WATER METERS SHALL BE RELOCATED AS SHOWN IN THE PLANS WHERE FEASIBLE; OTHERWISE, NEW METERS SHALL BE INSTALLED.
- INDIVIDUAL WATER AND SEWER SERVICE CONNECTIONS ARE SHOWN APPROXIMATELY. FINAL SERVICE CONNECTION LOCATIONS SHALL BE DETERMINED IN THE FIELD AND PROVIDED ON AS-BUILT PLANS FOR RECORD. ALL WATER AND SEWER SERVICES SHALL BE INSTALLED PER THE RESPECTIVE TOWN/MUNICIPAL STANDARDS, NCDOT UTILITY STANDARDS, AS WELL AS NCDENR REQUIREMENTS.
- RELOCATED OR ADJUSTED WATER SERVICES, SEWER LATERALS, BACKFLOW UNITS, AND OTHER APPURTENANCES, SHALL COMPLY WITH TOWN STANDARDS, NC PLUMBING CODE, AND EDGEcombe COUNTY BUILDING INSPECTION PERMITS. BACKFLOW UNITS SHALL BE RECERTIFIED BY A LICENSED CERTIFIED BACKFLOW TECHNICIAN AND REPORTS SHALL BE SUBMITTED TO THE TOWN'S BACKFLOW ADMINISTRATOR. ALL EXISTING WATER SERVICE THAT ARE NOT COPPER, MUST BE ENTIRELY REPLACED FROM NEW MAIN TO NEW/EXISTING METER.
- CONTRACTOR SHALL OBTAIN ELEVATIONS OF EXISTING WATER AND SEWER PIPES AND NOTE EXISTING MATERIAL TYPE AT ALL PROPOSED CROSSINGS. ELEVATIONS AND MATERIALS SHALL BE PROVIDED IN AS-BUILT PLANS FOR RECORD WHERE REQUIRED VERTICAL SEPARATION CANNOT BE MET.
- THE UTILITY OWNER OWNS THE EXISTING UTILITY FACILITIES AND WILL OWN THE NEW UTILITY FACILITIES AFTER ACCEPTANCE BY THE DEPARTMENT. THE DEPARTMENT OWNS THE CONSTRUCTION CONTRACT AND HAS ADMINISTRATIVE AUTHORITY.
- MAINTAIN ON-SITE A FULL SET OF PROJECT DRAWINGS FOR PURPOSE OF RECORDING AS-CONSTRUCTED CONDITIONS.
- INFORMATION SHOULD BE LEGIBLY RECORDED AS CONSTRUCTION PROGRESSES.
- CLEARLY AND COMPLETELY IDENTIFY AND FIELD CHANGES FROM THE ORIGINAL DRAWINGS.
- THE DEPTH OF ALL FORCE MAINS SHALL BE RECORDED AT ALL ROADWAYS, WATERWAY CROSSINGS, UTILITIES CROSSINGS AND ALL OTHER AREAS AS NEEDED TO ACCURATELY DEFINE THE VERTICAL LOCATION OF THE FORCE MAIN. A MINIMUM OF ONE DEPTH SHALL BE RECORDED ON EACH 100 FEET OF PIPE INSTALLED. DEPTH SHALL BE REFERENCED TO FINISHED SURFACE GRADES.
- SHOW HORIZONTAL AND VERTICAL LOCATION OF ANY LOCATION OF ANY EXISTING UNDERGROUND UTILITIES ENCOUNTERED DURING CONSTRUCTION.
- SUBMIT DOCUMENT TO THE TOWN PRIOR TO FINAL ACCEPTANCE.

PROJECT REFERENCE NO.	SHEET NO.
U-4424	UC-2
RW SHEET NO.	
ROADWAY DESIGN ENGINEER	HYDRAULICS ENGINEER
	
DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED	