



NOTES:

MORTAR JOINTS 1/2" TO 1/4" THICK.
 USE CLASS "B" CONCRETE THROUGHOUT.
 USE TYPE "E", "F" AND "G" GRATES UNLESS OTHERWISE INDICATED.
 USE BRICK OR CONCRETE BLOCK WHICH COMPLIES WITH THE REQUIREMENTS
 OF SECTION 840 OF THE STANDARD SPECIFICATIONS.
 CHAMFER ALL EXPOSED CORNERS 1".
 DRAWING NOT TO SCALE.
 PROVIDE ALL CATCH BASINS OVER 3'-6" IN DEPTH WITH STEPS 12"
 ON CENTER. USE STEPS WHICH COMPLY WITH STD. DRAWING 840.66

5/16/2023 9:01:59 AM RDY_PSH02C-6.dgn
 11:32:58 PM



5/18/2023

DOCUMENT NOT CONSIDERED FINAL
UNLESS ALL SIGNATURES COMPLETED

CONTRACT STANDARDS AND DEVELOPMENT UNIT	
Office 919-707-6950 FAX 919-250-4119	
PROPOSED OFFSET CATCH BASIN	
ORIGINAL BY: _____	DATE: _____
MODIFIED BY: _____	DATE: _____
CHECKED BY: _____	DATE: _____
FILE SPEC.: _____	