

SEE SHEET UC-14
FOR WATER LINE 1 PROFILE

5' OF 18" WATER LINE
(DI RJ, PC 250)

703' OF 24" WATER LINE
(DI RJ, PC 250)

347' OF 48" ENCASEMENT PIPE
347' BORE AND JACK OF 48" STEEL
(STEEL ENCASEMENT, 0.625" THICK)

MATCHLINE -Y WB- STA 18+50 - SEE SHEET UC-7

4' OF 18" WATER LINE
(DI RJ, PC 250)

NOTE:
THE ESTIMATED QUANTITY OF DUCTILE IRON
WATER PIPE FITTINGS ON THIS PLAN SHEET
IS 9000 POUNDS. THE ACTUAL QUANTITY AND
TYPE OF FITTINGS WILL VARY BASED ON
FIELD CONDITIONS.

24" X 18" REDUCER

1-24" VALVE
(BV, 250# WP)

765' OF ABANDON 18" UTILITY PIPE

36" OF 2" WATER LINE
(PVC RJ, SDR 21)

1-24" VALVE
(BV, 250# WP)

24" X 18" REDUCER

HINDE ENGINEERING
License No. C-2639
401 Harrison Oaks Blvd., Suite 220 Cary, NC 27513

**DOCUMENT NOT CONSIDERED FINAL
UNLESS ALL SIGNATURES COMPLETED**

PROJECT REFERENCE NO. I-2513 AA/AB	SHEET NO. UC-8
DESIGNED BY: JKC	
DRAWN BY: JKC	
CHECKED BY: CLS	
APPROVED BY: CDB	
REVISED:	
NORTH CAROLINA DEPARTMENT OF TRANSPORTATION	
UTILITIES ENGINEERING SECTION	
PHONE: (919) 707-6690	UTILITY CONSTRUCTION PLANS ONLY
FAX: (919) 250-4151	

UTILITY CONSTRUCTION

