



NOTES

1. BOND CLASS II, 28 STRAND (MINIMUM), 15 AWG (MINIMUM) ROPE-LAY BARE COPPER CONDUCTOR TO THE MAIN GROUND ROD BY AN IRREVERSIBLE MECHANICAL CRIMP. MAINTAIN MAXIMUM HORIZONTAL SEPARATION BETWEEN COPPER CONDUCTOR AND RISER.
2. ALL CONNECTIONS TO GROUND RODS SHOULD BE MADE WITH AN IRREVERSIBLE MECHANICAL CRIMP METHOD.
3. REFER TO STANDARD DRAWING 1700-2 FOR ALTERNATE GROUND ROD INSTALLATION METHOD AS APPROVED BY THE ENGINEER.
4. INSTALL MARKER TAPE DIRECTLY ABOVE ALL GROUNDING ELECTRODES AND CONDUCTORS AT A DEPTH OF 12 INCHES.
5. REMOVE BONDING JUMPER BETWEEN EQUIPMENT CABINET GROUND BUSS AND NEUTRAL BUSS.

EXULT ENGINEERING
304-F W. Millbrook Rd
Raleigh, NC 27609
984.500.5425
www.exultengineering.com

Plans Prepared For:

250 N. Greenfield Place, Garner, NC 27529

CCTV CAMERA INSTALLATION FOR WOOD POLES WITH UNDERGROUND ELECTRICAL SERVICE

DIVISION 13 BUNCOMBE COUNTY ASHEVILLE

PLAN DATE: JANUARY 2024	REVIEWED BY: T. HONEYCUTT
PREPARED BY: M. STANLEY	REVIEWED BY: C. DAGERHARDT

REVISIONS	INIT.	DATE

SCALE: 0 NTS

SEAL

TAYLOR A. HONEYCUTT

SIGNATURE DATE