MAXTIME DETECTOR PROGRAMMING DETAIL FOR ALTERNATE PHASING LOOP 1A

Front Panel Main Menu >Controller >Detector >Veh Det Plans

Web Interface Home >Controller >Detector Configuration >Vehicle Detectors

In the table view of web interface right click on "Detector" in the top left corner of the table. Copy the entire contents of Detector Plan 1. Paste Detector Plan 1 into Detector Plan 2. Modify Detector Plan 2 as shown below and save changes.

Plan 2

	Detector	Call Phase	Delay	
1A	1	1	3	
	29	0	3	

MAXTIME OVERLAP PROGRAMMING DETAIL FOR DEFAULT PHASING

Front Panel Main Menu >Controller >Overlap >Overlap Parameters/Overlap Timings

Web Interface

Home >Controller >Overlap Configuration >Overlaps

Overlap Plan 1

Overlap	1	2	3	
Туре	FYA 4 - Section	-	-	
Included Phases	2	-	-	
Modifier Phases	1	-	-	
Modifier Overlaps	-	-	-	
Trail Green	0	0	0	
Trail Yellow	0.0	0.0	0.0	
Trail Red	0.0	0.0	0.0	

MAXTIME OVERLAP PROGRAMMING DETAIL FOR ALTERNATE PHASING

Front Panel


Web Interface Home >Controller >Overlap Configuration >Overlaps


In the table view of the web interface, right click on "Overlap" in the top left corner of the table. Copy the entire contents of Overlap Plan 1. Paste Overlap Plan 1 into Overlap Plan 2. Modify Overlap Plan 2 as shown below and save changes.

Overlap Plan 2

Overlap 1	1		
Type FYA 4 - S	e		
Included Phases -			
Modifier Phases 1			
Modifier Overlaps -			
Trail Green 0			
Trail Yellow 0.0			
Trail Red 0.0			


4 ---0 0.0 0.0





PROJECT REFERENCE NO.	SHEET NO.
U-5813	Sig. 22.2

Main Menu >Controller >Overlap >Overlap Parameters/Overlap Timings



THIS ELECTRICAL DETAIL IS FOR THE SIGNAL DESIGN: 08-0500 DESIGNED: AUGUST 2021 SEALED: 05/21/2024 REVISED:

Cianal Unarada Einal Da	a a la n					
Signal Upgrade - Final De Electrical Detail - Sheet 2	•					CONSIDERED FINAL
ELECTRICAL AND PROGRAMMING DETAILS FOR: Prepared for the Offices of:	US 64 Bus. (Dixie Dr)/N at		,		SEAL TH CAROLINA OR DEESSION 17	
NORTH CREEDING	I-73-US 220 SB/I-74 EB Division 8 Randolph County		3 Ramps Asheboro		0 Z SEAL 031464	
Still True	PLAN DATE:	August 2021	REVIEWED BY:	A.D. Klin	ksiek	ACINEER OT
	PREPARED BY:	N.K. Vlanich	REVIEWED BY:	N.R. Sim	mons	JAA R. SIMM
Signal Management		REVISIONS		INIT.	DATE	— DocuSigned by:
750 N. Greenfield Pkwy, Garner, NC 27529						<u>Natasha R Simmons</u> <u>5/21/2024</u> SIGNATURE DATE
						SIG. INVENTORY NO. 08-0500