

OVERLAP PROGRAMMING

Front Panel
Main Menu >Controller >Overlap >Overlap Parameters/Overlap Timings

Web Interface
Home >Controller >Overlap Configuration >Overlaps

Overlap Plan 1

Overlap	1	2	3	4
Type	FYA 4 - Section	OFF	FYA 4 - Section	Normal
Included Phases	2	-	6	4,5
Modifier Phases	1	-	5	-
Modifier Overlaps	-	-	-	-
Trail Green	0	0	0	0
Trail Yellow	0.0	0.0	0.0	0.0
Trail Red	0.0	0.0	0.0	0.0

FLASHER CIRCUIT MODIFICATION DETAIL

IN ORDER TO INSURE THAT SIGNALS FLASH CONCURRENTLY ON THE SAME APPROACH, MAKE THE FOLLOWING FLASHER CIRCUIT CHANGES:

1. ON REAR OF PDA - REMOVE WIRE FROM TERM. T2-4 AND TERMINATE ON T2-2.
2. ON REAR OF PDA - REMOVE WIRE FROM TERM. T2-5 AND TERMINATE ON T2-3.
3. REMOVE FLASHER UNIT 2.

THE CHANGES LISTED ABOVE TIES ALL PHASES AND OVERLAPS TO FLASHER UNIT 1.

OUTPUT CHANNEL CONFIGURATION

Front Panel
Main Menu >Controller >More>Channels>Channels Config

Web Interface
Home >Controller >Advanced IO>Channels>Channels Configuration

Channel Configuration

	Channel	Control Type	Control Source	Flash Yellow	Flash Red	Flash Alt	MMU Channel
	1	Phase Vehicle	1		X	X	1
NOTICE PHASE 2 FLASH RED →	2	Phase Vehicle	2		X		2
	3	Phase Vehicle	3		X	X	3
	4	Phase Vehicle	4		X		4
	5	Phase Vehicle	5		X		5
NOTICE PHASE 6 FLASH RED →	6	Phase Vehicle	6		X	X	6
	7	Phase Vehicle	7		X		7
	8	Phase Vehicle	8		X	X	8
NOTICE OVERLAP 1 FLASH RED →	9	Overlap	1		X	X	9
	10	Overlap	2		X	X	10
NOTICE OVERLAP 3 FLASH RED →	11	Overlap	3		X		11
	12	Overlap	4		X		12
	13	Phase Ped	2				13
	14	Phase Ped	4				14
	15	Phase Ped	6				15
	16	Phase Ped	8				16
	17	Overlap	5		X	X	17
	18	Overlap	6		X		18

MAXTIME STARTUP AND SOFTWARE FLASH PROGRAMMING DETAIL

Front Panel
Main Menu >Controller >Unit

Web Interface
Home >Controller >Unit


Modify parameters as shown below and save changes.

Startup Parameters	Unit Flash Parameters
Startup Clearance Hold	All Red Flash Exit Time
6	6

THIS ELECTRICAL DETAIL IS FOR
THE SIGNAL DESIGN: 08-0709T3
DESIGNED: June 2024
SEALED: 7/11/2024
REVISED:

Electrical Detail - Sheet 2 of 2
Temporary Design 3 (TMP Phase III)

M M
MOTT MACDONALD
MOTT MACDONALD I & E, LLC
930 Main Campus Drive
Suite 200
RALEIGH, NC 27606
License No. F-0669

ELECTRICAL AND PROGRAMMING
DETAILS FOR:
Prepared for:

750 N. Greenfield Pkwy, Corner, NC 27529

NC 211
at
SR 1238 (Love Grove Church Rd)
Division 8 Moore County West End
PLAN DATE: June 2024 REVIEWED BY: R. Mullinax
PREPARED BY: LD Stouchko REVIEWED BY:
REVISIONS INIT. DATE
DATE

DOCUMENT NOT CONSIDERED
FINAL UNLESS ALL
SIGNATURES COMPLETED
SEAL
NORTH CAROLINA
PROFESSIONAL
ENGINEER
SEAL
034437
LD STOUCHKO
DATE
SIG. INVENTORY NO. 08-0709T3