

### OVERLAP PROGRAMMING DETAIL FOR OVERLAP A\*

(program controller as shown below)

\*NOTE FOR ALL OVERLAPS: Use Default values for Overlap 'PLUS' programming details.

FROM MAIN MENU PRESS "1" CONTROLLER  
AND THEN "5" OVERLAPS

```

Overlaps
1.General Parm
2.Program
3.Status
  
```

```

General Overlap Parameters
Lock Inhibit OFF
Confl Lock Enable OFF
Parent P Cirncs ON
Extra Included Phases OFF
  
```

PRESS "ESC"

```

Overlaps
1.General Parm
2.Program
3.Status
  
```

Enter Overlap # 1  
then press Enter

```

Overlap A-1
1.Program Parm
2.Confl Prog+
3.Program Parm+
  
```

Notice  
Type  
FYA-4 →

```


Ovr lp A-1  Ps.....
Included Ps  1 0 0 0 0 0 0 0
Modifier Ps  2 0 0 0 0 0 0 0
Type:FYA-4  Grn: 0 Yel: 3.5 Red: 1.5
  
```

END OF OVERLAP PROGRAMMING DETAIL

THIS ELECTRICAL DETAIL IS FOR  
THE SIGNAL DESIGN: 07-1648T1  
DESIGNED: January 2025  
SEALED: 03-14-2025  
REVISED: N/A

13-MAR-2025 11:22 PW:///SUD0036343:wootr:ris-com:ATKMANCO/Document/Roads and Bridges/Projects/100059632 USSR S1g and ITS/Task 05.11.Signal/071648T1\_sml.ele\_2023mdd.dgn S1F4669 - AT U0591089

#### Electrical Detail - Sheet 2 of 3 Temporary Design 1



ELECTRICAL AND PROGRAMMING DETAILS FOR:		SR 1850 (Sandy Ridge Road) at I-40 EB Ramps	
Prepared for the Offices of:		Division 7 Guilford County Greensboro	
PLAN DATE: January 2025	REVIEWED BY: AM Encarnacion		
PREPARED BY: JT Stiff	REVIEWED BY: PL Alexander		
REVISIONS	INIT.	DATE	

DOCUMENT NOT CONSIDERED FINAL UNLESS ALL SIGNATURES COMPLETED

SEAL

Anthony Encarnacion  
PROFESSIONAL ENGINEER  
SEAL 044476  
ANTHONY M. ENCARNACION

3/14/2025  
DATE

SIG. INVENTORY NO. 07-1648T1