

OUTPUT CHANNEL CONFIGURATION

Front Panel  
Main Menu >Controller >More>Channels>Channels Config

Web Interface  
Home >Controller >Advanced IO>Channels>Channels Configuration

Channel Configuration

Channel	Control Type	Control Source	Flash Yellow	Flash Red	Flash Alt	MMU Channel
1	Phase Vehicle	1		X	X	1
2	Phase Vehicle	2		X		2
3	Phase Vehicle	3		X	X	3
4	Phase Vehicle	4		X		4
5	Phase Vehicle	5		X		5
6	Phase Vehicle	6		X	X	6
7	Phase Vehicle	7		X		7
8	Phase Vehicle	8		X	X	8
9	Overlap	1		X	X	9
10	Overlap	2		X	X	10
11	Overlap	3		X		11
12	Overlap	4		X		12
13	Phase Ped	2				13
14	Phase Ped	4				14
15	Phase Ped	6				15
16	Phase Ped	8				16
17	Overlap	5		X	X	17
18	Overlap	6		X		18

↑      ↑  
NOTE: ALL RED FLASH

OVERLAP PROGRAMMING

Front Panel  
Main Menu >Controller >Overlap >Overlap Parameters/Overlap Timings

Web Interface  
Home >Controller >Overlap Configuration >Overlaps

Overlap Plan 1

Overlap	3
Type	FYA 4 - Section
Included Phases	6
Modifier Phases	5
Modifier Overlaps	-
Trail Green	0
Trail Yellow	0.0
Trail Red	0.0

MAXTIME STARTUP AND SOFTWARE FLASH  
PROGRAMMING DETAIL

Front Panel  
Main Menu >Controller >Unit

Web Interface  
Home >Controller >Unit

Modify parameters as shown below and save changes.

Start Up Parameters

StartUp Clearance Hold
6

Unit Flash Parameters

All Red Flash Exit Time
6

THIS ELECTRICAL DETAIL IS FOR  
THE SIGNAL DESIGN: 06-0757T2  
DESIGNED: Feb 2025  
SEALED: 2/10/2025  
REVISED:


Temporary Design 2 - TMP Phase III, Step 1  
Electrical Detail - Sheet 2 of 2

DOCUMENT NOT CONSIDERED  
FINAL UNLESS ALL  
SIGNATURES COMPLETED



**STV Engineers, Inc.**  
900 West Trade St., Suite 715  
Charlotte, NC 28202  
(704) 372-1885  
NC License Number F-0991

ELECTRICAL AND PROGRAMMING  
DETAILS FOR:


Prepared for the Offices of:  
  
750 N.Greenfield Pkwy, Garner, NC 27529

SR 1997 (Fayetteville Road)  
at  
Farrington Street

Division 6      Robeson County      Lumberton

PLAN DATE:	Feb 2025	REVIEWED BY:	H.M. Surti
PREPARED BY:	J.C. Grimm	REVIEWED BY:	T.M. Woody
REVISIONS		INIT.	DATE

SEAL  
NORTH CAROLINA  
PROFESSIONAL  
ENGINEER  
TRENT M. WOODY  
040329

DocuSigned by:  
Trent M. Woody

2/10/2025  
DATE

SIG. INVENTORY NO. 06-0757T2